


Deborah Edwards
684 SW Marion Mann Terrace
Lake City, FL 32024

Maria Luisa Baque Manzo
Respalcorp Electric LLC
EC13009466



Notes:

- 1) TUB USES 10AMPS
- 2) NEW 20 AMP BREAKER W/NEW DEDICATED 120 VOLT GFCI PROTECTED TR OUTLET.
- 3) GFCI PROTECTION PROVIDED BY 20AMP GFCI BREAKER OR BLANKFACE GFCI.
- 4) TUB HAS REMOVABLE ACCESS PANEL ON FRONT FOR ACCESSIBILITY
- 5) WILL COMPLY W/NEC680.71, NEC680.74
- 6) WILL COMPLY W/FBC 314 SMOKE ALARMS WHERE EXISTING OR 10 YEAR WILL BE INSTALLED