

# Inspection Checklist for Permit #000055464

Notes:

Order	Category	Inspection	Requirements
1	Plumbing/Gas	<b>1st Underground Rough-In</b> <i>Inspects drainage and water piping before backfill. Ref: FBC-P 312</i>	
2	Building	<b>Framing</b> <i>Reviews structural framing, load paths, fire blocking, and MEP rough-ins prior to insulation. Ref: FBC 110.3(3)</i>	
3	Electrical	<b>2nd Rough-In</b> <i>Checks wiring, panel placement, and boxes before cover-up. Ref: NEC Art. 110.3</i>	
4	Plumbing/Gas	<b>2nd Rough-In</b> <i>Reviews piping, venting, and fixtures before wall close. Ref: FBC-P 312</i>	
5	Fire	<b>Sprinkler System Alteration</b> <i>Inspects modified sprinkler system installation. Ref: NFPA 13 §25.2</i>	
6	Heat & AC	<b>Rough-in/Duct</b>	
7	Mechanical	<b>Above Ceiling</b> <i>Reviews ductwork, fire dampers, and insulation before ceiling close. Ref: FBC-M 603</i>	
8	Building	<b>Insulation</b> <i>Verifies insulation type, R-value, and installation before drywall. Ref: FBC Energy C101.5</i>	
9	Fire	<b>Fire Final</b> <i>Full review of fire systems before occupancy. Ref: FBC 907</i>	
10	Building	<b>Final</b> <i>Ensures structure is complete, safe, and code-compliant before Certificate of Occupancy. Ref: FBC 110.5</i>	