

Inspection Checklist for Permit #000056471

Notes:

Order	Category	Inspection	Requirements
1	Electrical	Permanent Power <i>Releases power once service equipment is complete and safe. Ref: NEC Art. 230</i>	
2	Solar	Solar Final <i>Ensures PV system, inverter, and disconnects are safe/approved. Ref: NEC 690</i>	
3	Building	Footer <i>Inspects footing size, depth, and reinforcing steel before concrete placement. Ref: FBC 110.3(1)</i>	