



June 11, 2026

Mr. Chris Newsome
America's Home Place
282 Norman Drive, Suite B
Valdosta, GA 31601

**RE: NW Lona Loop
Lot 10 Fairfield Woods Subdivision
Parcel ID# 29-2S-16-02391-010
Columbia County, FL**

Dear Mr. Newsome:

After review of the foundation constructed and the associated elevations above finished grade, the finished floor of the slab is a minimum of 12" above grade at the high point of the existing grade. The parcel is not located in a flood zone per FEMA FIRM 120070 280 D, dated 11/02/2018 (Zone X), and all above the Flood Protection Elevation. Since the finished floor elevation is greater than 12" above existing grade at the high point of the existing grade, the slab elevation as constructed is acceptable.


If you have any questions or concerns regarding this project please do not hesitate to call me at your earliest convenience.

Sincerely,
WYE Engineering LLC

Eric W
Gooch

Digitally signed
by Eric W Gooch
Date: 2026.06.11
20:01:59 -04'00'

Eric W. Gooch, P.E.
FL PE 61686



This item has been digitally signed and sealed by Eric W. Gooch, PE on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

D:\WYE\Projects\Seminole Trusses\AmericasHomePlace\26003\Jackson\FL-Ltr-Elev.doc