

Columbia County Building Permit Application

etc # 12259

For Office Use Only Application # 0610-23 Date Received 10-6-06 By LH Permit # 25096
Application Approved by - Zoning Official BLK Date 09.10.06 Plans Examiner DK JTH Date 10-10-06
Flood Zone X Development Permit N/A Zoning RSF-2 Land Use Plan Map Category Residential
Comments Accessory Use

NOC EH Deed or PA Site Plan State Road Info Parent Parcel # Development Permit

Name Authorized Person Signing Permit Patty Wilson - letter of authorization given J.L. Dupree Contractor Phone 754 25678

Address 438 SW SR 247 Lake City FL - P.O. 2861 Lake 32025
Owners Name Columbia County Resources Phone 752 8822

911 Address 438 SW SR 247 Lake City FL 32025
Contractors Name J.L. Dupree Construction Phone 754 5678

Address PO Box 2861 Lake City FL 32056
Fee Simple Owner Name & Address

Bonding Co. Name & Address NA
Architect/Engineer Name & Address Bill Freeman Design

Mortgage Lenders Name & Address NA

Circle the correct power company - FL Power & Light - Clay Elec. - Suwannee Valley Elec. - Progressive Energy

Property ID Number 01-45-16-02642-000 Estimated Cost of Construction 13,000.00
Subdivision Name Lot Block Unit Phase

Driving Directions Branford Hwy (SR 247) to Mary Ethel Lane - turn Right follow around to 2nd gate at fairgrounds

Type of Construction Pole Barn - Wood Number of Existing Dwellings on Property NO

Total Acreage Lot Size Do you need a - Culvert Permit or Culvert Waiver or Have an Existing Drive

Actual Distance of Structure from Property Lines - Front 710 ft Side Side Rear
Total Building Height 15'8" Number of Stories 1 Heated Floor Area 600 SF FT Roof Pitch

Application is hereby made to obtain a permit to do work and installations as indicated. I certify that no work or installation has commenced prior to the issuance of a permit and that all work be performed to meet the standards of all laws regulating construction in this jurisdiction.

OWNERS AFFIDAVIT: I hereby certify that all the foregoing information is accurate and all work will be done in compliance with all applicable laws and regulating construction and zoning.

WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOU PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT.

Owner Builder or Authorized Person by Notarized Letter

STATE OF FLORIDA
COUNTY OF COLUMBIA

Sworn to (or affirmed) and subscribed before me this 6th day of October 2006.

Personally known X or Produced Identification

Contractor Signature J.L. Dupree
Contractors License Number CGC 0606031
Competency Card Number
NOTARY STAMP/SEAL

Shannon M Regar
My Commission DD364938
Expires October 21, 2008

Notary Signature (Revised Sept. 2006)

NOTICE OF COMMENCEMENT FORM
COLUMBIA COUNTY, FLORIDA

0610-23
***THIS DOCUMENT MUST BE RECORDED AT THE COUNTY
CLERKS OFFICE BEFORE YOUR FIRST INSPECTION.***

THE UNDERSIGNED hereby gives notice that improvement will be made to certain real property, and in accordance with Chapter 713, Florida Statutes, the following information is provided in this Notice of Commencement.

Tax Parcel ID Number C1-45-16-02642-0

PERMIT NUMBER _____

- Description of property: (legal description of the property and street address or 911 address)
N.W 1/4 of N.W 1/4 Ex 466.62 Ft E+W By 746.69 Ft H L S
- General description of improvement: Pole Barn
- Owner Name & Address Columbia County Resources
438 SW SR 247 Lake City FL 32056 Interest in Property 100%
- Name & Address of Fee Simple Owner (if other than owner): N/A
- Contractor Name JL Dupree Construction Phone Number 754 5678
Address P.O. Box 2861 Lake City FL 32056
- Surety Holders Name N/A Phone Number _____
Address _____
- Amount of Bond _____
- Lender Name N/A Phone Number _____
Address _____
- Persons within the State of Florida designated by the Owner upon whom notices or other documents may be served as provided by section 713.13 (1)(a) 7; Florida Statutes:
Name Steve Briscoe Phone Number 752 8822
Address 438 SW SR 247 Lake City FL 32056
- In addition to himself/herself the owner designates N/A of _____
_____ to receive a copy of the Lienor's Notice as provided in Section 713.13 (1) -
(a) 7. Phone Number of the designee N/A
- Expiration date of the Notice of Commencement (the expiration date is 1 (one) year from the date of recording, (Unless a different date is specified) 10/9/07

NOTICE AS PER CHAPTER 713, Florida Statutes:

The owner must sign the notice of commencement and no one else may be permitted to sign in his/her stead.

[Signature]
Signature of Owner

Sworn to (or affirmed) and subscribed before
day of October 9, 2006

NOTARY STAMP/SEAL
PATRICIA WILSON
MY COMMISSION # DD 278289
EXPIRES JANUARY 1, 2008
15003-NOTARY

[Signature]
Signature of Notary

Monday, October 09, 2006

Columbia County Building Dept.
Lake City, FL. 32055

RE: **PERMIT #0610-23**

To Whom It May Concern:

The header size on the pole barn structure may be changed from a double 2x12 #2 syp to a double 2x10 # 2 syp. The roofing covering shall be changed from 26 gage R-Panel roofing to an asphalt shingle. If you have any questions, please call me at (386) 758-4209.

Sincerely,



William H. Freeman, P.E.
President
Certificate of Authorization # 00008701



MIAMI-DADE COUNTY, FLORIDA
 METRO-DADE FLAGLER BUILDING
 140 WEST FLAGLER STREET, SUITE 1603
 MIAMI, FLORIDA 33130-1563
 (305) 375-2901 FAX (305) 375-2908

BUILDING CODE COMPLIANCE OFFICE (BCCO)
 PRODUCT CONTROL DIVISION

NOTICE OF ACCEPTANCE (NOA)

Tamko Roofing Products, Inc.
 P.O. Box 1404
 Joplin, MO 64802

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: TAMKO ASTM Heritage 30, 40 & 50 Roof Shingles

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This consists of pages 1 through 4.

The submitted documentation was reviewed by Frank Zuloaga, RRC



NOA No.: 02-0501.03
 Expiration Date: 03/21/07
 Approval Date: 05/30/02
 Page 1 of 4

ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub-Category: 07310 Composition Shingles
Materials: Dimensional
Deck Type: Wood

1. SCOPE:

This approves **Tamko ASTM Heritage 30 AR, Heritage 40 AR and Heritage 50 AR** Asphalt Shingles, manufactured by **Tamko Roofing Products, Inc.** as described in this Notice of Acceptance.

2. PRODUCT DESCRIPTION

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
ASTM Heritage 30 AR	12" x 37"	PA 110	A heavy weight, 240lb/sq, dimensional asphalt shingle.
Heritage 40 AR	12" x 36"	PA 110	A heavy weight, 275lb/sq, dimensional asphalt shingle.
Heritage 50 AR	12" x 36"	PA 110	A heavy weight, 305lb/sq, dimensional asphalt shingle.

3. LIMITATIONS

- 3.1 Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 3.2 Shall not be installed on roof mean heights in excess of 33 ft.

4. INSTALLATION

- 4.1 Shingles shall be installed in accordance with Roofing Application Standard RAS 115.
- 4.2 The manufacturer shall provide clearly written application instructions.
- 4.3 Exposure and course layout shall be in compliance with Detail 'A', attached.
- 4.4 Nailing shall be in compliance with Detail 'B', attached.

5. LABELING

- 5.1 Shingles shall be labeled with the Miami-Dade Logo or the wording "Miami-Dade County-Product Control Approved".

6. BUILDING PERMIT REQUIREMENTS


- 6.1 Application for building permit shall be accompanied by copies of the following:
 - 6.1.1 This Notice of Acceptance.
 - 6.1.2 Any other documents required by the Building Official or the applicable Building Code in order to properly evaluate the installation of this system.



DETAIL A


ASTM HERITAGE 30

All dimensions are in inches.



HERITAGE 40 & 50


All dimensions are in inches.



DETAIL B


ASTM HERITAGE 30

12" x 37" LAMINATED SHINGLE
All dimensions are in inches.



HERITAGE 40 & 50

12" x 36" LAMINATED SHINGLE
All dimensions are in inches.



END OF THIS ACCEPTANCE



NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED
(For File ONLY. Not part of NOA.)

A. EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Underwriters Laboratories, Inc.	PA 107	01NK409172	12/04/01
Underwriters Laboratories, Inc.	Letter ASTM D3462	R2919	02/25/02
PRI Asphalt Technologies, Inc.	PA 100	TAP-052-02-01 TAP-053-02-01 TAP-054-02-01	11/28/01 11/29/01 11/29/01

B. OTHER

1. Notice of Acceptance number 02-0130.02



MIAMI-DADE COUNTY, FLORIDA
 METRO-DADE FLAGLER BUILDING
 140 WEST FLAGLER STREET, SUITE 1603
 MIAMI, FLORIDA 33130-1563
 (305) 375-2901 FAX (305) 375-2908

BUILDING CODE COMPLIANCE OFFICE (BCCO)
 PRODUCT CONTROL DIVISION

NOTICE OF ACCEPTANCE (NOA)

Tamko Roofing Products, Inc.
 P.O. Box 1404
 Joplin, MO 64802

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: TAMKO ASTM Heritage 30, 40 & 50 Roof Shingles

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENTS: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This consists of pages 1 through 4.

The submitted documentation was reviewed by Frank Zuloaga, RRC



ROOFING ASSEMBLY APPROVAL

Category:

Roofing

Sub-Category:

07310 Composition Shingles

Materials

Dimensional

Deck Type:

Wood

1. SCOPE:

This approves **Tamko ASTM Heritage 30 AR, Heritage 40 AR and Heritage 50 AR** Asphalt Shingles, manufactured by **Tamko Roofing Products, Inc.** as described in this Notice of Acceptance.

2. PRODUCT DESCRIPTION

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
ASTM Heritage 30 AR	12" x 37"	PA 110	A heavy weight, 240lb/sq, dimensional asphalt shingle.
Heritage 40 AR	12" x 36"	PA 110	A heavy weight, 275lb/sq, dimensional asphalt shingle.
Heritage 50 AR	12" x 36"	PA 110	A heavy weight, 305lb/sq, dimensional asphalt shingle.

3. LIMITATIONS

- 3.1 Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 3.2 Shall not be installed on roof mean heights in excess of 33 ft.

4. INSTALLATION

- 4.1 Shingles shall be installed in accordance with Roofing Application Standard RAS 115.
- 4.2 The manufacturer shall provide clearly written application instructions.
- 4.3 Exposure and course layout shall be in compliance with Detail 'A', attached.
- 4.4 Nailing shall be in compliance with Detail 'B', attached.

5. LABELING

- 5.1 Shingles shall be labeled with the Miami-Dade Logo or the wording "Miami-Dade County-Product Control Approved".

6. BUILDING PERMIT REQUIREMENTS


- 6.1 Application for building permit shall be accompanied by copies of the following:
 - 6.1.1 This Notice of Acceptance.
 - 6.1.2 Any other documents required by the Building Official or the applicable Building Code in order to properly evaluate the installation of this system.



DETAIL A


ASTM HERITAGE 30

All dimensions are in inches.



HERITAGE 40 & 50


All dimensions are in inches.



DETAIL B


ASTM HERITAGE 30

12" x 37" LAMINATED SHINGLE
All dimensions are in inches.



HERITAGE 40 & 50

12" x 36" LAMINATED SHINGLE
All dimensions are in inches.



END OF THIS ACCEPTANCE



NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED
(For File ONLY. Not part of NOA.)

A. EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Underwriters Laboratories, Inc.	PA 107	01NK409172	12/04/01
Underwriters Laboratories, Inc.	Letter ASTM D3462	R2919	02/25/02
PRI Asphalt Technologies, Inc.	PA 100	TAP-052-02-01 TAP-053-02-01 TAP-054-02-01	11/28/01 11/29/01 11/29/01

B. OTHER

1. Notice of Acceptance number 02-0130.02

MIAMI-DADE

BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

Tamko Roofing Products, Inc.
P.O. Box 1404
Joplin, MO 64802

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: TAMKO ASTM Heritage 30, 40 & 50 Roof Shingles

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This consists of pages 1 through 4.
The submitted documentation was reviewed by Frank Zaloga, RRC



ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub-Category: 07310 Composition Shingles
Materials: Dimensional
Deck Type: Wood

1. SCOPE:

This approves **Tamko ASTM Heritage 30 AR, Heritage 40 AR and Heritage 50 AR** Asphalt Shingles, manufactured by **Tamko Roofing Products, Inc.** as described in this Notice of Acceptance.

2. PRODUCT DESCRIPTION

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
ASTM Heritage 30 AR	12" x 37"	PA 110	A heavy weight, 240lb/sq, dimensional asphalt shingle.
Heritage 40 AR	12" x 36"	PA 110	A heavy weight, 275lb/sq, dimensional asphalt shingle.
Heritage 50 AR	12" x 36"	PA 110	A heavy weight, 305lb/sq, dimensional asphalt shingle.

3. LIMITATIONS

- 3.1 Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 3.2 Shall not be installed on roof mean heights in excess of 33 ft.

4. INSTALLATION

- 4.1 Shingles shall be installed in accordance with Roofing Application Standard RAS 115.
- 4.2 The manufacturer shall provide clearly written application instructions.
- 4.3 Exposure and course layout shall be in compliance with Detail 'A', attached.
- 4.4 Nailing shall be in compliance with Detail 'B', attached.

5. LABELING

- 5.1 Shingles shall be labeled with the Miami-Dade Logo or the wording "Miami-Dade County-Product Control Approved".

6. BUILDING PERMIT REQUIREMENTS


- 6.1 Application for building permit shall be accompanied by copies of the following:
 - 6.1.1 This Notice of Acceptance.
 - 6.1.2 Any other documents required by the Building Official or the applicable Building Code in order to properly evaluate the installation of this system.



DETAIL A


ASTM HERITAGE 30

All dimensions are in inches.



HERITAGE 40 & 50

All dimensions are in inches.




DETAIL B

ASTM HERITAGE 30

12" x 37" LAMINATED SHINGLE


All dimensions are in inches.



HERITAGE 40 & 50

12" x 36" LAMINATED SHINGLE

All dimensions are in inches.



END OF THIS ACCEPTANCE



NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED
(For File ONLY. Not part of NOA.)

A. EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Underwriters Laboratories, Inc.	PA 107	01NKK409172	12/04/01
Underwriters Laboratories, Inc.	Letter ASTM D3462	R2919	02/25/02
PRI Asphalt Technologies, Inc.	PA 100	TAP-052-02-01 TAP-053-02-01 TAP-054-02-01	11/28/01 11/29/01 11/29/01

B. OTHER

1. Notice of Acceptance number 02-0130.02

COLUMBIA COUNTY BUILDING DEPARTMENT

**COMMERCIAL MINIMUM PLAN REQUIREMENTS AND CHECKLIST
FOR FLORIDA BUILDING CODE 2001 WITH AMENDMENTS**

ALL REQUIREMENTS LISTED ARE SUBJECT TO CHANGE
EFFECTIVE MARCH 1, 2002

ALL BUILDING PLANS MUST INCLUDE THE FOLLOWING ITEMS AND INDICATE COMPLIANCE WITH CHAPTER 1606 OF THE FLORIDA BUILDING CODE 2001 WITH AMENDMENTS BY PROVIDING CALCULATIONS AND DETAILS THAT HAVE THE SIGNATURE AND SEAL OF A CERTIFIED ARCHITECT OR ENGINEER REGISTERED IN THE STATE OF FLORIDA. THE FOLLOWING BASIC WIND SPEED AS PER SECTION 1606 SHALL BE USED.

WIND SPEED LINE SHALL BE DEFINED AS FOLLOWS: THE CENTERLINE OF INTERSTATE 75

1. ALL BUILDINGS CONSTRUCTED EAST OF SAID LINE SHALL BE ----- 100 MPH
2. ALL BUILDINGS CONSTRUCTED WEST OF SAID LINE SHALL BE ----- 110 MPH
3. NO AREA IN COLUMBIA COUNTY IS IN A WIND BORNE DEBRIS REGION

APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL

GENERAL REQUIREMENTS: Two (2) complete sets of plans containing a floor plan, site plan, foundation plan, floor/roof framing plan or truss layout, wall sections and all exterior elevations with the following criteria and documents:

Applicant

Plans Examiner

- | | | |
|-------------------------------------|--------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | All drawings must be clear, concise and drawn to scale ("Optional" details that are not used shall be marked void or crossed off). Square footage of different areas shall be shown on plans. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Designers name and signature on document (FBC 104.2.1) If licensed architect or engineer, official seal shall be affixed. |
| <input type="checkbox"/> | <input type="checkbox"/> | <u>Two (2) Copies of Approved Site Plan</u> |
| <input type="checkbox"/> | <input type="checkbox"/> | <u>Minimum Type Construction (FBC Table 500)</u> |
| <input type="checkbox"/> | <input type="checkbox"/> | <u>Wind Load Engineering Summary, calculations and any details required:</u>
a) Plans or specifications must state compliance with FBC Section 1606
b) The following information must be shown as per section 1606.1.7 FBC <ol style="list-style-type: none">1. Basic wind speed (MPH)2. Wind importance factor (I) and building category3. Wind exposure – if more than one wind exposure is used, the wind exposure and applicable wind direction shall be indicated4. The applicable internal pressure coefficient5. Components and Cladding. The design wind pressure in terms of psf (kN/m²), to be used for the design of exterior component and cladding materials not specifically designed by the registered design professional |
| <input type="checkbox"/> | <input type="checkbox"/> | <u>Fire Resistant Construction Requirements shall include:</u>
a) Fire resistant separations (listed system)
b) Fire resistant protection for type of construction
c) Protection of openings and penetrations of rated walls (listed systems)
d) Fire blocking and draft-stopping
e) Calculated fire resistance |

NA

NH

Fire Suppression Systems shall include: (To be reviewed by Fire Department)

- a) Fire sprinklers
- b) Fire alarm system (early warning) with name of licensed installer. If not shown on plans or not known at time of permitting, a separate permit shall be required by the licensed installer
- c) Smoke evacuation system schematic
- d) Stand-pipes
 - Pre-engineered system
 - Riser diagram

NH

Life Safety Systems shall include: (To be reviewed by Fire Department)

- a) Occupancy load and egress capacity
- b) Early warning
- c) Smoke control
- d) Stair pressurization
- e) Systems schematic

NH

Occupancy Load/Egress Requirements shall include:

- a) Occupancy load (gross and net)
- b) Means of egress
 - exit access, exit and exit discharge
- c) Stair construction/geometry and protection
- d) Doors
- e) Emergency lighting and exit signs
- f) Specific occupancy requirements
 - 1. Construction requirements
 - 2. Horizontal exits/exit passageways

NH

Structural Requirements shall include:

- a) Soil conditions/analysis
- b) Show type of termite treatment (termicide or alternative method)
- c) Design loads
- d) Wind requirements
- e) Building envelope
- f) Structural calculations
- g) Foundations
- h) Wall systems
- i) Floor systems
- j) Roof systems
- k) Threshold inspection plan (if applicable)
- l) Stair systems

Materials shall include:

- a) Wood
- b) Steel
- c) Aluminum
- d) Concrete
- e) Plastic
- f) Glass (mfg. Listing for wind zone including details for installation and attachments)
- g) Masonry
- h) Gypsum board and plaster
- i) Insulating (mechanical)
- j) Roofing (mfg. Listed system for wind zone with installation and attachments)
- k) Insulation

NA

-
-
-
-
-
-
-

Accessibility Requirements shall include:

- a) Site requirements
- b) Accessible route
- c) Vertical accessibility
- d) Toilet and bathing facilities
- e) Drinking fountains
- f) Equipment
- g) Special occupancy requirements
- h) Fair housing requirements

NA

-
-
-

Interior Requirements shall include:

- a) Interior finishes (flame spread/smoke develop)
- b) Light and ventilation
- c) Sanitation

NA

-
-
-

Special Systems shall include:

- a) Elevators
- b) Escalators
- c) Lifts

Swimming Pools – Commercial – Plans shall be signed and sealed by a Professional Engineer registered in the State of Florida and approved by the Department of Business and Professional Regulation/Health Department Indicating compliance with the Florida Administrative Code, Chapter 64E-9 And Section 424 of the Florida Building Code

NA

-
-
-
-
-
-
-
-

Electrical:

- a) Electrical wiring, services, feeders and branch circuits, over-current protection, grounding, wiring methods and materials, GFCIs
- b) Equipment
- c) Special Occupancies
- d) Emergency Systems
- e) Communication Systems
- f) Low Voltage
- g) Load calculations
- h) Riser diagram

NA

-
-
-
-
-
-
-
-
-
-
-
-
-
-

Plumbing:

- a) Minimum plumbing facilities
- b) Fixture requirements
- c) Water supply piping
- d) Sanitary drainage
- e) Water heaters
- f) Vents
- g) Roof drainage
- h) Back flow prevention
- i) Irrigation
- j) Location of water supply
- k) Grease traps
- l) Environmental requirements
- m) Plumbing riser

THE FOLLOWING ITEMS MUST BE SUBMITTED WITH BUILDING PLANS:

1. **Building Permit Application:** A current Building Permit Application form is to be completed and submitted for all construction projects; If you were required to have a Site and Development Plan Approval, list SDP number.
2. **Parcel Number:** The parcel number (Tax ID number) from the Property Appraiser is required. A copy of property deed is also requested. (386) 758-1084
3. **Environmental Health Permit or Sewer Tap Approval:** A copy of the Environmental Health permit, existing septic tank approval or sewer tap is required
4. **City Approval:** If the project is located within the city limits of the Town of Fort White prior approval is required. The Town of Fort White approval letter is required to be submitted by the owner or contractor to this office when applying for a Building Permit. (386) 497-2321
5. **Flood Information:** All projects within the Floodway of the Suwannee or Santa Fe Rivers shall require permitting through the Suwannee River Water Management District, before submitting application to this office. Any project located within a flood zone where the base flood elevation (100 year flood) **has been** established shall meet the requirements of section 8.8 of the Columbia County Land Development Regulations. Any project that is located within a flood zone where the base flood elevation (100 year flood) **has not been** established shall meet the requirements of section 8.7 of the Columbia County Land Development Regulations. **CERTIFIED FINISHED FLOOR ELEVATIONS WILL BE REQUIRED ON ANY PROJECT WHERE THE BASE FLOOD ELEVATION (100 YEAR FLOOD) HAS BEEN ESTABLISHED.**
A development permit will also be required. **The development permit cost is \$50.00**
6. **Driveway Connection:** If the property does not have an existing access to a public road, then an application for a culvert permit must be made (**\$25.00**). Culvert installation for commercial, industrial and other uses shall **conform to the approved site plan or to the specifications of a registered engineer. Joint use culverts will comply with Florida Department of Transportation specifications.** If the project is to be located on a F.D.O.T. maintained road, then an F.D.O.T. access permit is required.
7. **Suwannee River Water Management District Approval:** All commercial projects must have an SRWMD permit issued or an exemption letter, before a building will be issued.

ALL REQUIRED INFORMATION IS TO BE SUBMITTED FOR REVIEW. YOU WILL BE NOTIFIED WHEN YOUR APPLICATION AND PLANS ARE APPROVED AND READY TO PERMIT. PLEASE DO NOT EXPECT OR REQUEST THAT PERMIT APPLICATIONS BE REVIEWED OR APPROVED WHILE YOU ARE HERE – TIME WILL NOT ALLOW THIS – PLEASE DO NOT ASK



Columbia County 9-1-1 Addressing / GIS Department

P.O. Box 1787, Lake City, FL 32056

Telephone: (386) 758-1125 * Fax: (386) 758-1365 * E-mail: ron_croft@columbiacountyfla.com



9-1-1 Address Request Form

NOTE: ADDRESS ASSIGNMENT MAY REQUIRE UP TO 10 WORKING DAYS. IF THE ADDRESSING DEPARTMENT NEEDS TO CONDUCT ON SITE GPS LOCATION IDENTIFICATION, ADDITIONAL TIME MAY BE REQUIRED.

Date of Request: _____

Requester Last Name: _____

First Name: _____

Contact Telephone Number: _____

(Cell Phone Number if Provided): _____

Requested for Self: _____ or Requested for Company: _____
(check one)

If Address is Requested by a Company, Provide Name of Requesting Company:

Parcel Identification Number: _____ - _____ - _____ - _____

If in Subdivision, Provide Name Of Subdivision:

Phase or Unit Number (if any): _____ Block Number (if any): _____

Lot Number: _____

Attach Site Plan or you may use back of Request Form for Site Plan:

Requirements for Site Plan Are Listed on Back of Request From:

(NOTE: Site Plan Does NOT have to be a survey or to scale; FURTHER a Environmental Health Dept. Site Plan showing only a 210 by 210 cutout of a property will NOT suffice for Addressing Requirements.)

Addressing / GIS Department Use Only:


Date Received: _____

Date Assigned: _____

ID Number: _____

1. A PLAT, PLAN, OR DRAWING SHOWING THE PROPERTY LINES OF THE PARCEL.
2. LOCATION OF PLANNED RESIDENT OR BUSINESS STRUCTURE ON THE PROPERTY WITH DISTANCES FROM AT LEAST TWO OF THE PROPERTY LINES TO THE STRUCTURE (SEE SAMPLE BELOW).
3. LOCATION OF THE ACCESS POINT (DRIVEWAY, ETC.) ON THE ROADWAY FROM WHICH LOCATION IS TO BE ADDRESSED WITH A DISTANCE FROM A PARALLEL PROPERTY LINE AND OR PROPERTY CORNER (SEE SAMPLE BELOW).
4. TRAVEL OF THE DRIVEWAY FROM THE ACCESS POINT TO THE STRUCTURE (SEE SAMPLE BELOW).

SAMPLE:



SITE PLAN BOX:

