



---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

10/09/2020

Permit # 000039682

Lot 44 of Crosswinds Phase 1

L-26950

Lipscomb & Eagle

To whom it may concern,

The elevation of the top of the slab on Lot 44 is found to be 101.08 feet. The minimum floor elevation is shown to be 1 foot above the road (assumed 100 feet) per the permit.

The Elevations shown hereon are based on assumed Datum.

Sincerely,

A handwritten signature in black ink, appearing to read "L. Scott Britt", is written over a circular, faint background stamp.

L. Scott Britt  
LS 5757