

Name of person this mobile home home is for?	MIKAYLA SMITH
Resident's Phone #	904-608-6671
Are you applying for a 5 year temporary permit?	Yes
Special temporary use permit number:	STUP260205
Septic #	26-0296
Setback Info	
Site Plan Setbacks Front	530
Site Plan Setbacks Side 1	50
Site Plan Setbacks Side 2	370
Site Plan Setbacks Rear	310
Optional Job Notes	

Review Notes: NEEDED

* THERE IS A SIGNIFICANT DIFFERENCE IN THE ELEVATION OF THE ROAD AND THE ELEVATION AT THE PROPOSED DEVELOPMENT. AN ENGINEER LETTER WILL BE REQUIRED TO ASSURE THAT THE MINIMUM FLOOR ELEVATION WILL BE SUFFICIENT TO AVOID POSSIBLE RISING WATERS OF THE AREA--- RECEIVED, NEEDS REVIEWED