



# 53433

---

**Britt Surveying and Mapping, LLC**

1438 SW Main Boulevard • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

03/25/2022

Permit # 000043744

L-28429


Brown Gate Land Trust

Re: Lot 2 Oak Forest Landing

To Whom It May Concern:

The top of the mobile home finished floor on Lot 2 is found to be 168.31 feet. The building permit shows the minimum floor elevation to be 166.5 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,



L. Scott Britt

LS 5757