



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

12/01/2020

Permit # 000040087

L-27027

Re: Lot 4 Emerald Cove, Phase 1

Sylvester Warren

To Whom It May Concern:

The finished floor elevation is established to be 105.68 feet. The highest adjacent grade is 104.5 feet and the lowest adjacent grade is 103.6 feet. The elevations shown hereon are in NAVD 88 datum. The Minimum Floor Elevation is required to be 103 feet.

Sincerely,


L. Scott Britt
LS 5757

