

# Inspection Checklist for Permit #000055960

Notes:

<b>Order</b>	<b>Category</b>	<b>Inspection</b>	<b>Requirements</b>
1	Plumbing/Gas	<b>1st Underground Rough-In</b> <i>Inspects drainage and water piping before backfill. Ref: FBC-P 312</i>	
2	Electrical	<b>2nd Rough-In</b> <i>Checks wiring, panel placement, and boxes before cover-up. Ref: NEC Art. 110.3</i>	
3	Plumbing/Gas	<b>2nd Rough-In</b> <i>Reviews piping, venting, and fixtures before wall close. Ref: FBC-P 312</i>	
4	Building	<b>Insulation</b> <i>Verifies insulation type, R-value, and installation before drywall. Ref: FBC Energy C101.5</i>	
5	Building	<b>Final</b> <i>Ensures structure is complete, safe, and code-compliant before Certificate of Occupancy. Ref: FBC 110.5</i>	