



Lake City (386) 755-3611
Fax (321) 233-0265
aspenpc@gmail.com

Certificate of Compliance for Termite Protection
(as required by Florida Building Code (FBC) 1816.1.7)

Aspen Pest Control, Inc.
(386) 755-3611
State License # - JB182948
State Certification # - JF104376

2166 SW Challenger Ln. Lake City, FL 32025
Address of Treatment or Lot/Block of Treatment **House & Hanger**

Soil Barrier

(Method of Termite Prevention Treatment - Soil Barrier, Wood Treatment, Bait System, Other)

Horizontal, Vertical and Exterior Treatment

Description of Treatment

The above named structure has received a complete treatment for the prevention of subterranean termites. Treatment was done in accordance with the rules and laws established by the Florida Department of Agriculture and Consumer Services.

Shannon August
Authorized Signature

5-11-2026
Date



Commercial • Residential
P.O. Box 1795 / Lake City, FL 32056



Envelope Leakage Test Report (Blower Door Test)

Residential Prescriptive, Performance or ERI Method Compliance

Florida Building Code 2023, 8th Edition

Jurisdiction:

Permit #: 000054697

Job Information

Builder: RJH Construction Community: Bixler (Hanger) Lot:

Address: 266 SW Challenger Lane Unit:

City: Lake City State: FL Zip:

Air Leakage Test Results Passing results must meet either the Performance, Prescriptive, or ERI Method

PRESCRIPTIVE METHOD- The building or dwelling unit shall be tested and verified as having an air leakage rate of not exceeding 7 air changes per hour at a pressure of 0.2 inch w.g. (50 pascals) in Climate Zones 1 and 2.

PERFORMANCE or ERI METHOD- The building or dwelling unit shall be tested and verified as having an air leakage rate of not exceeding the selected ACH(50) value, as shown on FORM R405- (Performance) or R406- (ERI), section labeled as infiltration, sub-section ACH.

ACH(50) specified on Form R405- Energy Calc (Performance) or R406- (ERI):

$$\frac{793.3}{\text{CFM}(50)} \times 60 + \frac{8000}{\text{Building Volume}} = \frac{5.95}{\text{ACH}(50)}$$

PASS **FAIL**

When ACH(50) is less than 3, Mechanical Ventilation installation must be verified by building department.

Method for calculating building volume:

Retrieved from architectural plans

Code software calculated

Field measured and calculated

Testing. Testing shall be conducted in accordance with ANSI/RESNET/ICC 380 and reported at a pressure of 0.2 inch w.g. (50 Pascals). Testing shall be conducted by either individuals as defined in Section 553.993(5) or (7), Florida Statutes, or individuals licensed as set forth in Section 489.105(3)(f), (g), or (i) or an approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the code official. Testing shall be performed at any time after creation of all penetrations of the building thermal envelope.

During testing:

1. Exterior windows and doors, fireplace and stove doors shall be closed, but not sealed, beyond the intended weatherstripping or other infiltration control measures.
2. Dampers including exhaust, intake, makeup air, back draft and flue dampers shall be closed, but not sealed beyond intended infiltration control measures.
3. Interior doors, if installed at the time of the test, shall be open.
4. Exterior doors for continuous ventilation systems and heat recovery ventilators shall be closed and sealed.
5. Heating and cooling systems, if installed at the time of the test, shall be turned off.
6. Supply and return registers, if installed at the time of the test, shall be fully open.

Testing Company

Company Name: UES Professional Solutions, LLC Phone: 352 372 3392

I hereby verify that the above Air Leakage results are in accordance with the 2023 8th Edition Florida Building Code Energy Conservation requirements according to the compliance method selected above.

Signature of Tester: Nicholas Gauthier Date of Test: 5-28-26

Printed Name of Tester: Nicholas Gauthier

License/Certification #: 24099520 Issuing Authority: Retrotec