



**NICHOLAS
PAUL
GEISLER
ARCHITECT**

N.C.A.R.B. Certified

1758 NW Brown Rd.

Lake City, FL 32055

26th DECEMBER 2019

BUILDING OFFICIAL / INSPECTOR
COUNTY BUILDING DEPT.

RE: GLACKIN RESIDENCE

TO WHOM IT MAY CONCERN:

THE GABLE DORMERS WILL BE STRAPPED AS FOLLOWS. STRAP VALLEY STRINGERS TO TOP PLATE WITH TWIST STRAPS. ANCHOR RIDGE BEAM TO VERTICAL STUD WITH TWIST STRAP TOP, AND BOTTOM OF SUPPORT STUD WITH 6P2 TO DBL TOP PLATE. ALL RAFTERS TOE NAILED TO RIDGE AND VALLEY STRINGERS. ATTACH WINDOW KING STUDS TO DBL TOP PLATE WITH MSTAIB FLAT STRAPS.

BEST REGARDS,

