

**Mark D. Duren and  
Associates, Inc.  
Professional Surveyor and Mapper**

1604 SW SISTERS WELCOME ROAD  
Lake City, FL 32025  
386-758-9831 Phone  
386-758-8010 Fax  
[mddpsm@markduren.com](mailto:mddpsm@markduren.com)  
[jldmddpsm@gmail.com](mailto:jldmddpsm@gmail.com)

June 2, 2026


IE. Foundation elevation of building under construction at 135 SW Cherry Blossum way, Lake City, FL. 32024, Tax Parcel No. 15-4S-17-03011-110.

To Whom It May Concern,

A minimum floor elevation of 104.0 feet, the datum is not specified on the plat, is established for the parcel on site plan of "Rose Pointe", according to a copy of the site plan provided to this office.

The elevation of the top of the concrete slab of the main floor of the dwelling is 104.1 feet, NAVD 1988 datum, 104.9 feet, NGVD 1929 datum, based on elevations derived from Benchmark "Steinried AZ MK", NGS PID BD1035. The published elevation is 140.93 feet, NAVD 1988 datum. The published NGVD 1929 datum elevation for this benchmark is 141.74 feet.

Mark D. Duren LS 4708  
June 2, 2026



WO# 26-153