

## Soil Nuclear Gauge

**Report #:** SNG-000006

**Report Date:** 11/2/2020

**Test Method:** ASTM D 6938

### Client:

Ajax Building Corporation  
1080 Commerce Blvd.  
Midway, FL 32343

### Project:

10117-1020031.000  
Columbia County Detention Facility Materials  
Testing

Jacksonville, Florida

Test Results														
Test #	Retest Of	Test Date	Proctor ID	Method	Soil Classification	Optimum Moisture (%)	Maximum Dry Density (pcf)	In Place Moisture (%)	In Place Dry Density (pcf)	In Place Wet Density (pcf)	Probe Depth (in)	Percent Compaction	Min Comp. (%)	Remark
23		10/30/20	P-3 MODIFIED	D1557 A	SP-SM	8.3	118.0	6.7	115.7	123.5	12	98	95	DP
Test Information														
Test #	Test Location						Elevation	Reference		Gauge Make / Model / SN / Calibrated			Field Technician	
23	Utility Trench Backfill: Sanitary Sewer: Sanitary sewer pipe between structures S02 and S01						177.0	MSL		Troxler / 3430 / 21834 /			Raymond Easley	
Remarks					Comments									
DP: Density Pass					Tests are "Direct Transmission" (Method A) unless probe depth is noted as "Backscatter". Gauge calibration data on file with the testing agency.									

Electronically signed and sealed by William L. Lawrence, P.E., Senior Regional Engineer on Nov 06, 2020 using a Digital Signature.

Should the areas tested be subject to rain, freezing, or other adverse conditions, prior to paving, concreting, etc, NOVA recommends re-evaluation.

Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.

Information provided herein is intended for the sole and exclusive use of our Client unless other written agreement is entered into by NOVA and other parties.

Other recipients are provided this document for information purposes only and use of said information shall be at their sole risk. Report shall not be reproduced, except in full, without prior written consent of the agency.