

Project Information

For: **Trafco**
 466 SW Winswept GLN, Lake City, FL 32024

Notes:

Design Information

Weather: Gainesville, FL, US

Winter Design Conditions

Outside db 33 °F
 Inside db 70 °F
 Design TD 37 °F

Ventilation Method MJ8

Heating Summary

Structure 11982 Btuh
 Ducts (R-6.0) 2183 Btuh
 Central vent (0 cfm) 0 Btuh

Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 14166 Btuh

Infiltration

Method Simplified
 Construction quality Average
 Fireplaces 0

	Heating	Cooling
Area (ft ²)	605	605
Volume (ft ³)	4830	4830
Air changes/hour	0.61	0.32
Equiv. AVF (cfm)	49	26

Heating Equipment Summary

Make Trane
 Trade TRANE
 Model 4TWR4018N1000A
 AHRI ref 209842209

Efficiency 7.5 HSPF2
 Heating input
 Heating output 19300 Btuh @ 47°F
 Temperature rise 27 °F
 Actual air flow 643 cfm
 Air flow factor 0.045 cfm/Btuh
 Static pressure 0.53 in H2O
 Space thermostat
 Capacity balance point = 22 °F

Backup:
 Input = 4 kW, Output = 13611 Btuh, 100 AFUE

Summer Design Conditions

Outside db 92 °F
 Inside db 75 °F
 Design TD 17 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 43 gr/lb

Sensible Cooling Equipment Load Sizing

Structure 12645 Btuh
 Ducts (R-6.0) 3078 Btuh
 Central vent (0 cfm) 0 Btuh

Blower 0 Btuh

Use manufacturer's data y
 Rate/swing multiplier 1.00
 Equipment sensible load 15724 Btuh

Latent Cooling Equipment Load Sizing

Structure 758 Btuh
 Ducts 630 Btuh
 Central vent (0 cfm) 0 Btuh

Equipment latent load 1388 Btuh

Equipment Total Load (Sen+Lat) 17112 Btuh
 Req. total capacity at 0.80 SHR 1.6 ton

Cooling Equipment Summary

Make Trane
 Trade TRANE
 Cond 4TWR4018N1000A
 Coil TEM4B0B24M21SA
 AHRI ref 209842209

Efficiency 11.7 EER2, 14.3 SEER2
 Sensible cooling 15440 Btuh
 Latent cooling 3860 Btuh
 Total cooling 19300 Btuh
 Actual air flow 643 cfm
 Air flow factor 0.041 cfm/Btuh
 Static pressure 0.53 in H2O
 Load sensible heat ratio 0.92

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Project Information

For: Trafco
466 SW Winswept GLN, Lake City, FL 32024

Cooling Equipment

Design Conditions

Outdoor design DB:	92.4°F	Sensible gain:	15724 Btuh	Entering coil DB:	77.2°F
Outdoor design WB:	75.8°F	Latent gain:	1388 Btuh	Entering coil WB:	63.6°F
Indoor design DB:	75.0°F	Total gain:	17112 Btuh		
Indoor RH:	50%	Estimated airflow:	643 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Trane	Model:	4TWR4018N1000A+TEM4B0B24M21SA		
Actual airflow:	643 cfm				
Sensible capacity:	15291 Btuh	97% of load			
Latent capacity:	3204 Btuh	231% of load			
Total capacity:	18495 Btuh	108% of load	SHR:	83%	

Heating Equipment

Design Conditions

Outdoor design DB:	33.3°F	Heat loss:	14166 Btuh	Entering coil DB:	68.9°F
Indoor design DB:	70.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Trane	Model:	4TWR4018N1000A+TEM4B0B24M21SA		
Actual airflow:	643 cfm				
Output capacity:	15533 Btuh	110% of load		Capacity balance:	22 °F
Supplemental heat required:	0 Btuh			Economic balance:	-99 °F

Backup equipment type:	Elec strip				
Manufacturer:		Model:			
Actual airflow:	643 cfm				
Output capacity:	4.0 kW	96% of load	Temp. rise:	50 °F	

Meets all requirements of ACCA Manual S.