



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

5/05/2026

L-32273

Re: 31-4S-17-08915-103

John Altebaumer

To Whom It May Concern:

The finished floor elevation on Lot 3 is determined to be 107.34 feet. The bottom of the I-Beam is determined to be 105.61 feet. The permit shows an MFE of 94 feet. The elevations are shown in NAVD 88 datum.

Sincerely,


L. Scott Britt
LS 5757

