



Duct Leakage Test Report



Residential Prescriptive, Performance or ERI Method Compliance
2023 Florida Building Code, Energy Conservation, 8th Edition

Jurisdiction: <u>Columbia County</u>		Permit #: <u>2513485 56045</u>	
Job Information			
Builder: <u>BRIAN HANKS</u>		Lot: _____	
Address: <u>423 S.W. PATHFINDER GLEN</u>		Unit: _____	
City: <u>FT White</u>		State: <u>FL</u>	Zip: <u>32038</u>
Duck Leakage Test Results		☐ Prescriptive Method ☐ Performance/ERI Method	
System 1	<u>39</u> cfm25	☒ Prescriptive Method cfm25 (Total) To qualify as "substantially leak free" Q_n must be less than or equal to 0.04 if air handler unit is installed. If air handler unit is not installed, Q_n Total must be less than or equal to 0.03. This testing method meets the requirements in accordance with Section R403.3.3. Is the air handler unit installed during testing? ☐ YES ($= .04Q_n$) ☐ NO ($= .03Q_n$) ☐ Performance Method cfm25 (Out or Total) To qualify as "substantially leak free" Q_n must not be greater than the proposed duct leakage Q_n specified on form R405-2023 OR R406-2023. ☐ Leakage Type selected on Form R405-2023 (Energy Calc) or R406-2023 ☐ Q_n specified on Form R405-2023 (Energy Calc) or R406-2023	
System 2	_____ cfm25		
System 3	_____ cfm25		
Sum of any additional systems	_____ cfm25		
Total of all systems	<u>39</u> cfm25		
<u>39</u> + <u>1561</u> = <u>.03</u> Q_n			
☒ PASS ☐ FAIL			
Duct tightness shall be verified by testing in accordance with ANSI/RESNET/ICC380 by either individuals as defined in Section 553.993(5) or (7), <i>Florida Statutes</i> , or individuals licensed as set forth in Section 489.105(3)(f), (g) or (i), <i>Florida Statutes</i> .			
Testing Company			
Company Name: <u>BLOWER Door Testing, LLC</u> Phone: <u>352-870-9475</u>			
I hereby verify that the above duct leakage testing results are in accordance with the Florida Building Code requirements with the selected compliance path as stated above, either the Prescriptive Method or Performance Method.			
Signature of Tester: <u>James W. George</u>		Date of Test: <u>9/26/26</u>	
Printed Name of Tester: <u>James W. George</u>			
License/Certification #: <u>5059955</u>		Issuing Authority: <u>BPI</u>	