

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Information

	Htg	Clg	Infiltration	Simplified Average
Outside db (°F)	33	92	Method	
Inside db (°F)	65	78	Construction quality	
Design TD (°F)	32	14	Fireplaces	0
Daily range	-	M		
Inside humidity (%)	30	50		
Moisture difference (gr/lb)	5	40		

HEATING EQUIPMENT

Make	n/a
Trade	n/a
Model	n/a
AHRI ref	n/a
Efficiency	n/a
Heating input	0 Btuh
Heating output	0 Btuh
Temperature rise	0 °F
Actual air flow	1550 cfm
Air flow factor	0.033 cfm/Btuh
Static pressure	0.50 in H2O
Space thermostat	

COOLING EQUIPMENT

Make	Trane
Trade	TRANE
Cond	5TTR4048A1
Coil	5TEM4D06AC41++TDR
AHRI ref	215440473
Efficiency	11.7 EER2, 14.3 SEER2
Sensible cooling	32550 Btuh
Latent cooling	13950 Btuh
Total cooling	46500 Btuh
Actual air flow	1550 cfm
Air flow factor	0.043 cfm/Btuh
Static pressure	0.50 in H2O
Load sensible heat ratio	0.84

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Room2	200	0	0	0	0
Room3	200	0	0	0	0
Room4	200	3272	2863	108	123
Room5	200	1793	1565	59	67
Room6	200	1793	1565	59	67
Room7	200	1793	1565	59	67
Room8	200	2073	1916	69	83
Room9	200	4134	2299	137	99
Room10	200	1793	1565	59	67
Room11	200	1793	1565	59	67
Room12	200	1793	1565	59	67
Room13	200	2073	1916	69	83
Room14	150	3471	1883	115	81
Room15	150	1716	1333	57	57

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Room16	150	1716	1333	57	57
Room17	150	1716	1333	57	57
Room18	150	1716	1333	57	57
Room19	150	1716	1333	57	57
Room20	150	1925	1596	64	69
Room21	150	3471	1883	115	81
Room22	150	1716	1333	57	57
Room23	150	1716	1333	57	57
Room24	150	1716	1333	57	57
Room25	150	1925	1596	64	69
Room26	800	0	0	0	0
Entire House	5000	46827	36005	1550	1550
Other equip loads		0	0		
Equip. @ 0.97 RSM			34924		
Latent cooling			7065		
TOTALS	5000	46827	41989	1550	1550

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Project Information


For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location: Gainesville Regional AP, FL, US Elevation: 164 ft Latitude: 30°N		Indoor: Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)		Heating 65 32 30 5.0	Cooling 78 14 50 40.4
Outdoor: Drybulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	Heating 33 - - 15.0	Cooling 92 18 (M) 76 7.5	Infiltration: Method Construction quality Fireplaces	Simplified Average 0	


Heating

Component	Btuh/ft²	Btuh	% of load
Walls	3.1	9160	19.6
Glazing	0	0	0
Doors	11.1	465	1.0
Ceilings	1.1	5372	11.5
Floors	2.1	10313	22.0
Infiltration	2.4	7256	15.5
Ducts		14261	30.5
Piping		0	0
Humidification		0	0
Ventilation		0	0
Adjustments		0	0
Total		46827	100.0



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	1.5	4392	12.2
Glazing	0	0	0
Doors	9.2	387	1.1
Ceilings	2.4	11875	33.0
Floors	0	0	0
Infiltration	0.6	1722	4.8
Ducts		17629	49.0
Ventilation		0	0
Internal gains		0	0
Blower		0	0
Adjustments		0	0
Total		36005	100.0



Latent Cooling Load = 7065 Btuh
 Overall U-value = 0.062 Btuh/ft²·°F, Window / Floor Area = 0.0 %

WARNING: window to floor area ratio = 0.0% - less than 5%.



Component Constructions
Entire House
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:			Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US			Indoor temperature (°F)	65	78
Elevation: 164 ft			Design TD (°F)	32	14
Latitude: 30°N			Relative humidity (%)	30	50
Outdoor:	Heating	Cooling	Moisture difference (gr/lb)	5.0	40.4
Drybulb (°F)	33	92	Infiltration:		
Daily range (°F)	-	18 (M)	Method	Simplified	
Wet bulb (°F)	-	76	Construction quality	Average	
Wind speed (mph)	15.0	7.5	Fireplaces	0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²·°F	Insul R ft²·°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12F-0sm. Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh,	n	360	0.099	21.0	3.13	1126	1.50	540
2"x6" metal frm, 24" o.c. stud	e	1104	0.099	21.0	3.13	3454	1.50	1656
	s	339	0.099	21.0	3.13	1061	1.50	508
	w	1125	0.099	21.0	3.13	3519	1.50	1687
	all	2928	0.099	21.0	3.13	9160	1.50	4392
Partitions								
(none)								
Windows								
(none)								
Doors								
11N0 Door, mtl eps core type	e	21	0.350	8.7	11.1	232	9.22	194
	s	21	0.350	8.7	11.1	232	9.22	194
	all	42	0.350	8.7	11.1	465	9.22	387
Ceilings								
16A-28md Attic ceiling, mtl roof mat, r-28 cell ins		5000	0.034	28.0	1.07	5372	2.37	11875
Floors								
22A-tp1 Bg floor, light dry soil, on grade depth		330	0.989	0	31.3	10313	0	0



Component Constructions
Room2
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
Outdoor:	Heating	Cooling	Moisture difference (gr/lb)	5.0
Drybulb (°F)	33	92		40.4
Dailyrange (°F)	-	18 (M)	Infiltration:	
Wet bulb (°F)	-	76	Method	Simplified
Wind speed (mph)	15.0	7.5	Construction quality	Average
			Fireplaces	0

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12F-0sm Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh,	e	90	0.099	21.0	3.13	282	1.50	135
2"x6" metal frm, 24" o.c. stud	s	180	0.099	21.0	3.13	563	1.50	270
	all	270	0.099	21.0	3.13	845	1.50	405
Partitions								
(none)								
Windows								
(none)								
Doors								
(none)								
Ceilings								
16A-28md Attic ceiling, mtl roof mat, r-28 ceil ins		200	0.034	28.0	1.07	215	2.37	475
Floors								
22A-tp1 Bg floor, light dry soil, on grade depth		30	0.989	0	31.3	938	0	0





PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:			Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US			Indoor temperature (°F)	65	78
Elevation: 164 ft			Design TD (°F)	32	14
Latitude: 30°N			Relative humidity (%)	30	50
Outdoor:	Heating	Cooling	Moisture difference (gr/lb)	5.0	40.4
Drybulb (°F)	33	92	Infiltration:		
Daily range (°F)	-	18 (M)	Method	Simplified	
Wet bulb (°F)	-	76	Construction quality	Average	
Wind speed (mph)	15.0	7.5	Fireplaces	0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²·°F	Insul R ft²·°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12F-0sm. Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o c. stud	e	90	0.099	21.0	3.13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings								
16A-28md: Attic ceiling, mtl roof mat, r-28 ceil ins		200	0.034	28.0	1.07	215	2.37	475
Floors								
22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0





Component Constructions
Room4
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:			Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US			Indoor temperature (°F)	65	78
Elevation: 164 ft			Design TD (°F)	32	14
Latitude: 30°N			Relative humidity (%)	30	50
Outdoor:	Heating	Cooling	Moisture difference (gr/lb)	5.0	40.4
Drybulb (°F)	33	92	Infiltration:		
Daily range (°F)	-	18 (M)	Method	Simplified	
Wet bulb (°F)	-	76	Construction quality	Average	
Wind speed (mph)	15.0	7.5	Fireplaces	0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls 12F-0sm. Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	e	90	0.099	21.0	3.13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md: Attic ceiling, mtl roof mat, r-28 cell ins		200	0.034	28.0	1.07	215	2.37	475
Floors 22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0





Component Constructions
Room5
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
		Moisture difference (gr/lb)	5.0	40.4
Outdoor:	Heating	Cooling		
Drybulb (°F)	33	92		
Daily range (°F)	-	18 (M)		
Wet bulb (°F)	-	76		
Wind speed (mph)	15.0	7.5		
		Infiltration:		
		Method	Simplified	
		Construction quality	Average	
		Fireplaces	0	

Construction descriptions

Construction descriptions	Or	Area ft ²	U-value Btuh/ft ² -°F	Insul R ft ² -°F/Btuh	Htg HTM Btuh/ft ²	Loss Btuh	Cig HTM Btuh/ft ²	Gain Btuh
Walls 12F-0sm Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o c. stud	e	90	0.099	21.0	3.13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md Attic ceiling, mtl roof mat, r-28 ceil ins		200	0.034	28.0	1.07	215	2.37	475
Floors 22A-1pl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0



Component Constructions
Room6
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
		Moisture difference (gr/lb)	5.0	40.4
Outdoor:	Heating	Cooling		
Drybulb (°F)	33	92		
Daily range (°F)	-	18 (M)		
Wet bulb (°F)	-	76		
Wind speed (mph)	15.0	7.5		
		Infiltration:		
		Method	Simplified	
		Construction quality	Average	
		Fireplaces	0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12F-0sm: Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	e	90	0.099	21.0	3.13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings								
16A-28md: Attic ceiling, mtl roof mat, r-28 ceil ins		200	0.034	28.0	1.07	215	2.37	475
Floors								
22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0





Component Constructions
Room7
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
Outdoor:	Heating	Cooling	Moisture difference (gr/lb)	5.0
Drybulb (°F)	33	92		40.4
Dailyrange (°F)	-	18 (M)	Infiltration:	
Wet bulb (°F)	-	76	Method	Simplified
Wind speed (mph)	15.0	7.5	Construction quality	Average
			Fireplaces	0

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-F	Insul R ft²-F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12F-0sm: Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	e	90	0.099	21.0	3.13	282	1.50	135
Partitions								
(none)								
Windows								
(none)								
Doors								
(none)								
Ceilings								
16A-28md: Attic ceiling, mtl roof mat, r-28 ceil ins		200	0.034	28.0	1.07	215	2.37	475
Floors								
22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0



Component Constructions
Room8
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
Outdoor:	Heating	Cooling		
Drybulb (°F)	33	92		
Daily range (°F)	-	18 (M)		
Wet bulb (°F)	-	76		
Wind speed (mph)	15.0	7.5		
		Infiltration:		
		Method	Simplified	
		Construction quality	Average	
		Fireplaces	0	

Construction descriptions

Construction descriptions	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Cig HTM Btuh/ft²	Gain Btuh
Walls 12F-0sm: Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	e	90	0.099	21.0	3.13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md: Attic ceiling, mtl roof mat, r-28 ceil ins		200	0.034	28.0	1.07	215	2.37	475
Floors 22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0



Component Constructions
Room9
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
		Moisture difference (gr/lb)	5.0	40.4
Outdoor:	Heating	Cooling		
Drybulb (°F)	33	92		
Daily range (°F)	-	18 (M)		
Wet bulb (°F)	-	76		
Wind speed (mph)	15.0	7.5		
		Infiltration:		
		Method	Simplified	
		Construction quality	Average	
		Fireplaces	0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12F-0sm Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh,	n	180	0.099	21.0	3.13	563	1.50	270
2"x6" metal frm, 24" o c. stud	e	90	0.099	21.0	3.13	282	1.50	135
	all	270	0.099	21.0	3.13	845	1.50	405
Partitions								
(none)								
Windows								
(none)								
Doors								
(none)								
Ceilings								
16A-28md Attic ceiling, mtl roof mat, r-28 cell ins		200	0.034	28.0	1.07	215	2.37	475
Floors								
22A-1pl Bg floor, light dry soil, on grade depth		30	0.989	0	31.3	938	0	0





Component Constructions
Room10
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location: Gainesville Regional AP, FL, US Elevation: 164 ft Latitude: 30°N	Indoor: Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	Heating 65 32 30 5.0	Cooling 78 14 50 40.4
Outdoor: Drybulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	Heating 33 - - 15.0	Cooling 92 18 (M) 76 7.5	Infiltration: Method Construction quality Fireplaces
		Simplified Average 0	

Construction descriptions	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls 12F-0sm. Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	e	90	0.099	21.0	3.13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md: Attic ceiling, mtl roof mat, r-28 cell ins		200	0.034	28.0	1.07	215	2.37	475
Floors 22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0



Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:			Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US			Indoor temperature (°F)	65	78
Elevation: 164 ft			Design TD (°F)	32	14
Latitude: 30°N			Relative humidity (%)	30	50
Outdoor:	Heating	Cooling	Moisture difference (gr/lb)	5.0	40.4
Drybulb (°F)	33	92	Infiltration:		
Daily range (°F)	-	18 (M)	Method	Simplified	
Wet bulb (°F)	-	76	Construction quality	Average	
Wind speed (mph)	15.0	7.5	Fireplaces	0	

Construction descriptions

	Or	Area ft²	U-value Btu/h/ft²-°F	Insul R ft²-°F/Btu/h	Htg HTM Btu/h/ft²	Loss Btu/h	Clg HTM Btu/h/ft²	Gain Btu/h
Walls								
12F-0sm: Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	e	90	0.099	21.0	3.13	282	1 50	135
Partitions								
(none)								
Windows								
(none)								
Doors								
(none)								
Ceilings								
16A-28md: Attic ceiling, mtl roof mat, r-28 cell ins		200	0.034	28.0	1.07	215	2 37	475
Floors								
22A-tp1 Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0



Component Constructions
Room12
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location: Gainesville Regional AP, FL, US Elevation: 164 ft Latitude: 30°N	Indoor: Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	Heating 65 32 30 5.0	Cooling 78 14 50 40.4
Outdoor: Drybulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	Heating 33 - - 15.0	Cooling 92 18 (M) 76 7.5	Infiltration: Method Construction quality Fireplaces
		Simplified Average 0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls 12F-0sm Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	e	90	0.099	21.0	3 13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md: Attic ceiling, mtl roof mat, r-28 ceil ins		200	0.034	28.0	1.07	215	2 37	475
Floors 22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31 3	313	0	0



Component Constructions
Room13
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
		Moisture difference (gr/lb)	5.0	40.4
Outdoor:	Heating	Cooling		
Drybulb (°F)	33	92		
Dailyrange (°F)	-	18 (M)		
Wet bulb (°F)	-	76		
Wind speed (mph)	15.0	7.5		
		Infiltration:		
		Method	Simplified	
		Construction quality	Average	
		Fireplaces	0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12F-0sm: Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	e	90	0.099	21.0	3.13	282	1 50	135
Partitions								
(none)								
Windows								
(none)								
Doors								
(none)								
Ceilings								
16A-28md: Attic ceiling, mtl roof mat, r-28 ceil ins		200	0.034	28.0	1 07	215	2.37	475
Floors								
22A-tp1 Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0





Component Constructions
Room14
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:			Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US			Indoor temperature (°F)	65	78
Elevation: 164 ft			Design TD (°F)	32	14
Latitude: 30°N			Relative humidity (%)	30	50
Outdoor:	Heating	Cooling	Moisture difference (gr/lb)	5.0	40.4
Dry bulb (°F)	33	92	Infiltration:		
Daily range (°F)	-	18 (M)	Method	Simplified	
Wet bulb (°F)	-	76	Construction quality	Average	
Wind speed (mph)	15.0	7.5	Fireplaces	0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12F-0sm: Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh,	s	135	0.099	21.0	3.13	422	1.50	202
2"x6" metal frm, 24" o.c. stud	w	90	0.099	21.0	3.13	282	1.50	135
	all	225	0.099	21.0	3.13	704	1.50	337
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings								
16A-28md. Attic ceiling, mtl roof mat, r-28 cell ins		150	0.034	28.0	1.07	161	2.37	356
Floors								
22A-tp1: Bg floor, light dry soil, on grade depth		25	0.989	0	31.3	781	0	0





Component Constructions
Room15
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
		Moisture difference (gr/lb)	5.0	40.4
Outdoor:	Heating	Cooling		
Drybulb (°F)	33	92		
Dailyrange (°F)	-	18 (M)		
Wet bulb (°F)	-	76		
Wind speed (mph)	15.0	7.5		
		Infiltration:		
		Method	Simplified	
		Construction quality	Average	
		Fireplaces	0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12F-0sm: Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	w	90	0.099	21.0	3.13	282	1.50	135
Partitions								
(none)								
Windows								
(none)								
Doors								
(none)								
Ceilings								
16A-28md: Attic ceiling, mtl roof mat, r-28 ceil ins		150	0.034	28.0	1.07	161	2.37	356
Floors								
22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0



Component Constructions
Room16
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:			Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US			Indoor temperature (°F)	65	78
Elevation: 164 ft			Design TD (°F)	32	14
Latitude: 30°N			Relative humidity (%)	30	50
Outdoor:	Heating	Cooling	Moisture difference (gr/lb)	5.0	40.4
Drybulb (°F)	33	92	Infiltration:		
Daily range (°F)	-	18 (M)	Method	Simplified	
Wet bulb (°F)	-	76	Construction quality	Average	
Wind speed (mph)	15.0	7.5	Fireplaces	0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls 12F-0sm: Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	w	90	0.099	21.0	3.13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md: Attic ceiling, mtl roof mat, r-28 cell ins		150	0.034	28.0	1.07	161	2.37	356
Floors 22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0





Component Constructions

Room17

D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location: Gainesville Regional AP, FL, US Elevation: 164 ft Latitude: 30°N		Indoor: Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	Heating 65 32 30 5.0	Cooling 78 14 50 40.4
Outdoor: Drybulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	Heating 33 - - 15.0	Cooling 92 18 (M) 76 7.5	Infiltration: Method Construction quality Fireplaces	Simplified Average 0

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Cig HTM Btuh/ft²	Gain Btuh
Walls 12F-0sm Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	w	90	0.099	21.0	3.13	282	1 50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md: Attic ceiling, mtl roof mat, r-28 ceil ins		150	0.034	28.0	1.07	161	2.37	356
Floors 22A-tp1 Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0





Component Constructions
Room18
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
		Moisture difference (gr/lb)	5.0	40.4
Outdoor:	Heating	Cooling		
Drybulb (°F)	33	92		
Daily range (°F)	-	18 (M)		
Wet bulb (°F)	-	76		
Wind speed (mph)	15.0	7.5		
		Infiltration:		
		Method	Simplified	
		Construction quality	Average	
		Fireplaces	0	

Construction descriptions	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls 12F-0sm. Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	w	90	0.099	21.0	3.13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md. Attic ceiling, mtl roof mat, r-28 ceil ins		150	0.034	28.0	1.07	161	2.37	356
Floors 22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0





Component Constructions
Room19
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location: Gainesville Regional AP, FL, US Elevation: 164 ft Latitude: 30°N		Indoor: Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	Heating 65 32 30 5.0	Cooling 78 14 50 40.4
Outdoor: Drybulb (°F) Dailyrange (°F) Wet bulb (°F) Wind speed (mph)	Heating 33 - - 15.0	Cooling 92 18 (M) 76 7.5	Infiltration: Method Construction quality Fireplaces	Simplified Average 0

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Cig HTM Btuh/ft²	Gain Btuh
Walls 12F-0sm Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	w	90	0.099	21.0	3.13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md: Attic ceiling, mtl roof mat, r-28 ceil ins		150	0.034	28.0	1.07	161	2.37	356
Floors 22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0



Component Constructions
Room20
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
Outdoor:	Heating	Cooling	Moisture difference (gr/lb)	
Drybulb (°F)	33	92	5.0	40.4
Daily range (°F)	-	18 (M)		
Wet bulb (°F)	-	76		
Wind speed (mph)	15.0	7.5		
		Infiltration:		
		Method	Simplified	
		Construction quality	Average	
		Fireplaces	0	

Construction descriptions	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12F-0sm: Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	w	90	0.099	21.0	3 13	282	1.50	135
Partitions								
(none)								
Windows								
(none)								
Doors								
(none)								
Ceilings								
16A-28md: Attic ceiling, mtl roof mat, r-28 cell ins		150	0.034	28.0	1.07	161	2.37	356
Floors								
22A-tpl. Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0



Component Constructions
Room21
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone. 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location: Gainesville Regional AP, FL, US Elevation: 164 ft Latitude: 30°N	Indoor: Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	Heating 65 32 30 5.0	Cooling 78 14 50 40.4
Outdoor: Drybulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	Heating 33 - - 15.0	Cooling 92 18 (M) 76 7.5	Infiltration: Method Construction quality Fireplaces
		Simplified Average 0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²·°F	Insul R ft²·°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Cig HTM Btuh/ft²	Gain Btuh
Walls 12F-0sm. Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	n w all	135 90 225	0.099 0.099 0.099	21.0 21.0 21.0	3.13 3.13 3.13	422 282 704	1.50 1.50 1.50	202 135 337
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md: Attic ceiling, mtl roof mat, r-28 cell ins		150	0.034	28.0	1.07	161	2.37	356
Floors 22A-1pl: Bg floor, light dry soil, on grade depth		25	0.989	0	31.3	781	0	0





Component Constructions
Room22
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, Fl 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, Fl 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
		Moisture difference (gr/lb)	5.0	40.4
Outdoor:	Heating	Cooling		
Drybulb (°F)	33	92		
Dailyrange (°F)	-	18 (M)		
Wet bulb (°F)	-	76		
Wind speed (mph)	15.0	7.5		
		Infiltration:		
		Method	Simplified	
		Construction quality	Average	
		Fireplaces	0	

Construction descriptions

	Or	Area ft²	U-value Bluh/ft²-F	Insul R ft²-F/Bluh	Htg HTM Bluh/ft²	Loss Clg HTM Bluh	Clg HTM Bluh/ft²	Gain Bluh
Walls 12F-0sm: Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int frsh, 2"x6" metal frm, 24" o.c. stud	w	90	0.099	21.0	3.13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md. Attic ceiling, mtl roof mat, r-28 ceil ins		150	0.034	28.0	1.07	161	2.37	356
Floors 22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0





Component Constructions
Room23
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation: 164 ft		Design TD (°F)	32	14
Latitude: 30°N		Relative humidity (%)	30	50
Outdoor:	Heating	Cooling	Moisture difference (gr/lb)	5.0
Drybulb (°F)	33	92		40.4
Daily range (°F)	-	18 (M)	Infiltration:	
Wet bulb (°F)	-	76	Method	Simplified
Wind speed (mph)	15.0	7.5	Construction quality	Average
			Fireplaces	0

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12F-0sm Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	w	90	0.099	21.0	3.13	282	1.50	135
Partitions								
(none)								
Windows								
(none)								
Doors								
(none)								
Ceilings								
16A-28md: Attic ceiling, mtl roof mat, r-28 cell ins		150	0.034	28.0	1.07	161	2.37	356
Floors								
22A-1pl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0



Component Constructions
Room24
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location: Gainesville Regional AP, FL, US Elevation: 164 ft Latitude: 30°N			Indoor: Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	Heating 65 32 30 5.0	Cooling 78 14 50 40.4
Outdoor: Drybulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	Heating 33 - - 15.0	Cooling 92 18 (M) 76 7.5	Infiltration: Method Construction quality Fireplaces		Simplified Average 0

Construction descriptions	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls 12F-0sm Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh, 2"x6" metal frm, 24" o.c. stud	w	90	0.099	21.0	3.13	282	1.50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md: Attic ceiling, mtl roof mat, r-28 ceil ins		150	0.034	28.0	1.07	161	2.37	356
Floors 22A-1pl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0



Component Constructions
Room25
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location: Gainesville Regional AP, FL, US Elevation: 164 ft Latitude: 30°N		Indoor: Indoor temperature (°F) 65 Design TD (°F) 32 Relative humidity (%) 30 Moisture difference (gr/lb) 5.0	Heating 65 32 30 5.0	Cooling 78 14 50 40.4
Outdoor: Drybulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	Heating 33 - - 15.0	Cooling 92 18 (M) 76 7.5	Infiltration: Method Simplified Construction quality Average Fireplaces 0	

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls 12F-0sm Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fsh, 2"x6" metal frm, 24" o.c. stud	w	90	0.099	21.0	3 13	282	1 50	135
Partitions (none)								
Windows (none)								
Doors (none)								
Ceilings 16A-28md: Attic ceiling, mtl roof mat, r-28 cell ins		150	0.034	28 0	1.07	161	2.37	356
Floors 22A-tpl Bg floor, light dry soil, on grade depth		10	0.989	0	31.3	313	0	0



Component Constructions
Room26
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:		Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)		65	78
Elevation:	164 ft	Design TD (°F)		32	14
Latitude:	30°N	Relative humidity (%)		30	50
Outdoor:	Heating	Cooling	Infiltration:		
Drybulb (°F)	33	92	Method		
Daily range (°F)	-	18 (M)	Construction quality		
Wet bulb (°F)	-	76	Fireplaces		
Wind speed (mph)	15.0	7.5	Simplified		
			Average		
			0		

Construction descriptions

Walls

12F-0sm Frm wall, mtl ext, r-30 cav ins, 1/2" gypsum board int fnsh,
 2"x6" metal frm, 24" o.c. stud

Or	Area ft²	U-value Btuh/ft²·°F	Insul R ft²·°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
n	45	0.099	21.0	3.13	141	1.50	67
e	24	0.099	21.0	3.13	75	1.50	36
s	24	0.099	21.0	3.13	75	1.50	36
w	45	0.099	21.0	3.13	141	1.50	67
all	138	0.099	21.0	3.13	432	1.50	207

Partitions

(none)

Windows

(none)

Doors

11N0 Door, mtl eps core type

e	21	0.350	8.7	11.1	232	9.22	194
s	21	0.350	8.7	11.1	232	9.22	194
all	42	0.350	8.7	11.1	465	9.22	387

Ceilings

16A-28md: Attic ceiling, mtl roof mat, r-28 ceil ins

	800	0.034	28.0	1.07	860	2.37	1900
--	-----	-------	------	------	-----	------	------

Floors

22A-tp1 Bg floor, light dry soil, on grade depth

	20	0.989	0	31.3	625	0	0
--	----	-------	---	------	-----	---	---





Project Summary
Entire House
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phono: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Notes:

Design Information

Weather: Gainesville Regional AP, FL, US

Winter Design Conditions

Outside db 33 °F
 Inside db 65 °F
 Design TD 32 °F

Ventilation Method MJ8

Heating Summary

Structure 32566 Btuh
 Ducts (R-6.0) 14261 Btuh
 Central vent (0 cfm) 0 Btuh
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 46827 Btuh

Infiltration

Method Simplified
 Construction quality Average
 Fireplaces 0

	Heating	Cooling
Area (ft ²)	5000	5000
Volume (ft ³)	45000	45000
Air changes/hour	0.28	0.15
Equiv. AVF (cfm)	210	113

Heating Equipment Summary

Make n/a
 Trade n/a
 Model n/a
 AHRI ref n/a
 Efficiency n/a
 Heating input 0 Btuh
 Heating output 0 Btuh
 Temperature rise 0 °F
 Actual air flow 1550 cfm
 Air flow factor 0.033 cfm/Btuh
 Static pressure 0.50 in H2O
 Space thermostat

Summer Design Conditions

Outside db 92 °F
 Inside db 78 °F
 Design TD 14 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 40 gr/lb

Sensible Cooling Equipment Load Sizing

Structure 18376 Btuh
 Ducts (R-6.0) 17629 Btuh
 Central vent (0 cfm) 0 Btuh
 Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 0.97
 Equipment sensible load 34924 Btuh

Latent Cooling Equipment Load Sizing

Structure 3074 Btuh
 Ducts 3991 Btuh
 Central vent (0 cfm) 0 Btuh
 Equipment latent load 7065 Btuh
Equipment Total Load (Sen+Lat) 41989 Btuh
 Req. total capacity at 0.70 SHR 4.2 ton

Cooling Equipment Summary

Make Trane
 Trade TRANE
 Cond 5TTR4048A1
 Coil 5TEM4D06AC41++TDR
 AHRI ref 215440473
 Efficiency 11.7 EER2, 14.3 SEER2
 Sensible cooling 32550 Btuh
 Latent cooling 13950 Btuh
 Total cooling 46500 Btuh
 Actual air flow 1550 cfm
 Air flow factor 0.043 cfm/Btuh
 Static pressure 0.50 in H2O
 Load sensible heat ratio 0.84

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

Project Information


For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:		Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)		65	78
Elevation:	164 ft	Design TD (°F)		32	14
Latitude:	30°N	Relative humidity (%)		30	50
Outdoor:		Heating	Cooling	Moisture difference (gr/lb)	
Drybulb (°F)		33	92	5.0	40.4
Daily range (°F)		-	18 (M)		
Wet bulb (°F)		-	76		
Wind speed (mph)		15.0	7.5		
			Infiltration:		

Test for Adequate Exposure Diversity

Hourly Glazing Load



Maximum hourly glazing load exceeds average by 0.0%.

House has adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 0 Btuh



Right-J® Worksheet
 Entire House
 D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1 Room name		Entire House		Room2										
2 Exposed wall		330.0 ft		30.0 ft										
3 Room height		9.0 ft		9.0 ft										
4 Room dimensions		5000.0 ft²		100 x 200 ft										
5 Room area				200.0 ft²										
6	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6 11	W	12F-0sm	0.099	n	3.13	1.50	360	360	1126	540	0	0	0	0
		12F-0sm	0.099	e	3.13	1.50	1125	1104	3454	1656	90	90	282	135
	W	11N0	0.350	s	11.06	9.22	21	21	232	194	0	0	0	0
		12F-0sm	0.099	s	3.13	1.50	360	339	1061	508	180	180	563	270
	W	11N0	0.350	s	11.06	9.22	21	21	232	194	0	0	0	0
		12F-0sm	0.099	w	3.13	1.50	1125	1125	3519	1687	0	0	0	0
	C	16A-28md	0.034	-	1.07	2.37	5000	5000	5372	11875	200	200	215	475
	F	22A-tpi	0.989	-	31.25	0.00	5000	330	10313	0	200	200	30	938
6	c) AED excursion								0				0	
	Envelope loss/gain								25310	16653			1997	880
12	a) Infiltration								7256	1722			660	157
	b) Room ventilation								0	0			0	0
13	Internal gains.		Occupants @	230			0			0	0			0
			Appliances/other							0				0
	Subtotal (lines 6 to 13)								32566	18376			2657	1037
14	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								0	0			-2657	-1037
	Subtotal								32566	18376			0	0
15	Duct loads						44%	96%	14261	17629	44%	96%	0	0
	Total room load								46827	36005			0	0
	Air required (cfm)								1550	1550			0	0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

1 Room name				Room3				Room4						
2 Exposed wall				9.0 ft		10.0 ft		9.0 ft		10.0 ft				
3 Room height				heat/cool		heat/cool		heat/cool		heat/cool				
4 Room dimensions				10.0 x 20.0 ft		10.0 x 20.0 ft		10.0 x 20.0 ft		10.0 x 20.0 ft				
5 Room area				200.0 ft²		200.0 ft²		200.0 ft²		200.0 ft²				
6	Ty	Construction number	U-value (Btuh/ft²-F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	12F-0sm	0.099	n	3.13	1.50	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	e	3.13	1.50	90	90	282	135	90	90	282	135
	W	11N0	0.350	e	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	0	0	0	0
	W	11N0	0.350	s	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	w	3.13	1.50	0	0	0	0	0	0	0	0
11	C	16A-28md	0.034	-	1.07	2.37	200	200	215	475	200	200	215	475
	F	22A-tp1	0.989	-	31.25	0.00	200	10	313	0	200	10	313	0
6	c) AED excursion									0				0
	Envelope loss/gain								809	610			809	610
12	a) Infiltration								220	52			220	52
	b) Room ventilation								0	0			0	0
13	Internal gains		Occupants @	230			0				0	0		0
			Appliances/other								0	0		0
	Subtotal (lines 6 to 13)								1029	662			1029	662
14	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								-1029	-662			1247	799
	Subtotal								0	0			2276	1461
15	Duct loads						44%	96%	0	0	44%	96%	997	1402
	Total room load								0	0			3272	2863
	Air required (cfm)								0	0			108	123

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

1 Room name		Room5		Room6										
2 Exposed wall		10.0 ft		10.0 ft										
3 Room height		9.0 ft		9.0 ft										
4 Room dimensions		10.0 x 20.0 ft		10.0 x 20.0 ft										
5 Room area		200.0 ft ²		200.0 ft ²										
Ty	Construction number	U-value (Btuh/ft ² -°F)	Or	HTM (Btuh/ft ²)		Area (ft ²) or perimeter (ft)		Load (Btuh)		Area (ft ²) or perimeter (ft)		Load (Btuh)		
				Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	12F-0sm	0.099	n	3.13	1.50	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	e	3.13	1.50	90	90	282	135	90	90	282	135
	D	11N0	0.350	e	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	0	0	0	0
11	D	11N0	0.350	s	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	w	3.13	1.50	0	0	0	0	0	0	0	0
	C	16A-28md	0.034	-	1.07	2.37	200	200	215	475	200	200	215	475
	F	22A-tpi	0.989	-	31.25	0.00	200	10	313	0	200	10	313	0
6	c) AED excursion								0				0	
	Envelope loss/gain								809	610			809	610
12	a) Infiltration								220	52			220	52
	b) Room ventilation								0	0			0	0
13	Internal gains		Occupants @	230			0		0	0	0		0	0
			Appliances/other						0	0			0	0
	Subtotal (lines 6 to 13)								1029	662			1029	662
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								218	137			218	137
14	Subtotal								1247	799			1247	799
15	Duct loads						44%	96%	546	766	44%	96%	546	766
	Total room load								1793	1565			1793	1565
	Air required (cfm)								59	67			59	67

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1		Room name		Room7		Room8								
2		Exposed wall		100 ft		100 ft								
3		Room height		90 ft		90 ft								
4		Room dimensions		100 x 200 ft		100 x 200 ft								
5		Room area		200.0 ft²		200.0 ft²								
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	12F-0sm	0.099	n	3.13	1.50	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	e	3.13	1.50	90	90	282	135	90	90	282	135
	W	11N0	0.350	e	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	0	0	0	0
11	W	11N0	0.350	s	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	w	3.13	1.50	0	0	0	0	0	0	0	0
	C	16A-28md	0.034	-	1.07	2.37	200	200	215	475	200	200	215	475
	F	22A-1pl	0.989	-	31.25	0.00	200	10	313	0	200	10	313	0
6	c) AED excursion									0				0
	Envelope loss/gain								809	610			809	610
12	a) Infiltration								220	52			220	52
	b) Room ventilation								0	0			0	0
13	Internal gains		Occupants @	230			0			0	0			0
			Appliances/other							0				0
	Subtotal (lines 6 to 13)								1029	662			1029	662
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								218	137			413	316
14	Subtotal								1247	799			1441	978
15	Duct loads						44%	96%	546	766	44%	96%	631	938
	Total room load								1793	1565			2073	1916
	Air required (cfm)								69	67			69	83

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-J® Worksheet
Entire House
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1		Room name		Room9		Room10								
2		Exposed wall		30.0 ft		10.0 ft								
3		Room height		9.0 ft		9.0 ft								
4		Room dimensions		10.0 x 20.0 ft		10.0 x 20.0 ft								
5		Room area		200.0 ft²		200.0 ft²								
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	12F-0sm	0.099	n	3.13	1.50	180	180	583	270	0	0	0	0
	W	12F-0sm	0.099	e	3.13	1.50	90	90	282	135	90	90	282	135
	W	11N0	0.350	e	11.06	9.22	0	0	0	0	0	0	0	0
11	W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	0	0	0	0
	W	11N0	0.350	s	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	w	3.13	1.50	0	0	0	0	0	0	0	0
	C	16A-28md	0.034	-	1.07	2.37	200	200	215	475	200	200	215	475
	F	22A-1pl	0.989	-	31.25	0.00	200	30	938	0	200	10	313	0
6	c) AED excursion									0				0
	Envelope loss/gain								1997	880			809	610
12	a) Infiltration								660	157			220	52
	b) Room ventilation								0	0			0	0
13	Internal gains.		Occupants @	230			0			0	0			0
			Appliances/other							0				0
	Subtotal (lines 6 to 13)								2657	1037			1029	662
14	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								218	137			218	137
	Subtotal								2875	1173			1247	799
15	Duct loads						44%	96%	1259	1126	44%	96%	546	766
	Total room load								4134	2299			1793	1565
	Air required (cfm)								137	99			59	67

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

		Room11		Room12										
		10.0 ft		10.0 ft										
		heat/cool		heat/cool										
		10.0 x 20.0 ft		10.0 x 20.0 ft										
		200.0 ft²		200.0 ft²										
1	Room name													
	Exposed wall													
2	Room height													
3	Room dimensions													
4	Room area													
5														
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	12F-0sm	0.099	n	3.13	1.50	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	e	3.13	1.50	90	90	282	135	90	90	282	135
	W	11N0	0.350	e	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	0	0	0	0
	W	11N0	0.350	s	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	w	3.13	1.50	0	0	0	0	0	0	0	0
	C	16A-28md	0.034	-	1.07	2.37	200	200	215	475	200	200	215	475
	F	22A-tpi	0.989	-	31.25	0.00	200	10	313	0	200	10	313	0
6	c) AED excursion									0				0
	Envelope loss/gain								809	610			809	610
12	a) Infiltration								220	52			220	52
	b) Room ventilation								0	0			0	0
13	Internal gains				Occupants @	230		0			0	0		0
					Appliances/other						0	0		0
	Subtotal (lines 6 to 13)								1029	662			1029	662
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								218	137			218	137
14	Subtotal								1247	799			1247	799
15	Duct loads						44%	96%	546	766	44%	96%	546	766
	Total room load								1793	1565			1793	1565
	Air required (cfm)								59	67			59	67

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1 Room name				Room13		Room14								
2 Exposed wall				10.0 ft		25.0 ft								
3 Room height				9.0 ft		9.0 ft								
4 Room dimensions				10.0 x 20.0 ft		10.0 x 15.0 ft								
5 Room area				200.0 ft ²		150.0 ft ²								
6	Ty	Construction number	U-value (Btuh/ft ² ·°F)	Or	HTM (Btuh/ft ²)		Area (ft ²) or perimeter (ft)		Load (Btuh)		Area (ft ²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	12F-0sm	0.099	n	3.13	1.50	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	e	3.13	1.50	90	90	282	135	0	0	0	0
	W	11N0	0.350	e	11.06	9.22	0	0	0	0	0	0	0	0
11	W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	135	135	422	202
	W	11N0	0.350	s	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	w	3.13	1.50	0	0	0	0	90	90	282	135
	C	16A-28md	0.034	-	1.07	2.37	200	200	215	475	150	150	161	356
	F	22A-1pl	0.989	-	31.25	0.00	200	10	313	0	150	25	781	0
6	c) AED excursion									0				0
	Envelope loss/gain								809	610			1646	694
12	a) Infiltration								220	52			550	130
	b) Room ventilation								0	0			0	0
13	Internal gains.		Occupants @	230			0			0	0			0
			Appliances/other							0				0
	Subtotal (lines 6 to 13)								1029	662			2196	824
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								413	316			218	137
14	Subtotal								1441	978			2414	961
15	Duct loads						44%	96%	631	938	44%	96%	1057	922
	Total room load								2073	1916			3471	1883
	Air required (cfm)								69	83			115	81

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1	Room name				Room15				Room16					
	Exposed wall				10.0 ft				10.0 ft					
	Room height				9.0 ft				9.0 ft					
3	Room dimensions				10.0 x 15.0 ft				10.0 x 15.0 ft					
4	Room area				150.0 ft ²				150.0 ft ²					
6	Ty	Construction number	U-value (Btuh/ft ² ·°F)	Or	HTM (Btuh/ft ²)		Area (ft ²) or perimeter (ft)		Load (Btuh)		Area (ft ²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	12F-0sm	0.099	n	3.13	1.50	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	e	3.13	1.50	0	0	0	0	0	0	0	0
	W	11N0	0.350	e	11.06	9.22	0	0	0	0	0	0	0	0
11	W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	0	0	0	0
	W	11N0	0.350	s	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	w	3.13	1.50	90	90	282	135	90	90	282	135
	C	16A-28md	0.034	-	1.07	2.37	150	150	161	356	150	150	161	356
	F	22A-tp1	0.989	-	31.25	0.00	150	10	313	0	150	10	313	0
6	c) AED excursion									0				0
	Envelope loss/gain								755	491			755	491
12	a) Infiltration								220	52			220	52
	b) Room ventilation								0	0			0	0
13	Internal gains:		Occupants @		230		0		0		0		0	
			Appliances/other						0		0		0	
	Subtotal (lines 6 to 13)								975	543			975	543
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								218	137			218	137
14	Subtotal								1193	680			1193	680
15	Duct loads						44%	96%	522	652	44%	96%	522	652
	Total room load								1716	1333			1716	1333
	Air required (cfm)								57	57			57	57

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

		Room17								Room18							
		9.0 ft				10.0 ft				9.0 ft				10.0 ft			
		heat/cool				heat/cool				heat/cool				heat/cool			
		10.0 x 15.0 ft				10.0 x 15.0 ft				10.0 x 15.0 ft				10.0 x 15.0 ft			
		150.0 ft²				150.0 ft²				150.0 ft²				150.0 ft²			
1	Room name	Exposed wall	Room height	Room dimensions	Room area	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)			
						Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool		
6	W	12F-0sm	0.099	n	3.13	1.50	0	0	0	0	0	0	0	0	0		
	W	12F-0sm	0.099	e	3.13	1.50	0	0	0	0	0	0	0	0	0		
	W	11N0	0.350	e	11.06	9.22	0	0	0	0	0	0	0	0	0		
11	W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	0	0	0	0	0		
	W	11N0	0.350	s	11.06	9.22	0	0	0	0	0	0	0	0	0		
	W	12F-0sm	0.099	w	3.13	1.50	90	90	282	135	90	90	282	135	0		
	C	16A-28md	0.034	-	1.07	2.37	150	150	161	356	150	150	161	356	0		
	F	22A-lpl	0.989	-	31.25	0.00	150	10	313	0	150	10	313	0	0		
6	c) AED excursion									0					0		
	Envelope loss/gain									755	491			755	491		
12	a) Infiltration									220	52			220	52		
	b) Room ventilation									0	0			0	0		
13	Internal gains		Occupants @	230			0			0	0			0	0		
			Appliances/other							0	0			0	0		
	Subtotal (lines 6 to 13)									975	543			975	543		
	Less external load									0	0			0	0		
	Less transfer									0	0			0	0		
	Redistribution									218	137			218	137		
14	Subtotal									1193	680			1193	680		
15	Duct loads						44%	96%		522	652		44%	96%	522	652	
	Total room load									1716	1333			1716	1333		
	Air required (cfm)									57	57			57	57		

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1		Room name		Room19				Room20						
2		Exposed wall		10.0 ft				10.0 ft						
3		Room height		9.0 ft				9.0 ft						
4		Room dimensions		10.0 x 15.0 ft				10.0 x 15.0 ft						
5		Room area		150.0 ft²				150.0 ft²						
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	12F-0sm	0.099	n	3.13	1.50	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	e	3.13	1.50	0	0	0	0	0	0	0	0
	W	11N0	0.350	e	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	0	0	0	0
11	W	11N0	0.350	s	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	w	3.13	1.50	90	90	282	135	90	90	282	135
	C	16A-28md	0.034	-	1.07	2.37	150	150	161	358	150	150	161	358
	F	22A-1pl	0.989	-	31.25	0.00	150	10	313	0	150	10	313	0
6	c) AED excursion									0				0
	Envelope loss/gain									755	491			755 491
12	a) Infiltration									220	52			220 52
	b) Room ventilation									0	0			0 0
13	Internal gains		Occupants @	230			0			0	0			0 0
			Appliances/other							0	0			0 0
	Subtotal (lines 6 to 13)									975	543			975 543
	Less external load									0	0			0 0
	Less transfer									0	0			0 0
	Redistribution									218	137			364 271
14	Subtotal									1193	680			1339 815
15	Duct loads						44%	96%		522	652	44%	96%	586 781
	Total room load									1716	1333			1925 1596
	Air required (cfm)									57	57			64 69

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

1 Room name				Room21				Room22					
2 Exposed wall				9.0 ft		25.0 ft		9.0 ft		10.0 ft			
3 Room height				10.0		x 15.0		10.0		x 15.0			
4 Room dimensions				150.0		ft²		150.0		ft²			
5 Room area													
6 Ty	Construction number	U-value (Btuh/ft²-°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
				Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6 W	12F-0sm	0.099	n	3.13	1.50	135	135	422	202	0	0	0	0
W	12F-0sm	0.099	e	3.13	1.50	0	0	0	0	0	0	0	0
W-D	11N0	0.350	e	11.06	9.22	0	0	0	0	0	0	0	0
W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	0	0	0	0
W-D	11N0	0.350	s	11.06	9.22	0	0	0	0	0	0	0	0
W	12F-0sm	0.099	w	3.13	1.50	90	90	282	135	90	90	282	135
C	16A-28md	0.034	-	1.07	2.37	150	150	161	356	150	150	161	356
F	22A-tpi	0.989	-	31.25	0.00	150	25	781	0	150	10	313	0
6	c) AED excursion								0				0
	Envelope loss/gain							1646	694			755	491
12	a) Infiltration							550	130			220	52
	b) Room ventilation							0	0			0	0
13	Internal gains	Occupants @	230			0			0	0			0
		Appliances/other							0				0
	Subtotal (lines 6 to 13)							2196	824			975	543
	Less external load							0	0			0	0
	Less transfer							0	0			0	0
	Redistribution							218	137			218	137
14	Subtotal							2414	961			1193	680
15	Duct loads					44%	96%	1057	922	44%	96%	522	652
	Total room load							3471	1883			1716	1333
	Air required (cfm)							115	81			57	57

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-J® Worksheet
 Entire House
 D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

				Room23				Room24							
				9.0 ft		10.0 ft		9.0 ft		10.0 ft					
				heat/cool		heat/cool		heat/cool		heat/cool					
				10.0 x 15.0 ft		10.0 x 15.0 ft		10.0 x 15.0 ft		10.0 x 15.0 ft					
				150.0 ft²		150.0 ft²		150.0 ft²		150.0 ft²					
6	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	12F-0sm	0.099	n	3.13	1.50	0	0	0	0	0	0	0	0	
	W	12F-0sm	0.099	e	3.13	1.50	0	0	0	0	0	0	0	0	
	W	11N0	0.350	e	11.06	9.22	0	0	0	0	0	0	0	0	
	11	W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	0	0	0	0
		W	11N0	0.350	s	11.06	9.22	0	0	0	0	0	0	0	0
	W	12F-0sm	0.099	w	3.13	1.50	90	90	282	135	90	90	282	135	
	C	16A-28md	0.034	-	1.07	2.37	150	150	161	356	150	150	161	356	
	F	22A-tp1	0.989	-	31.25	0.00	150	10	313	0	150	10	313	0	
	6	c) AED excursion								0				0	
		Envelope loss/gain								755	491			755	491
	12	a) Infiltration								220	52			220	52
	b) Room ventilation								0	0			0	0	
13	Internal gains		Occupants @	230		0			0	0		0	0		
			Appliances/other						0	0			0		
	Subtotal (lines 6 to 13)								975	543			975	543	
14	Less external load								0	0			0	0	
	Less transfer								0	0			0	0	
	Redistribution								218	137			218	137	
	Subtotal								1193	680			1193	680	
15	Duct loads						44%	96%	522	652	44%	96%	522	652	
	Total room load								1716	1333			1716	1333	
	Air required (cfm)								57	57			57	57	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

1		Room name		Room25		Room26									
2		Exposed wall		10 0 ft		20 0 ft									
3		Room height		9 0 ft		9 0 ft									
4		Room dimensions		10 0 x 15 0 ft		1 0 x 8 0 0 ft									
5		Room area		150.0 ft²		800.0 ft²									
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	12F-0sm	0.099	n	3.13	1.50	0	0	0	0	45	45	141	67	
	W	12F-0sm	0.099	e	3.13	1.50	0	0	0	0	45	24	75	36	
	W	11N0	0.350	e	11.06	9.22	0	0	0	0	21	21	232	194	
	W	12F-0sm	0.099	s	3.13	1.50	0	0	0	0	45	24	75	36	
11	W	11N0	0.350	s	11.06	9.22	0	0	0	0	21	21	232	194	
	W	12F-0sm	0.099	w	3.13	1.50	90	90	282	135	45	45	141	67	
	C	16A-28md	0.034	-	1.07	2.37	150	150	161	356	800	800	860	1900	
	F	22A-1pl	0.989	-	31.25	0.00	150	10	313	0	800	20	625	0	
6	c) AED excursion									0				0	
	Envelope loss/gain									755	491			2381	2494
12	a) Infiltration									220	52			440	104
	b) Room ventilation									0	0			0	0
13	Internal gains.		Occupants @		230		0			0	0			0	0
			Appliances/other							0	0			0	0
	Subtotal (lines 6 to 13)									975	543			2821	2599
	Less external load									0	0			0	0
	Less transfer									0	0			0	0
	Redistribution									364	271			-2821	-2599
14	Subtotal									1339	815			0	0
15	Duct loads						44%	96%		586	781	44%	96%	0	0
	Total room load									1925	1596			0	0
	Air required (cfm)									64	69			0	0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Project Information


For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Design Conditions

Location:		Indoor:	Heating	Cooling
Gainesville Regional AP, FL, US		Indoor temperature (°F)	65	78
Elevation:	164 ft	Design TD (°F)	32	14
Latitude:	30°N	Relative humidity (%)	30	50
Outdoor:		Moisture difference (gr/lb)	5.0	40.4
	Heating	Cooling		
Drybulb (°F)	33	92		
Dailyrange (°F)	-	18 (M)		
Wet bulb (°F)	-	76		
Wind speed (mph)	15.0	7.5		
		Infiltration:		

Front Door	North	Northeast	East	Southeast	South	Southwest	West	Northwest
Sensible Load (Btuh)	34924	34924	34924	34924	34924	34924	34924	34924
Latent Load (Btuh)	7065	7065	7065	7065	7065	7065	7065	7065
Total Load (Btuh)	41989	41989	41989	41989	41989	41989	41989	41989
Heating AVF (cfm)	1550	1550	1550	1550	1550	1550	1550	1550
Cooling AVF (cfm)	1550	1550	1550	1550	1550	1550	1550	1550

Building Orientation Cooling Load



Current Orientation: Front Door faces North
 Highest Cooling Load: Front Door faces North

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



J1 Form - Worksheet A
Entire House
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

Supporting Detail	
Project Name: Lake City Mini Storage Baya Ave	Date: 09/22/2025
Address: Baya Ave, Lake City, FL 32025	
Phone:	Job ID: 1

Worksheet A Location and Design Conditions		
Weather Location: Gainesville Regional AP, FL, US	Elevation = 164	Latitude = 30
Indoor Conditions, Heating: DB = 65 °F RH = 30 %	Indoor Conditions, Cooling: DB = 78 °F RH = 50 %	
Table 1 Conditions 99% DB = 33 °F 1% DB = 92 °F	Grains Difference = 40 gr/lb	Daily Range = M
Design Temperature Differences	HTD = 32 °F	CTD = 14 °F

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone. 386-754-1987 Email derrick@dtwilliamsheatingandcooling.com

1 Name of Room				Entire House					Room2			
2 Running Feet of Exposed Wall				9.0 ft					9.0 ft			
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)				330.0 ft					30.0 ft			
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)				14850.0 ft²					540.0 ft²			
5 Ceiling Slope (Deg) and Gross Ceiling Area (SqFt)				5000.0 ft²					200.0 ft²			
				0 °					0 °			
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh		
			Htg	Clg		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg
6 Wall	12F-0sm	n	3.13	1.50	360	1126	540		0	0	0	
	12F-0sm	e	3.13	1.50	1125	3454	1656		90	282	135	
Door	11N0	e	11.06	9.22	21	232	194		0	0	0	
	12F-0sm	s	3.13	1.50	360	1061	508		180	563	270	
11 Door	11N0	s	11.06	9.22	21	232	194		0	0	0	
	12F-0sm	w	3.13	1.50	1125	3519	1687		0	0	0	
Wall	16A-28md	-	1.07	2.37	5000	5372	11875		200	215	475	
Cell	22A-tp1	-	31.25	0.00	5000	10313	0		200	938	0	
Flor												
12 Infiltration	Heating Load (Btuh)		Effect ACH		0.28	7256			WAR 1.00	680	-	
	Sensible Load (Btuh)				0.15		1722		WAR 0.09		157	
	Latent Load (Btuh)							3074				
13 Internal	a Occupants at 230 and 200 Btuh				0	0	0	0	0	0	0	
	b Scenario number					0				0		
	c Default Adjustments									0	0	
	d Custom Appliances					0	0			0	0	
	e Plants						0				0	
14 Subtotals	Sum lines 6 through 12					32566	18376	3074		0	0	
15 Duct Loads	EHLF & ESGF		0.438	0.959		14261	17629			0	0	
	ELG							3991			160	
16 Ventilation Loads	Vent Cfm	0	E Cfm	0		0	0	0				
17 Winter Humidification Load	Gal/Day		0			0						
18 Piping Load						0						
19 Blower Heat							0					
20 AED Excursion & Latent Moisture Migration Load							0			0		
21 Total Load	Sum lines 13 through 19					48827	38005	7085		0	0	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1 Name of Room				Room3			Room4					
2 Running Feet of Exposed Wall				10.0 ft			10.0 ft					
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)				9.0 ft 10.0 x 20.0 ft			9.0 ft 10.0 x 20.0 ft					
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)				540.0 ft² 200.0 ft²			540.0 ft² 200.0 ft²					
5 Ceiling Slope (Deg) and Gross Ceiling Area (SqFt)				0 ° 200.0 ft²			0 ° 200.0 ft²					
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh		
			Htg	Clg		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg
6	Wall	12F-0sm	n	3.13	1.50	0	0	0	0	0	0	0
	Wall	12F-0sm	e	3.13	1.50	90	282	135	90	282	135	
	Door	11N0	e	11.06	9.22	0	0	0	0	0	0	
	Wall	12F-0sm	s	3.13	1.50	0	0	0	0	0	0	
11	Door	11N0	s	11.06	9.22	0	0	0	0	0	0	
	Wall	12F-0sm	w	3.13	1.50	0	0	0	0	0	0	
	Cell	18A-28md	-	1.07	2.37	200	215	475	200	215	475	
	Flor	22A-tpl	-	31.25	0.00	200	313	0	200	313	0	
12	Infiltration	Heating Load (Btuh)		Effect ACH	0.28	WAR 0.03	220		WAR 0.03	220		
		Sensible Load (Btuh)			0.15			52			52	
		Latent Load (Btuh)										
13	Internal	a Occupants at 230 and 200 Btuh				0	0	0	0	0	0	0
		b Scenario number					0			0		
		c Default Adjustments					0			0		
		d Custom Appliances					0			0		
		e Plants					0			0		
14	Subtotals	Sum lines 6 through 12					0	0		2276	1461	
15	Duct Loads	EHLF & ESGF		0.438	0.959		0	0		997	1402	
		ELG							160			160
16	Ventilation Loads	Vent Cfm	0	E Cfm	0							
17	Winter Humidification Load	Gal/Day		0								
18	Piping Load											
19	Blower Heat											
20	AED Excursion & Latent Moisture Migration Load											
21	Total Load	Sum lines 13 through 19					0	0		3272	2863	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1 Name of Room			Room5			Room6						
2 Running Feet of Exposed Wall			10.0 ft			10.0 ft						
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)			9.0 ft 540.0 ft²			9.0 ft 540.0 ft²						
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)			10.0 x 20.0 ft 200.0 ft²			10.0 x 20.0 ft 200.0 ft²						
5 Ceiling Slope (Deg) and Gross Ceiling Area (SqFt)			0 ° 200.0 ft²			0 ° 200.0 ft²						
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh		
			Htg	Clg		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg
6	Wall	12F-0sm	n	3.13	1.50	0	0	0	0	0	0	0
	Wall	12F-0sm	e	3.13	1.50	90	282	135	90	282	135	0
11	Door	11N0	e	11.06	9.22	0	0	0	0	0	0	0
	Wall	12F-0sm	s	3.13	1.50	0	0	0	0	0	0	0
11	Door	11N0	s	11.06	9.22	0	0	0	0	0	0	0
	Wall	12F-0sm	w	3.13	1.50	0	0	0	0	0	0	0
11	Cell	16A-28md	-	1.07	2.37	200	215	475	200	215	475	0
	Flor	22A-1pl	-	31.25	0.00	200	313	0	200	313	0	0
12	Infiltration	Heating Load (Btuh)		Effect ACH	0.28	WAR 0.03	220	WAR 0.03	220	220	52	52
		Sensible Load (Btuh)			0.15		52		52			
		Latent Load (Btuh)										
13	Internal	a Occupants at 230 and 200 Btuh			0	0	0	0	0	0	0	0
		b Scenario number										
		c Default Adjustments										
		d Custom Appliances										
		e Plants										
14	Subtotals	Sum lines 6 through 12				1247	799		1247	799		
15	Duct Loads	EHLF & ESGF		0.438	0.959	546	766		546	766		
		ELG						160			160	
16	Ventilation Loads	Vent Cfm	0	E Cfm	0							
17	Winter Humidification Load	Gal/Day		0								
18	Piping Load											
19	Blower Heat											
20	AED Excursion & Latent Moisture Migration Load						0			0		
21	Total Load	Sum lines 13 through 19				1793	1565		1793	1565		

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com

1 Name of Room				Room7					Room8			
2 Running Feet of Exposed Wall				10.0 ft					10.0 ft			
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)				9.0 ft					9.0 ft			
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)				10.0 x 20.0 ft					10.0 x 20.0 ft			
5 Ceiling Slope (Deg) and Gross Ceiling Area (SqFt)				0 °					0 °			
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Bluh			Area or Length	Bluh		
			Htg	Cig		Heating	S-Cig	L-Cig		Heating	S-Cig	L-Cig
6 Wall	12F-0sm	n	3.13	1.50	0	0	0	0	0	0	0	
Wall	12F-0sm	e	3.13	1.50	90	282	135	90	282	135	0	
Door	11N0	s	11.06	9.22	0	0	0	0	0	0	0	
11 Wall	12F-0sm	s	3.13	1.50	0	0	0	0	0	0	0	
Door	11N0	s	11.06	9.22	0	0	0	0	0	0	0	
Wall	12F-0sm	w	3.13	1.50	0	0	0	0	0	0	0	
Cell	16A-28md	-	1.07	2.37	200	215	475	200	215	475	0	
Flor	22A-1pl	-	31.25	0.00	200	313	0	200	313	0	0	
12 Infiltration	Heating Load (Btuh)		Effect ACH		WAR 0.03	220		WAR 0.03	220			
	Sensible Load (Btuh)		0.28				52				52	
	Latent Load (Btuh)		0.15									
13 Internal	a	Occupants at 230 and 200 Btuh				0	0	0	0	0	0	
	b	Scenario number					0			0		
	c	Default Adjustments					0			0		
	d	Custom Appliances					0			0		
	e	Plants					0			0		
14 Subtotals	Sum lines 6 through 12					1247	799		1441	978		
15 Duct Loads	EHLF & ESGF		0.438	0.959		546	766		631	938		
	ELG							160			160	
16 Ventilation Loads	Vent Cfm	0	E Cfm	0								
17 Winter Humidification Load	Gal/Day		0									
18 Piping Load												
19 Blower Heat												
20 AED Excursion & Latent Moisture Migration Load							0			0		
21 Total Load	Sum lines 13 through 19					1793	1585		2073	1916		

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1 Name of Room				Room9					Room10			
2 Running Feet of Exposed Wall				30.0 ft					10.0 ft			
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)				9.0 ft 540.0 ft²					9.0 ft 540.0 ft²			
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)				10.0 x 20.0 ft 200.0 ft²					10.0 x 20.0 ft 200.0 ft²			
5 Ceiling Slope (Deg.) and Gross Ceiling Area (SqFt)				0 ° 200.0 ft²					0 ° 200.0 ft²			
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh		
			Htg	Clg		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg
6 Wall	12F-0sm	n	3.13	1.50	180	563	270		0	0	0	
Wall	12F-0sm	e	3.13	1.50	90	282	135		90	282	135	
Door	11N0	e	11.06	9.22	0	0	0		0	0	0	
Wall	12F-0sm	s	3.13	1.50	0	0	0		0	0	0	
Door	11N0	s	11.06	9.22	0	0	0		0	0	0	
Wall	12F-0sm	w	3.13	1.50	0	0	0		0	0	0	
Cell	16A-28md	-	1.07	2.37	200	215	475		200	215	475	
Floor	22A-1pl	-	31.25	0.00	200	938	0		200	313	0	
12 Infiltration	Heating Load (Btuh)		Effect ACH		WAR 0.09	680			WAR 0.03	220		
	Sensible Load (Btuh)		0.28			157				52		
	Latent Load (Btuh)		0.15									
13 Internal	a	Occupants at 230 and 200 Btuh				0	0	0	0	0	0	0
	b	Scenario number					0			0		
	c	Default Adjustments										
	d	Custom Appliances					0	0		0	0	
	e	Plants						0			0	
14 Subtotals	Sum lines 6 through 12					2875	1173		1247	799		
15 Duct Loads	EHLF & ESGF		0.438	0.959		1259	1126		546	766		
	ELG							160			160	
16 Ventilation Loads	Vent Cfm	0	E Cfm	0								
17 Winter Humidification Load	Gal/Day		0									
18 Piping Load												
19 Blower Heat												
20 AED Excursion & Latent Moisture Migration Load							0			0		
21 Total Load	Sum lines 13 through 19					4134	2299		1793	1565		

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatngandcooling.com

1 Name of Room				Room11					Room12				
2 Running Feet of Exposed Wall				10.0 ft					10.0 ft				
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)				9.0 ft 540.0 ft ²					9.0 ft 540.0 ft ²				
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)				10.0 x 20.0 ft 200.0 ft ²					10.0 x 20.0 ft 200.0 ft ²				
5 Ceiling Slope (Deg.) and Gross Ceiling Area (SqFt)				0 ° 200.0 ft ²					0 ° 200.0 ft ²				
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh			
			Htg	Clg.		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg	
6 Wall	12F-0sm	n	3.13	1.50	0	0	0	0	0	0	0	0	
Wall	12F-0sm	e	3.13	1.50	90	282	135	0	90	282	135	0	
Door	11N0	e	11.06	9.22	0	0	0	0	0	0	0	0	
Wall	12F-0sm	s	3.13	1.50	0	0	0	0	0	0	0	0	
Door	11N0	s	11.06	9.22	0	0	0	0	0	0	0	0	
Wall	12F-0sm	w	3.13	1.50	0	0	0	0	0	0	0	0	
Ceil	16A-28md	-	1.07	2.37	200	215	475	0	200	215	475	0	
Floer	22A-ipl	-	31.25	0.00	200	313	0	0	200	313	0	0	
12 Infiltration	Heating Load (Btuh)		Effect ACH		WAR 0.03	220			WAR 0.03	220			
	Sensible Load (Btuh)		0.28				52					52	
	Latent Load (Btuh)		0.15										
13 Internal	a Occupants at 230 and 200 Btuh				0	0	0	0	0	0	0	0	
	b Scenario number					0	0	0		0	0	0	
	c Default Adjustments												
	d Custom Appliances					0	0	0		0	0	0	
	e Plants												
14 Subtotals	Sum lines 6 through 12					1247	799			1247	799		
15 Duct Loads	EHLF & ESGF		0.438	0.959		546	766			546	766		
	ELG							160				160	
16 Ventilation Loads	Vent Cfm	0	E Cfm	0									
17 Winter Humidification Load	Gal/Day		0										
18 Piping Load													
19 Blower Heat													
20 AED Excursion & Latent Moisture Migration Load							0			0			
21 Total Load	Sum lines 13 through 19					1793	1565			1793	1565		

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1 Name of Room				Room13					Room14				
2 Running Feet of Exposed Wall				10.0 ft					25.0 ft				
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)				9.0 ft					9.0 ft				
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)				10.0 x 20.0 ft					10.0 x 15.0 ft				
5 Ceiling Slope (Deg) and Gross Ceiling Area (SqFt)				0 °					0 °				
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh			
			Htg	Clg		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg	
6	Wall	12F-0sm	3.13	1.50	0	0	0	0	0	0	0	0	
	Wall	12F-0sm	3.13	1.50	90	282	135		0	0	0	0	
	Door	11N0	11.06	9.22	0	0	0	0	0	0	0	0	
	Wall	12F-0sm	3.13	1.50	0	0	0	0	135	422	202	0	
11	Door	11N0	11.06	9.22	0	0	0	0	0	0	0	0	
	Wall	12F-0sm	3.13	1.50	0	0	0	0	90	282	135	0	
	Cell	16A-28md	1.07	2.37	200	215	475		150	161	356	0	
	Flor	22A-tpl	31.25	0.00	200	313	0		150	781	0	0	
12	Infiltration	Heating Load (Btuh)		Effect ACH	0.28	WAR 0.03	220			WAR 0.08	550		
		Sensible Load (Btuh)					52				130		
		Latent Load (Btuh)											
13	Internal	a Occupants at 230 and 200 Btuh			0		0			0	0		
		b Scenario number					0				0		
		c Default Adjustments					0				0		
		d Custom Appliances					0				0		
		e Plants					0				0		
14	Subtotals	Sum lines 6 through 12				1441	978		2414	961			
15	Duct Loads	EHLF & ESGF		0.438	0.959		631	938		1057	922		
		ELG						160			120		
16	Ventilation Loads	Vent Cfm	0	E Cfm	0								
17	Winter Humidification Load	Gal/Day		0									
18	Piping Load												
19	Blower Heat												
20	AED Excursion & Latent Moisture Migration Load						0			0			
21	Total Load	Sum lines 13 through 19				2073	1916		3471	1883			

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1 Name of Room					Room15			Room16				
2 Running Feet of Exposed Wall					9.0 ft	10.0 ft	450.0 ft ²	9.0 ft	10.0 ft	450.0 ft ²		
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)					10.0 x 15.0 ft		150.0 ft ²	10.0 x 15.0 ft		150.0 ft ²		
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)					0 °		150.0 ft ²	0 °		150.0 ft ²		
5 Ceiling Slope (Deg) and Gross Ceiling Area (SqFt)												
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh		
			Htg	Clg.		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg
6 Wall	12F-0sm	n	3.13	1.50	0	0	0	0	0	0	0	
Wall	12F-0sm	e	3.13	1.50	0	0	0	0	0	0	0	
Door	11N0	e	11.06	9.22	0	0	0	0	0	0	0	
Wall	12F-0sm	s	3.13	1.50	0	0	0	0	0	0	0	
Door	11N0	s	11.06	9.22	0	0	0	0	0	0	0	
Wall	12F-0sm	w	3.13	1.50	90	282	135	90	282	135	90	
Ceiling	16A-28md	-	1.07	2.37	160	161	356	150	161	356	150	
Floor	22A-tpl	-	31.25	0.00	150	313	0	150	313	0	150	
12 Infiltration	Heating Load (Btuh)		Effect ACH		0.28	220		220				
	Sensible Load (Btuh)		0.15		WAR 0.03		52	WAR 0.03		52		
	Latent Load (Btuh)											
13 Internal	a Occupants at 230 and 200 Btuh b Scenario number c Default Adjustments d Custom Appliances e Plants				0		0	0	0		0	
14 Subtotals	Sum lines 6 through 12					1193	680		1193	680		
15 Duct Loads	EHLF & ESCF		0.438	0.959		522	652		522	652		
	ELG							120			120	
16 Ventilation Loads	Vent Cfm	0	E Cfm	0								
17 Winter Humidification Load	Gal/Day		0									
18 Piping Load												
19 Blower Heat												
20 AED Excursion & Latent Moisture Migration Load							0			0		
21 Total Load	Sum lines 13 through 19					1716	1333		1716	1333		

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1 Name of Room				Room17					Room18				
2 Running Feet of Exposed Wall				10.0 ft					10.0 ft				
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)				9.0 ft					9.0 ft				
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)				10.0 x 15.0 ft					10.0 x 15.0 ft				
5 Ceiling Slope (Deg) and Gross Ceiling Area (SqFt)				0 °					0 °				
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh			
			Htg	Clg.		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg	
6	Wall	12F-0sm	n	3.13	1.50	0	0	0	0	0	0	0	
	Wall	12F-0sm	e	3.13	1.50	0	0	0	0	0	0	0	
	Door	11N0	e	11.06	9.22	0	0	0	0	0	0	0	
	Wall	12F-0sm	s	3.13	1.50	0	0	0	0	0	0	0	
11	Door	11N0	s	11.06	9.22	0	0	0	0	0	0	0	
	Wall	12F-0sm	w	3.13	1.50	90	282	135	90	282	135	0	
	Cell	16A-28mid	-	1.07	2.37	160	161	356	150	161	356	0	
	Flor	22A-1pl	-	31.25	0.00	150	313	0	150	313	0	0	
12	Infiltration	Heating Load (Btuh)		Effect ACH	0.28	WAR 0.03	220	WAR 0.03	220				
		Sensible Load (Btuh)			0.15		52		52				
		Latent Load (Btuh)											
13	Internal	a Occupants at 230 and 200 Btuh				0	0	0	0	0	0	0	0
		b Scenario number					0			0		0	
		c Default Adjustments					0			0		0	
		d Custom Appliances					0			0		0	
		e Plants					0			0		0	
14	Subtotals	Sum lines 6 through 12					1193	680		1193	680		
15	Duct Loads	EHLF & ESGF		0.438	0.959		522	652		522	652		
		ELG							120			120	
16	Ventilation Loads	Vent Cfm	0	E Cfm	0								
17	Winter Humidification Load	Gal/Day		0									
18	Piping Load												
19	Blower Heat												
20	AED Excursion & Latent Moisture Migration Load							0			0		
21	Total Load	Sum lines 13 through 19					1716	1333		1716	1333		

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1 Name of Room				Room19					Room20			
2 Running Feet of Exposed Wall				10.0 ft					10.0 ft			
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)				9.0 ft					9.0 ft			
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)				10.0 x 15.0 ft					10.0 x 15.0 ft			
5 Ceiling Slope (Deg) and Gross Ceiling Area (SqFt)				0 °					0 °			
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh		
			Htg	Clg		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg
6 11	Wall	12F-0sm	n	3.13	1.50	0	0	0	0	0	0	0
	Wall	12F-0sm	e	3.13	1.50	0	0	0	0	0	0	0
	Door	11N0	e	11.06	9.22	0	0	0	0	0	0	0
	Wall	12F-0sm	s	3.13	1.50	0	0	0	0	0	0	0
	Door	11N0	s	11.06	9.22	0	0	0	0	0	0	0
	Wall	12F-0sm	w	3.13	1.50	90	282	135	90	282	135	90
Cell	18A-28md	-	1.07	2.37	150	161	356	150	161	356	150	
Flor	22A-tp1	-	31.25	0.00	150	313	0	150	313	0	0	
12	Infiltration		Heating Load (Btuh)		Effect ACH	0.28	WAR 0.03	220	WAR 0.03	220		
	Sensible Load (Btuh)							52		52		
	Latent Load (Btuh)											
13	Internal		a Occupants at 230 and 200 Btuh			0	0	0	0	0	0	0
			b Scenario number				0	0		0		
			c Default Adjustments				0	0		0		
			d Custom Appliances				0	0		0		
			e Plants				0	0		0		
14	Subtotals		Sum lines 6 through 12			1193	680	1339	815			
15	Duct Loads		EHLF & ESGF		0.438	0.959	522	652	586	781		
			ELG						120	120		
16	Ventilation Loads		Vent Cfm	0	E Cfm	0						
17	Winter Humidification Load		Gal/Day		0							
18	Piping Load											
19	Blower Heat											
20	AED Excursion & Latent Moisture Migration Load											
21	Total Load		Sum lines 13 through 19			1716	1333	1925	1596			

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1 Name of Room				Room21					Room22			
2 Running Feet of Exposed Wall				25.0 ft					10.0 ft			
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)				9.0 ft 450.0 ft ²					9.0 ft 450.0 ft ²			
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)				10.0 x 15.0 ft 150.0 ft ²					10.0 x 15.0 ft 150.0 ft ²			
5 Ceiling Slope (Deg) and Gross Ceiling Area (SqFt)				0 ° 150.0 ft ²					0 ° 150.0 ft ²			
Type of Exposure	Const. Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh		
			Htg	Clg		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg
6 Wall	12F-0sm	n	3.13	1.50	135	422	202		0	0	0	
Wall	12F-0sm	e	3.13	1.50	0	0	0		0	0	0	
Door	11N0	e	11.06	9.22	0	0	0		0	0	0	
Wall	12F-0sm	s	3.13	1.50	0	0	0		0	0	0	
Door	11N0	s	11.06	9.22	0	0	0		0	0	0	
Wall	12F-0sm	w	3.13	1.50	90	282	135		90	282	135	
Cell	16A-28md	-	1.07	2.37	150	161	356		150	161	356	
Flor	22A-1pl	-	31.25	0.00	150	781	0		150	313	0	
12 Infiltration	Heating Load (Btuh)		Effect ACH		WAR 0.08	550			WAR 0.03	220		
	Sensible Load (Btuh)		0.28				130				52	
	Latent Load (Btuh)		0.15									
13 Internal	a	Occupants at 230 and 200 Btuh				0	0	0	0	0	0	
	b	Scenario number					0			0		
	c	Default Adjustments										
	d	Custom Appliances					0	0		0	0	
	e	Plants						0			0	
14 Subtotals	Sum lines 6 through 12					2414	961			1193	680	
15 Duct Loads	EHLF & ESGF		0.438	0.959		1057	922			522	652	
	ELG							120			120	
16 Ventilation Loads	Vent Cfm	0	E Cfm	0								
17 Winter Humidification Load	Gal/Day		0									
18 Piping Load												
19 Blower Heat												
20 AED Excursion & Latent Moisture Migration Load							0			0		
21 Total Load	Sum lines 13 through 19					3471	1883			1716	1333	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email derrick@dlwilliamsheatingandcooling.com


1 Name of Room				Room23					Room24				
2 Running Feet of Exposed Wall				10.0 ft					10.0 ft				
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)				9.0 ft 450.0 ft ²					9.0 ft 450.0 ft ²				
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)				10.0 x 15.0 ft 150.0 ft ²					10.0 x 15.0 ft 150.0 ft ²				
5 Ceiling Slope (Deg) and Gross Ceiling Area (SqFt)				0 ° 150.0 ft ²					0 ° 150.0 ft ²				
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh			
			Htg.	Clg		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg	
6 Wall	12F-0sm	n	3.13	1.50	0	0	0	0	0	0	0	0	
Wall	12F-0sm	e	3.13	1.50	0	0	0	0	0	0	0	0	
Door	11N0	e	11.06	9.22	0	0	0	0	0	0	0	0	
Wall	12F-0sm	s	3.13	1.50	0	0	0	0	0	0	0	0	
Door	11N0	s	11.06	9.22	0	0	0	0	0	0	0	0	
Wall	12F-0sm	w	3.13	1.50	90	282	135	90	282	135	90	282	
Ceiling	16A-28md	-	1.07	2.37	150	161	356	150	161	356	150	356	
Floor	22A-tp1	-	31.25	0.00	150	313	0	150	313	0	150	0	
12 Infiltration	Heating Load (Btuh)		Effect ACH		WAR 0.03	220			WAR 0.03	220			
	Sensible Load (Btuh)		0.28			52				52			
	Latent Load (Btuh)		0.15										
13 Internal	a Occupants at 230 and 200 Btuh				0	0			0	0			
	b Scenario number					0				0			
	c Default Adjustments					0				0			
	d Custom Appliances					0				0			
	e Plants					0				0			
14 Subtotals	Sum lines 6 through 12					1193	680		1193	680			
15 Duct Loads	EHLF & ESGF		0.438	0.959		522	652		522	652			
	ELG					120			120				
16 Ventilation Loads	Vent Cfm	0	E Cfm	0									
17 Winter Humidification Load	Gal/Day		0										
18 Piping Load													
19 Blower Heat													
20 AED Excursion & Latent Moisture Migration Load						0			0				
21 Total Load	Sum lines 13 through 19					1716	1333		1716	1333			

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.


PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

1 Name of Room			Room25						Room26			
2 Running Feet of Exposed Wall			9.0 ft			10.0 ft			9.0 ft			
3 Ceiling Ht (Ft) and Gross Wall Area (SqFt)			10.0 x 15.0 ft			450.0 ft ²			2970.0 ft ²			
4 Room Dimensions (Ft) and Floor Plan Area (SqFt)			0 °			150.0 ft ²			800.0 ft ²			
5 Ceiling Slope (Deg) and Gross Ceiling Area (SqFt)			150.0 ft ²			150.0 ft ²			800.0 ft ²			
Type of Exposure	Const., Number	Panel Faces	HTM		Area or Length	Btuh			Area or Length	Btuh		
			Htg	Clg.		Heating	S-Clg	L-Clg		Heating	S-Clg	L-Clg
6	Wall	12F-0sm	n	3.13	1.50	0	0	0	45	141	67	
	Wall	12F-0sm	e	3.13	1.50	0	0	0	45	75	36	
	Door	11N0		11.06	9.22	0	0	0	21	232	194	
11	Wall	12F-0sm	s	3.13	1.50	0	0	0	45	75	36	
	Door	11N0	s	11.06	9.22	0	0	0	21	232	194	
	Wall	12F-0sm	w	3.13	1.50	90	282	135	45	141	67	
	Ceill	16A-28md	-	1.07	2.37	150	161	356	800	860	1900	
	Flor	22A-tp1	-	31.25	0.00	150	313	0	800	625	0	
12	Infiltration		Heating Load (Btuh)		Effect ACH	0.28	WAR 0.03	220	WAR 0.06	440		
	Sensible Load (Btuh)										104	
	Latent Load (Btuh)											
13	Internal		a Occupants at 230 and 200 Btuh			0	0	0	0	0	0	0
			b Scenario number									
			c Default Adjustments									
			d Custom Appliances									
			e Plants									
14	Subtotals		Sum lines 6 through 12				1339	815		0	0	
15	Duct Loads		EHLF & ESGF		0.438	0.959	586	781		0	0	
			ELG					120			639	
16	Ventilation Loads		Vent Cfm	0	E Cfm	0						
17	Winter Humidification Load		Gal/Day		0							
18	Piping Load											
19	Blower Heat											
20	AED Excursion & Latent Moisture Migration Load						0			0		
21	Total Load		Sum lines 13 through 19				1925	1596		0	0	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Sheet 1



Job #: 1
Performed by DL Williams for:
Lake City Mini Storage
Baya Ave
Lake City, FL 32025

D.L. Williams Heating & Cooling LLC
PO Box 2156
Lake City, FL 32056
Phone. 386-754-1987
derrick@dlwilliamsheatingandcooling.com

Scale: 1 : 208
Page 1
Right-Suite@ Universal 2025
25.0.03 RSU02245
2025-Sep-22 15:40:50
...e City Mini Storage Baya Ave.rup

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

	Heating	Cooling
External static pressure	0.50 in H2O	0.50 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.50 in H2O	0.50 in H2O
Supply / return available pressure	0.456 / 0.044 in H2O	0.456 / 0.044 in H2O
Lowest friction rate	0.061 in/100ft	0.061 in/100ft
Actual air flow	1550 cfm	1550 cfm
Total effective length (TEL)	825 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Room10	c 1565	59	67	0.065	6.0	0x0	ShMt	107.0	590.0	st3A
Room11	c 1565	59	67	0.070	6.0	0x0	ShMt	97.0	555.0	st3A
Room12	c 1565	59	67	0.073	6.0	0x0	ShMt	86.0	535.0	st3
Room13	c 1916	69	83	0.079	6.0	0x0	ShMt	77.0	500.0	st3
Room14	h 3471	115	81	0.411	5.0	0x0	ShMt	6.0	105.0	
Room15	c 1333	57	57	0.246	5.0	0x0	ShMt	10.0	175.0	st1
Room16	c 1333	57	57	0	0	0x0	ShMt	0	0	
Room17	c 1333	57	57	0.125	5.0	0x0	ShMt	30.0	335.0	st7
Room18	c 1333	57	57	0.100	5.0	0x0	ShMt	40.0	415.0	st5
Room19	c 1333	57	57	0.101	5.0	0x0	ShMt	50.0	400.0	st3
Room20	c 1596	64	69	0.088	5.0	0x0	ShMt	60.0	455.0	st3
Room21	h 3471	115	81	0.061	7.0	0x0	ShMt	115.0	635.0	st3B
Room22	c 1333	57	57	0.066	5.0	0x0	ShMt	105.0	590.0	st3A
Room23	c 1333	57	57	0.070	5.0	0x0	ShMt	96.0	555.0	st3A
Room24	c 1333	57	57	0.070	5.0	0x0	ShMt	85.0	565.0	st3A
Room25	c 1596	64	69	0.079	6.0	0x0	ShMt	75.0	500.0	st3
Room4	c 2863	108	123	0	0	0x0	ShMt	0	0	
Room5	c 1565	59	67	0	0	0x0	ShMt	0	0	
Room6	c 1565	59	67	0	0	0x0	ShMt	0	0	
Room7	c 1565	59	67	0.101	5.0	0x0	ShMt	52.0	400.0	st3
Room8	c 1916	69	83	0.088	6.0	0x0	ShMt	62.0	455.0	st3
Room9-A	h 4134	137	99	0.061	8.0	0x0	ShMt	117.0	635.0	st3B

Bold/Italic values have been manually overridden

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st3B	Peak AVF	252	180	0.061	462	10.0	0 x 0	ShtMetl	st3A
st3A	Peak AVF	541	487	0.061	689	12.0	0 x 0	ShtMetl	st3
st3	Peak AVF	981	981	0.061	703	16.0	0 x 0	ShtMetl	st5
st5	Peak AVF	1038	1039	0.061	744	16.0	0 x 0	ShtMetl	st7
st7	Peak AVF	1095	1096	0.061	785	16.0	0 x 0	ShtMetl	st10
st10	Peak AVF	1095	1096	0.061	785	16.0	0 x 0	ShtMetl	st1
st1	Peak AVF	1151	1154	0.061	826	16.0	0 x 0	ShtMetl	

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb1	0x0	1550	1550	73.0	0.061	644	21.0	0x0		ShMt	





Duct system multi orientation report

Entire House

D.L. Williams Heating & Cooling LLC

Job: 1
Date: 09/22/2025
By: DL Williams
Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
Baya Ave, Lake City, FL 32025

Group 1: (N, NE, E, SE, S, SW, W, NW)

Duct Name	(N)			(NE)			(E)			(SE)		
	Reg CFM	Reg Size	Duct Size	Reg CFM	Reg Size	Duct Size	Reg CFM	Reg Size	Duct Size	Reg CFM	Reg Size	Duct Size
Supply Branches												
Room10	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6
Room11	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6
Room12	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6
Room13	83 c	12x12	6	83 c	12x12	6	83 c	12x12	6	83 c	12x12	6
Room14	115 h	12x12	5	115 h	12x12	5	115 h	12x12	5	115 h	12x12	5
Room15	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room16	57 c	12x12	0	57 c	12x12	0	57 c	12x12	0	57 c	12x12	0
Room17	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room18	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room19	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room20	69 c	12x12	5	69 c	12x12	5	69 c	12x12	5	69 c	12x12	5
Room21	115 h	12x12	7	115 h	12x12	7	115 h	12x12	7	115 h	12x12	7
Room22	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room23	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room24	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room25	69 c	12x12	6	69 c	12x12	6	69 c	12x12	6	69 c	12x12	6
Room4	123 c	12x12	0	123 c	12x12	0	123 c	12x12	0	123 c	12x12	0
Room5	67 c	12x12	0	67 c	12x12	0	67 c	12x12	0	67 c	12x12	0
Room6	67 c	12x12	0	67 c	12x12	0	67 c	12x12	0	67 c	12x12	0
Room7	67 c	12x12	5	67 c	12x12	5	67 c	12x12	5	67 c	12x12	5
Room8	83 c	12x12	6	83 c	12x12	6	83 c	12x12	6	83 c	12x12	6
Room9-A	137 h	12x12	8	137 h	12x12	8	137 h	12x12	8	137 h	12x12	8
Supply Trunks												
st3B	252 h		10	252 h		10	252 h		10	252 h		10
st3A	541 h		12	541 h		12	541 h		12	541 h		12
st3	981 c		16	981 c		16	981 c		16	981 c		16
st5	1039 c		16	1039 c		16	1039 c		16	1039 c		16
st7	1096 c		16	1096 c		16	1096 c		16	1096 c		16
st10	1096 c		16	1096 c		16	1096 c		16	1096 c		16
st1	1154 c		16	1154 c		16	1154 c		16	1154 c		16
Return Branches												
rb1	1550 c	12x12	21	1550 c	12x12	21	1550 c	12x12	21	1550 c	12x12	21
Friction Rates												
Heating FR	0.061			0.061			0.061			0.061		
Cooling FR	0.061			0.061			0.061			0.061		



Right-Suite® Universal 2025 25 0.03 RSU02245

. HVAC\Tranel\Lake City Mini Storage Baya Ave.rup Calc = MJ8 Front Door faces. N

2025-Sep-22 15:40:25

Page 1

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Duct Name	(S)			(SW)			(W)			(NW)		
	Reg CFM	Reg Size	Duct Size	Reg CFM	Reg Size	Duct Size	Reg CFM	Reg Size	Duct Size	Reg CFM	Reg Size	Duct Size
Supply Branches												
Room10	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6
Room11	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6
Room12	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6	67 c	12x12	6
Room13	83 c	12x12	6	83 c	12x12	6	83 c	12x12	6	83 c	12x12	6
Room14	115 h	12x12	5	115 h	12x12	5	115 h	12x12	5	115 h	12x12	5
Room15	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room16	57 c	12x12	0	57 c	12x12	0	57 c	12x12	0	57 c	12x12	0
Room17	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room18	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room19	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room20	69 c	12x12	5	69 c	12x12	5	69 c	12x12	5	69 c	12x12	5
Room21	115 h	12x12	7	115 h	12x12	7	115 h	12x12	7	115 h	12x12	7
Room22	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room23	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room24	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5	57 c	12x12	5
Room25	69 c	12x12	6	69 c	12x12	6	69 c	12x12	6	69 c	12x12	6
Room4	123 c	12x12	0	123 c	12x12	0	123 c	12x12	0	123 c	12x12	0
Room5	67 c	12x12	0	67 c	12x12	0	67 c	12x12	0	67 c	12x12	0
Room6	67 c	12x12	0	67 c	12x12	0	67 c	12x12	0	67 c	12x12	0
Room7	67 c	12x12	5	67 c	12x12	5	67 c	12x12	5	67 c	12x12	5
Room8	83 c	12x12	6	83 c	12x12	6	83 c	12x12	6	83 c	12x12	6
Room9-A	137 h	12x12	8	137 h	12x12	8	137 h	12x12	8	137 h	12x12	8
Supply Trunks												
st3B	252 h		10	252 h		10	252 h		10	252 h		10
st3A	541 h		12	541 h		12	541 h		12	541 h		12
st3	981 c		16	981 c		16	981 c		16	981 c		16
st5	1039 c		16	1039 c		16	1039 c		16	1039 c		16
st7	1096 c		16	1096 c		16	1096 c		16	1096 c		16
st10	1096 c		16	1096 c		16	1096 c		16	1096 c		16
st1	1154 c		16	1154 c		16	1154 c		16	1154 c		16
Return Branches												
rb1	1550 c	12x12	21	1550 c	12x12	21	1550 c	12x12	21	1550 c	12x12	21
Friktion Rates												
Heating FR	0.061			0.061			0.061			0.061		
Cooling FR	0.061			0.061			0.061			0.061		

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Duct Name	Largest			Smallest		
	Reg CFM	Reg Size	Duct Size	Reg CFM	Reg Size	Duct Size
Supply Branches						
Room10	67 c	12x12	6	67 c	12x12	6
Room11	67 c	12x12	6	67 c	12x12	6
Room12	67 c	12x12	6	67 c	12x12	6
Room13	83 c	12x12	6	83 c	12x12	6
Room14	115 h	12x12	5	115 h	12x12	5
Room15	57 c	12x12	5	57 c	12x12	5
Room16	57 c	12x12	0	57 c	12x12	0
Room17	57 c	12x12	5	57 c	12x12	5
Room18	57 c	12x12	5	57 c	12x12	5
Room19	57 c	12x12	5	57 c	12x12	5
Room20	69 c	12x12	5	69 c	12x12	5
Room21	115 h	12x12	7	115 h	12x12	7
Room22	57 c	12x12	5	57 c	12x12	5
Room23	57 c	12x12	5	57 c	12x12	5
Room24	57 c	12x12	5	57 c	12x12	5
Room25	69 c	12x12	6	69 c	12x12	6
Room4	123 c	12x12	0	123 c	12x12	0
Room5	67 c	12x12	0	67 c	12x12	0
Room6	67 c	12x12	0	67 c	12x12	0
Room7	67 c	12x12	5	67 c	12x12	5
Room8	83 c	12x12	6	83 c	12x12	6
Room9-A	137 h	12x12	8	137 h	12x12	8
Supply Trunks						
st3B	252 h		10	252 h		10
st3A	541 h		12	541 h		12
st3	981 c		16	981 c		16
st5	1039 c		16	1039 c		16
st7	1096 c		16	1096 c		16
st10	1096 c		16	1096 c		16
st1	1154 c		16	1154 c		16
Return Branches						
rb1	1550 c	12x12	21	1550 c	12x12	21
Friction Rates						
Heating FR	0.061			0.061		
Cooling FR	0.061			0.061		



Background Color Legend

Yellow background

Duct Size - duct size is smaller than the largest duct size in the row

Reg Size - register size is smaller than the largest register size in the row

Reg CFM - register design cfm is larger than 150 CFM

Friction Rate - friction rate is outside ACCA Manual-D recommended range (0.06 - 0.18)

Pink background column header

Largest cooling load orientation





Static Pressure and Friction Rate
Entire House
D.L. Williams Heating & Cooling LLC

Job: 1
 Date: 09/22/2025
 By: DL Williams
 Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
 Baya Ave, Lake City, FL 32025

Available Static Pressure

	Heating (in H2O)	Cooling (in H2O)
External static pressure	0.50	0.50
Pressure losses		
Coil	0	0
Heat exchanger	0	0
Supply diffusers	0	0
Return grilles	0	0
Filter	0	0
Humidifier	0	0
Balancing damper	0	0
Other device	0	0
Available static pressure	0.50	0.50

Total Effective Length

	Supply (ft)	Return (ft)
Measured length of run-out	5	3
Measured length of trunk	112	0
Equivalent length of fittings	635	70
Total length	752	73
Total effective length		825

Friction Rate

	Heating (in/100ft)		Cooling (in/100ft)	
Supply Ducts	0.061	OK	0.061	OK
Return Ducts	0.061	OK	0.061	OK

Fitting Equivalent Length Details

Supply 4AD=60, 2A0=35, 2A0=35, 12J1=10, 2A1=45, 12J1=10, 2A1=45, 2A2=55, 2A3=65, 2A5=80, 2A5=80, 2A5=80,
 USR1=35: TotalEL=635
 Return 6M=20, 8AE=10, 5D=40: TotalEL=70





Manual S Compliance Report

Entire House

D.L. Williams Heating & Cooling LLC

Job: 1
Date: 09/22/2025
By: DL Williams
Plan: 1

PO Box 2156, Lake City, FL 32056 Phone: 386-754-1987 Email: derrick@dlwilliamsheatingandcooling.com

Project Information

For: Lake City Mini Storage
Baya Ave, Lake City, FL 32025

Cooling Equipment

Design Conditions

Outdoor design DB:	92.0°F	Sensible gain:	36005 Btuh	Entering coil DB:	81.2°F
Outdoor design WB:	76.3°F	Latent gain:	7065 Btuh	Entering coil WB:	66.4°F
Indoor design DB:	78.0°F	Total gain:	43070 Btuh		
Indoor RH:	50%	Estimated airflow:	1550 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split AC		
Manufacturer:	Trane	Model:	5TTR4048A1+5TEM4D06AC41++TDR
Actual airflow:	1550 cfm		
Sensible capacity:	32550 Btuh		90% of load
Latent capacity:	13950 Btuh		197% of load
Total capacity:	46500 Btuh		108% of load SHR: 70%

Heating Equipment

Design Conditions

Outdoor design DB:	33.4°F	Heat loss:	46827 Btuh	Entering coil DB:	0°F
Indoor design DB:	65.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:		Model:			
Manufacturer:					
Actual airflow:	1550 cfm				
Output capacity:	0 Btuh		0% of load	Capacity balance:	0 °F
Supplemental heat required:	0 Btuh			Economic balance:	0 °F

Backup equipment type:		Model:			
Manufacturer:					
Actual airflow:	1550 cfm				
Output capacity:	0 Btuh		0% of load	Temp. rise:	0 °F

Meets all requirements of ACCA Manual S.



Right-Suite® Universal 2025 25.0 03 RSU02245

HVAC\Trane\Lake City Mini Storage Baya Ave.rup Calc = MJB Front Door faces' N

2025-Sep-22 15:40:27

Page 1



Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form
RPER 2.0

Columbia Header Information

Contractor D.L. Williams Heating & Cooling LLC Applicable Attachments
Derrick Williams Manual J1 Form and Worksheet A: Yes No
 Mechanical license# _____ OEM performance data (heating, cooling, blower) Yes No
 Building plan # 1 Duct distribution sketch: Yes No
 IRC Table R301.2 (climate & geographic design criteria) Yes No

Home address (Street or Lot#, Block, Subdivision) Baya Ave, Entire House

HVAC LOAD CALCULATION (IRC M1401.3)

Manual J Design Criteria and Loads

Location		Summer Design Conditions		Manual J Loads	
Elevation	164 ft	Outdoor Cooling Temp	92 °F	Total Heat Loss	46827 Btuh
Altitude Correction Factor	0.99	Indoor Cooling Temp	78 °F	Sensible Heat Gain	36005 Btuh
Latitude	30 °N	Cooling Temp Diff	14 °F	Latent Heat Gain	7065 Btuh
Winter Design Conditions		Indoor Summer Design RH	50 %	Total Heat Gain	43070 Btuh
Outdoor Winter Temp	33 °F	Coincident Wet Bulb Temp	76 °F		
Indoor Winter Temp	65 °F				
Heating Temp Diff	32 °F				

The heat loss/gain was calculated in accordance with ACCA Manual J? Y N

HVAC EQUIPMENT SELECTION (IRC M1401.3)

Heating Equipment

- Furnace Boiler Electric Heat
 Single Speed Multi Stage Modulating

Cooling Equipment

- Air Conditioner Heat Pump
 Air-to-Air Geothermal Open Loop Geothermal Closed Loop
 Single Speed Multi Stage Variable Speed

Model _____

Model 5TTR4048A1+5TEM4D06AC41++TDR

Output	0 Btuh	Sizing Value	0 Btuh
Supplemental Heat	0 Btuh	Sizing Limit	0 %
		Load Capacity	0 %

Sensible	32550 Btuh	Sizing Value	43070 Btuh
Latent	13950 Btuh	Sizing Limit	115.0 %
Total	46500 Btuh	Load: Capacity	108.0 %

Size Factor is within Manual S Size Limit? Y N

Size Factor is within Manual S Size Limit? Y N

HVAC DUCT DISTRIBUTION DESIGN (IRC M1601.1)

Design airflow	1550 cfm	Longest Supply Duct	752 ft	Duct Materials Used	
External Static Pressure (ESP)	0.50 in H2O	Longest Return Duct	73.0 ft	Trunk Duct. <input type="checkbox"/> Duct Board <input checked="" type="checkbox"/> Sheet Metal	
Component Pressure Loss (CPL)	0 in H2O	Total Effective Length (TEL)	825 ft	<input type="checkbox"/> Flex <input type="checkbox"/> Lined Sheet Metal <input type="checkbox"/> Other	
Available static pressure (ASP)	0.50 in H2O	Friction Rate	0.06 in/100ft	Branch Duct. <input type="checkbox"/> Duct Board <input checked="" type="checkbox"/> Sheet Metal	
ESP - CPL = ASP		(ASP x 100) / TEL = Friction Rate		<input type="checkbox"/> Flex <input type="checkbox"/> Lined Sheet Metal <input type="checkbox"/> Other	

Ducts are sized per Manual D? Y N

I declare the load calculation, equipment selection, and duct system design were rigorously performed based on the building plan listed above and understand the claims made on these forms may be subject to review and verification.


Contractor's printed name: _____

Contractor's signature: _____ Date: _____



SOFFIT DETAIL

2" X 4" 20 GA. METAL STUD 16" O.C., TYPICAL, SUSPENDED FROM EXISTING METAL PURLINS



THRU 2/11



CAFECO® BLAZE-SHIELD II

DESCRIPTION

CAFECO BLAZE-SHIELD II is an inorganic, Portland cement based Spray-Applied Fire Resistive Material (SFRM) designed to provide fire protection for structural steel and concrete in commercial construction. CAFECO BLAZE-SHIELD II is an excellent choice for concealed environments and can be applied directly to decks, steel beams, columns or concrete surfaces. Tested and classified by UL as "investigated for exterior use". CAFECO BLAZE-SHIELD II can be left exposed to weather conditions during the construction cycle.

In addition to fire resistance, CAFECO BLAZE-SHIELD II also provides thermal and acoustical benefits. As a thermal insulator, it is effective in reducing heat loss, particularly when applied to the underside of a roof deck. The R-value added by CAFECO BLAZE-SHIELD II may also allow a reduction in roof insulation. As an efficient sound absorbing material, it adds value to the fire protection application in areas where high noise levels are anticipated.

With its high recycled content, no pre-mixing, and reduced labor costs to install, CAFECO BLAZE-SHIELD II continues to be the most cost effective SFRM in the world.

PRODUCT ADVANTAGES

- UL "Investigated for exterior use"
- Inorganic Portland cement based formulation
- Highest recycled content for commercial SFRMs (67% pre-consumer)
- Easy application and fast clean up

FIRE TEST PERFORMANCE

CAFECO BLAZE-SHIELD II has been extensively tested for fire resistance and is rated for up to 4 hours for floor assemblies, beams, joists, columns, roof assemblies and walls and partitions.

- Classified by UL in accordance with ANSI/UL 263 (ASTM E119)
- Classified by UL in accordance with CAN/ULC-S101 (ASTM E119)

CAFECO BLAZE-SHIELD II has also been tested for surface burning characteristics in accordance with ASTM E84 and is rated Class A.

Flame Spread.....	0
Smoke Developed.....	0

CODE COMPLIANCES

CAFECO BLAZE-SHIELD II satisfies the requirements of the following

- IBC® - INTERNATIONAL BUILDING CODE® (ICC ESR-1649)
- NBC - National Building Code of Canada

MAJOR SPECIFICATIONS

CAFECO BLAZE-SHIELD II complies with the requirements of the following specifications:

- MasterSpec®, Section 078100 APPLIED FIREPROOFING (AIA)
- MasterFormat® 2014, Section 07 81 00 Applied Fireproofing (CSC, CSI)
- Unified Facilities Guide Specification, UFGS 07 81 00 Spray-Applied Fireproofing (USACE, NAVFAC, AFCEC, NASA)
- Master Construction Specifications, Number 07 80 10 Applied Fireproofing (VA)
- Code of Federal Regulations, Title 40 Protection of the Environment (EPA)
- PBS-P100 Facilities Standards for the Public Buildings Services (GSA)

Thermal Properties

Product	Conductivity(k)*	Resistance (R/inch)
BLAZE-SHIELD II	0.30 BTU in/hr ft ² °F @ 75°F (0.043 W/mK @ 24°C)	3.33

*When tested in accordance with ASTM C518

Acoustical Properties

Product	Thickness	Base	NRC Rating*
BLAZE-SHIELD II	1/2 inch (13 mm)	Deck & Beam	0.75
BLAZE-SHIELD II	1 inch (25 mm)	Solid	0.75

*When tested in accordance with ASTM C423

Physical Performances

Characteristic	ASTM Method	Standard Performance*	Tested Performance**
Density	E805	15 pcf (240 kg/m ³)	16 pcf (256 kg/m ³)
Combustibility	E136	Noncombustible	Noncombustible
Cohesion/Adhesion	E736	150 psf (7.2 kPa)	375 psf (18.0 kPa)
Deflection	E759	No Cracks or Delaminations	No Cracks or Delaminations
Bond Impact	E760	No Cracks or Delaminations	No Cracks or Delaminations
Compressive Strength	E761	750 psf (35.9 kPa)	2,380 psf (114 kPa)
Air Erosion Resistance	E859	Less than 0.025 g/ft ² (0.27 g/m ²)	0.000 g/ft ² (0.000 g/m ²)
Corrosion Resistance	E937	Does Not Promote Corrosion of Steel	Does Not Promote Corrosion of Steel
Fungal Resistance	G21	No Growth After 28 Days	Passed

* Standard performance based on MasterSpec®, Section 078100 APPLIED FIREPROOFING. Refer to UL design for density requirement.

** Values represent independent laboratory tests under controlled conditions.

CAFCO BLAZE-SHIELD II Guide Specification

SECTION 07105 - APPLIED FIREPROOFING

The following is an outline of language specifications. Complete specifications for Spray-Applied Fire-Resistive Materials are available on various media on request.
PART 1 - GENERAL

1.1 Work Included

1.1.1 Provide all labor, materials, equipment and services necessary for and material to the complete and proper installation of all sprayed fire protection and related work as shown on the drawings or where specified herein, and in accordance with all applicable requirements of the Contract Documents.

1.1.2 The material and installation shall conform to the applicable building code requirements of all authorities having jurisdiction.

1.2 Quality Assurance

1.2.1 Work shall be performed by a firm with expertise in the installation of fire protection or similar materials. This firm shall be recognized or otherwise approved by the spray-applied fire resistive material manufacturer.

1.2.2 Before proceeding with the fire protection work, approval of the proposed material thickness and density shall be obtained from the architect and other applicable authorities having jurisdiction.

1.3 Related Sections

1.3.1 SECTION 051200 - STRUCTURAL STEEL FRAMING

1.3.2 SECTION 053100 - STEEL DECKING

1.3.3 SECTION 071100 - THERMAL INSULATION

1.3.4 SECTION 076123 - INTUMESCENT FIREPROOFING

1.3.5 SECTION 076443 - JOINT FIRESTOPPING

1.4 References

- A. ASTM E84 - Surface Burning Characteristics of Building Materials
- B. ASTM E119 - Fire Tests of Building Construction and Materials
- C. ASTM E136 (Noncombustibility) Behavior of Materials in a Vertical Tube Furnace at 750°C
- D. ASTM E805 - Thickness and Density of Sprayed Fire-Resistive Materials Applied to Structural Members
- E. ASTM E736 - Cohesion/Adhesion of Sprayed Fire-Resistive Materials Applied to Structural Members
- F. ASTM E759 - Effect of Deflection of Sprayed Fire-Resistive Materials Applied to Structural Members
- G. ASTM E700 - Effect of Impact on Bonding of Sprayed Fire-Resistive Materials Applied to Structural Members
- H. ASTM E761 - Compressive Strength of Sprayed Fire-Resistive Materials Applied to Structural Members
- I. ASTM E859 - Air Erosion of Sprayed Fire-Resistive Materials Applied to Structural Members
- J. ASTM E937 - Corrosion of Steel by Sprayed Fire-Resistive Materials Applied to Structural Members
- K. CAN/ULC-S107 - Standard Methods of Fire Tests of Building Construction and Materials
- L. CAN/ULC-S102 - Steiner Tunnel Test
- M. CAN-S1M Standard Test Method for Determination of Noncombustibility in Building Materials
- *4.1 Underwriters Laboratories (UL) Fire Resistance Directory

1.4.2 Underwriters Laboratories of Canada (ULC) List of Equipment and Materials.

1.4.3 IBC® INTERNATIONAL BUILDING CODE® CHAPTER 17 STRUCTURAL TESTS AND SPECIAL INSPECTIONS Section 1704 Special Inspections.

1.4.4 AWSI Publication Technical Manual 12-A Standard Practice for the Testing and Inspection of Field Applied Spray-on Fire-Resistive Materials an Annotated Guide.

1.5 Submittals

1.5.1 Manufacturer's Data. Submit Manufacturer's specification, including certification as may be required to show material compliance with Contract Documents.

1.5.2 Test Data. Independent laboratory test results shall be submitted for all applicable performance criteria.

1.6 Delivery, Storage and Handling

1.6.1 Deliver materials to the project or manufacturer's unopened packages, fully identified as to trade name, type and other identifying data. Packaging shall bear the UL labels for fire hazard and fire resistance classifications.

1.6.2 Store materials above ground, in a dry location, protected from the weather. Damaged packages found unsuitable for use should be replaced and removed from the project.

1.7 Project Conditions

1.7.1 When the prevailing outdoor temperature at the building is less than 40°F (4°C), minimum substrate and ambient temperature of 40°F (4°C) shall be maintained prior to, during, and a minimum of 74 hours after application of spray-applied fire resistive material. If necessary for job progress, General Contractor shall provide enclosures and heat to maintain proper temperatures and humidity levels.

1.7.2 General Contractor shall provide ventilation to allow proper drying of the sprayed fire protection during and subsequent to its application.

1.7.3 Ventilation must not be less than 4 complete air exchanges per hour until the materials dry. When spraying in enclosed areas such as basements, stairwells, shafts and small rooms, additional air exchanges may be necessary.

1.8 Sequencing/Scheduling

1.8.1 All fire protection work on a floor shall be completed before proceeding to the next floor.

1.8.2 The Contractor shall cooperate in the coordination and scheduling of fire protection work to avoid delays in job progress.

PART 2 - PRODUCTS

2.1 Acceptable Manufacturers

2.1.1 The spray-applied fire resistive material shall be manufactured under the CAFCO® brand name, by authorized producers.

2.2 Materials

2.2.1 Materials shall be CAFCO BLAZE-SHIELD II (UL ULC designations: Type II) applied to conform to the drawings, specifications and following test criteria.

2.2.1.1 Deflection. When tested in accordance with ASTM E759, the material shall not crack or delaminate when the non-combusting topped galvanized deck to which it is applied is subjected to a one time vertical load that resulting in a downward deflection of 1/10th of the span.

2.2.1.2 Bond Impact. When tested in accordance with ASTM E768, the material shall not crack or delaminate from the concrete topped galvanized deck to which it is applied.

2.2.1.3 Cohesion/Adhesion (bond strength). When tested in accordance with ASTM E736, the material applied over uncoated or galvanized steel shall have an average bond strength of 150 psi (P 2+P).

2.2.1.4 Air Erosion. When tested in accordance with ASTM E859, the material shall not be subject to losses from the finished application greater than 0.025 grams per sq. ft. (0.27 grams per square meter).

2.2.1.5 Compressive Strength. When tested in accordance with ASTM E761, the material shall not deform more than 10 percent when subjected to a crushing force of 1750 psi (15.9 kPa).

2.2.1.6 Corrosion Resistance. When tested in accordance with ASTM E937, the material shall not promote corrosion of steel.

2.2.1.7 Noncombustibility. When tested in accordance with ASTM E136 or CAN-S1M, the material shall be noncombustible.

2.2.1.8 Surface Burning Characteristics. When tested in accordance with ASTM E84 or CAN/ULC-S102, the material shall exhibit the following surface burning characteristics:
Flame Spread ... 0
Smoke Developed 0

2.2.1.9 Density. When tested in accordance with ASTM E805, the material shall meet the minimum individual and average density values as listed in the appropriate UL ULC design or as required by the authority having jurisdiction.

2.2.2 The material shall have been tested and classified by Underwriters Laboratories (UL) or Underwriters Laboratories of Canada (ULC) in accordance with the procedures of UL 263 (ASTM E119) or CAN/ULC-S101.

2.2.3 Spray-applied fire resistive materials shall be applied at the appropriate minimum thickness and density to achieve the following ratings:

Fire assemblies ... hr
Roof assemblies ... hr
Beams ... hr
Girders ... hr
Columns ... hr
Joists ... hr

2.2.4 Potable water shall be used for the application of spray-applied fire resistive materials.

2.2.5 Spray-applied fire resistive materials shall contain no detectable asbestos. Material manufacturer shall provide certification of such upon request.

PART 3 - EXECUTION

3.1 Preparation

3.1.1 All surfaces to receive spray-applied fire resistive material shall be free of oil, grease, loose mill scale, dirt, paints, primers or other foreign materials which would impair satisfactory bonding to the surface. Manufacturer shall be contacted for procedures on handling primed/protected steel. Any cleaning of surfaces to receive sprayed fire protection shall be the responsibility of the General Contractor or Steel Erector, as outlined in the structural steel or steel deck section.

3.1.2 Clips, hangers, supports, sleeves and other attachments to the substrate are to be placed by others prior to the application of spray-applied fire resistive material.

3.1.3 The installation of duct piping, conduit or other suspended equipment shall not take place until the application of spray-applied fire resistive materials is complete in an area.

3.1.4 The spray-applied fire resistive material shall only be applied to steel deck which has been fabricated and erected in accordance with the criteria set by the Steel Deck Institute.

3.1.5 When roof traffic is anticipated, as in the case of periodic maintenance, roofing panels shall be installed as a walkway to distribute loads.

3.2 Application

3.2.1 Equipment mixing and application shall be in accordance with the manufacturer's written application instructions.

3.2.2 The application of spray-applied fire resistive material shall not commence until certification has been received by the General Contractor that surfaces to receive sprayed fire protection have been inspected by the applicator and are acceptable to receive spray-applied fire resistive material.

3.2.3 All unsuitable substrates must be identified and made known to the General Contractor and corrected prior to application of the spray-applied fire resistive material.

3.2.4 Spray-applied fire resistive material shall not be applied to steel floor decks prior to the completion of concrete work on that deck.

3.2.5 The application of spray-applied fire resistive material to the underside of roof deck shall not commence until the roofing is completely installed and tight, all penetrations are complete as mechanical units have been placed, and after construction roof traffic has ceased.

3.2.6 Proper temperature and ventilation shall be maintained as specified in 1.7.1, 1.7.2, and 1.7.2.1.

3.2.7 Provide masking, drop cloths or other suitable coverings to prevent overspray from coming in contact with surfaces not intended to be sprayed.

3.2.8 CAFCO BOND-SEAL (Type EB) adhesive shall be applied as per the appropriate UL/ULC fire resistance design and manufacturer's written recommendations.

3.3 Repairing and Cleaning

3.3.1 All patching of, and repair to spray-applied fire resistive material, due to damage by other trades, shall be performed under this section and paid for by the trade responsible for the damage.

3.3.2 After the completion of the work in this section, equipment shall be removed and all surfaces not to be sprayed shall be cleaned to the extent previously agreed to by the applicator and General Contractor.

3.4 Inspection and Testing

3.4.1 The spray-applied fire resistive material shall be tested for thickness and density in accordance with one of the following procedures:
ASTM E805 - Standard Test Method of Sprayed Fire-Resistive Material Applied to Structural Members
AWSI Publication Technical Manual 12-A Standard Practice for the Testing and Inspection of Field Applied Spray-on Fire-Resistive Materials, an Annotated Guide.
IBC® INTERNATIONAL BUILDING CODE® CHAPTER 17 STRUCTURAL TESTS AND SPECIAL INSPECTIONS Section 1704 Special Inspections.

Product Availability
Isolatek International Spray-Applied Fire Resistive Materials are available to train, recognized applicators around the world from strategically located production and distribution points in the U.S., Canada, Mexico, Europe and the Pacific Basin.



ISOLATEK INTERNATIONAL is registered with the AIA Continuing Education System (AIA/CES)



We support our customers with unsurpassed technical expertise and customer service, complemented by an extensive global network of experienced sales representatives and recognized applicators. For detailed product information or for the name of the sales representative in your area please contact us.

The performance data herein reflect our expectations based on tests conducted in accordance with recognized standard methods under controlled conditions. The applicator, general contractor, property owner and/or user MUST read, understand and follow the directions, specifications and/or recommendations set forth in Isolatek International's publications concerning use and application of these products, and should not rely merely on the information contained in this product data sheet. Isolatek International is not responsible for property damage, bodily injuries, consequential damages, or losses of any kind that arise from or are related to the applicator's, general contractor's or property owners' failure to follow the recommendations set forth in Isolatek International's publications. The sale of these products shall be subject to the Terms and Conditions set forth in the Company's invoices.

Isolatek International provides passive fireproofing materials under the CAFCO® trademark throughout the Americas and other markets and under the ISOLATEK® trademark throughout the world.



C-TDS-09/14

Brand

recreational areas. On such sections, local traffic often mixes with through traffic, and the density of unsignalized roadside access points is noticeably higher than in a purely rural area. Class III highways may also be longer sections passing through more spread-out recreational areas, also with increased roadside densities. Such sections are often accompanied by reduced speed limits that reflect the higher activity level.

Data Requirements

Exhibit 38 lists the data needed to evaluate the full range of performance measures for HCM two-lane highway section analyses and for the two-lane facility analysis method described later. To evaluate two-lane highways at a facility level, all of the HCM section-level data listed in Exhibit 38 are required, plus the intersection data for the two-lane facility.

Section LOS

Section-level LOS is an output of the HCM method; step-by-step calculation details are provided in HCM Chapter 15. The HCM section method starts by estimating the free-flow speed based on the geometry of the section and the characteristics of the traffic demands (percent heavy vehicles). The average travel speed is then estimated, followed by the percent time-spent-following. Finally, the LOS and capacity are estimated.

Exhibit 39 presents the automobile LOS criteria for two-lane highway sections for each highway class. The HCM does not define LOS at a facility level for two-lane highways.

Exhibit 38. Required data for two-lane highway section analysis.

Input Data (units)	For HCM Section	For Facility Method	Default Value
Hourly two-directional volume (veh/h)	•	•	Must be provided
Directional split (%)	•	•	60/40
Locations and lengths of passing lanes	•	•	Must be provided
Terrain type (level, rolling, mountainous)	•	•	Must be provided*
Highway class (I, II, III)	•	•	Must be provided
Lane width (ft)	•	•	12
Shoulder width (ft)	•	•	6
Percentage no-passing zones (%)	•	•	Level terrain: 20%, rolling: 40%, more extreme: 80%
Access point density, one side (accesses/mi)	•	•	Classes I and II: 8 per mile, Class III: 16 per mile
Base free-flow speed (mph)	•	•	Speed limit + 10 mph
Percentage heavy vehicles (%)	•	•	6**
Peak hour factor (decimal)	•	•	0.88
Section length (mi)	•	•	Must be provided
Intersection performance data		•	Must be provided


Notes: See HCM Chapter 15 for definitions of the required input data.

*Heavy vehicle impacts on traffic flow on long (≥ 1 mi) and steep ($>4\%$) grades with relatively few ($<5\%$) trucks can be significantly more severe than the default value for mountainous terrain would indicate. Consideration should be given to developing specific passenger car equivalent values for mountainous sections where these conditions are met.

**HCM Chapter 26 provides state-specific default values.

Design No. P819

Restrained Assembly Rating — 1, 1-1/2 or 2 Hr. (see items 3, 9 and 13)
 Unrestrained Assembly Rating — 1, 1-1/2 or 2 Hr. (see items 3, 9 and 13)
 Unrestrained Beam Rating — 1, 1-1/2 or 2 Hr. (see items 9 and 13)
 Load Restricted for Canadian Applications — See Guide BXUV7



1. Beam — W6x16 min size, or Steel Joist min size (See Item 9).
2. Roof Covering — Consisting of hot mopped or cold application bituminous materials compatible with the insulation(s) described herein which provide Class A, B or C coverings. See Roofing Materials and Systems Directory-Roof Covering Materials (TEVT).
- 2A. In lieu of Item 2, roof covering consisting of single-ply Roofing Membrane* — that is either ballasted, adhered or mechanically attached as permitted under the respective manufacturer's Classification. See Fire Resistance Directory-Roofing Membranes (CHCI).
- 2B. Metal Roof Deck Panels — (Not Shown) — In addition to or in lieu of Items 2 or 2A, the roof covering may consist of a mechanically fastened metal roof deck panel assembly. See Fire Resistance Directory — Metal Roof Deck Panels (CETW).
3. Roof Insulation-Foamed Plastic* — 36 by 48 in. (min size) polyisocyanurate foamed plastic insulation boards applied in one or more layers. See Item 9 for min thicknesses with or without the use of gypsum wallboard (Item 13). No limit on max overall thickness. Boards to be installed with end joints staggered a min of 6 in. in adjacent rows. When applied in more than one layer, each layer to be offset in both directions from layer below a min of 6 in. in order to lap all joints.
 - ATLAS ROOFING CORP —ACFoam II, ACFoam III, ACFoam IV
 - CARLISLE SYNTEC INCORPORATED —Types HP, HP-H, HP-N, HP-W.
 - THE DOW CHEMICAL CO —Types Hy-Therm AP, Hy-Therm Tapered.
 - FIRESTONE BUILDING PRODUCTS CO L L C — "ISO 95+GL", "ISO 300", "ISO 95+CAN"
 - GAF MATERIALS CORP —Isotherm R.
 - HUNTER PANELS —H Shield.
 - JOHNS MANVILLE — ENRGY 3, ISO-1, PSI 25.
 - LOADMASTER SYSTEMS INC —Loadmaster Polyisocyanurate Insulation.
 - RMAX OPERATING L L C —Multi-Max-3, Multi-Max FA-3, Ultra-Max, Tapered Therमारoof-3, Tapered Therमारoof FA-3, Ultra-Max Tapered.
 - DOW ROOFING SYSTEMS L L C —"Dow Termico Polyisocyanurate Insulation", "Dow Termico ISO 3000 Insulation", "Dow Termico ISO HP-FR"
 - GENFLEX ROOFING SYSTEMS L L C — "GenFlex ISO"
- 3A. Roof Insulation — Building Units* — (Not Shown) — As an alternate to Item 3, 36 by 48 in. (min size) polyisocyanurate foamed plastic insulation boards, faced on underside (or both sides) with mineral and fiber boards. Min thickness of the polyisocyanurate core is as is stated for Item 3, Roof Insulation. No limit on max overall thickness. Boards to be installed with end joints staggered a min of 6 in. in adjacent rows.
 - FIRESTONE BUILDING PRODUCTS CO L L C —ISO 95+ Composite.
 - JOHNS MANVILLE —Fesco-Foam.
- 3B. Building Units* — (Not Shown) As an alternate to Item 3, polyisocyanurate foamed plastic insulation boards, nom 48 by 48 or 96 in., faced on the top surface with oriented strand board. Min thickness of the polyisocyanurate core is as is stated for Item 3, Roof Insulation. No limit on max overall thickness. Boards to be installed with end joints staggered a min of 6 in. in adjacent rows.
 - ATLAS ROOFING CORP —ACFoam NailBase Insulation, Vented-R.
 - FIRESTONE BUILDING PRODUCTS CO L L C —Hailgard.
 - HUNTER PANELS — H Shield
 - JOHNS MANVILLE —Nailboard.
- 3C. Building Units* — As an alternate to Item 3, polyisocyanurate foamed plastic insulation boards faced on the underside with wood fiber board. Min thickness of the polyisocyanurate core is as is stated for Item 3, Roof Insulation. No limit on max overall thickness. Boards to be installed with end joints staggered a min of 6 in. in adjacent rows.
 - FIRESTONE BUILDING PRODUCTS CO L L C — "ISO 95+ Wood Fiberboard Composite".
 - JOHNS MANVILLE —ENRGY 2 Plus.
- 3D. Building Units* — Not Shown — As an alternate to Item 3, composite polyisocyanurate foamed plastic insulation board with an adhered nailing surface, nom 48 by 48 or 96 in. may be used with the following limitations. These composite building units have ventilation slots internal to the panels. The thickness of the panel depends upon the thinnest portion of the polyisocyanurate insulation. The following dimensions apply to the polyisocyanurate insulation, min thickness is as stated in Item 3. There is no limit on the max insulation thickness.
 - GAF MATERIALS CORP —Type INSUL-AIR.
 - JOHNS MANVILLE —Type ISO-VENT
- 3E. Building Units* — As an alternate to Item 3, polyisocyanurate foamed plastic insulation boards, nom 48 by 48 or 96 in., faced on

FIRE RESISTANCE DIRECTORY ISOLATEK

the top surface with gypsum board. Min thickness of the polyisocyanurate core is as is stated for Item 3, Roof Insulation. No limit on overall thickness. Boards to be installed with end joints staggered a min of 6 in. in adjacent rows.

JOHNS MANVILLE—ENRGY 2 gypsum Composite.

- 3F. Building Units* — As an alternate to Item 3, polyisocyanurate foamed plastic insulation boards, nom 48 by 48 by 96 in., faced on the top surface with oriented strand board. Min thickness of the polyisocyanurate core is as stated in Item 3, Roof Insulation. No limit on overall thickness. Boards to be installed with end joints staggered a min of 6 in. in adjacent rows.
- 4. Vapor Retarder-Sheathing Material* — (Optional — Not shown) — Vinyl film or paper scrim vapor barrier, applied to steel roof deck with adhesive (Item 5), asphalt (Item 6) or laid loosely, overlapped approximately 2 in. on adjacent sheets. See Sheathing Material (CHIZ) category for names of manufacturers.
- 5. Adhesive* — (Optional) — The vapor retarder or the first layer of roof insulation may be secured with adhesive to the steel crest surfaces. Also used to attach the first layer of insulation to vapor retarder and each additional layer of insulation. Applied in 1/2 in wide ribbons 6 in. OC at 0.4 gal/100 sq ft. See Adhesives (GYWR) category for name of manufacturers.
- 5A. Adhesive*—(Optional) — (Bearing the UL Classification Marking for Roof Systems (TGFU)) - The vapor retarder, the gypsum wallboard or the first layer of roof insulation may be secured with adhesive to the steel crest surfaces. Also used to attach the vapor retarder to gypsum wallboard, the first layer of insulation to vapor retarder or gypsum wallboard and each additional layer of insulation. Applied at a max rate of 19.8 g/ft². When FAST 100 adhesive is used, additional Spray-Applied Fire Resistance Materials* (CHPX) is required on the deck for the 1-1/2 and 2 hr Unrestrained Assembly Ratings. The thickness specified for the deck shall be increased by 1/16 in. for 1-1/2 hr Unrestrained Assembly Rating and 1/4 in. for 2 hr Unrestrained Assembly Rating.

CARLISLE SYNTEC INCORPORATED — FAST 100

- 6. Asphalt or Coal Tar Pitch* — (Optional — Not shown) — The vapor retarder or the first layer of roof insulation may be secured with asphalt or coal tar pitch to the steel crest surfaces at a max rate of 15 lbs/100 sq ft. Also used to attach the first layer of insulation to vapor retarder and each additional layer of roof insulation, applied at a max rate of 25 lbs/100 sq ft.
- 7 Mechanical Fasteners — (Optional — Not shown) — Mechanical screw-type fastener with metal or plastic washer designed for the purpose may be used to attach one or more layers of insulation to steel roof deck.
- 8. Steel Roof Deck — (Unclassified) — Min 1-1/2 in. deep and 30 in. wide galv or painted fluted steel deck. When unclassified painted deck is used, Item 8A must be used. Flutes 6 in. OC with crest width ranging from 3-5/8 to 5-1/16 in. Min gauge is 22 MSG. Ends overlapped at supports min 1-1/2 in. and welded to supports at deck laps at a max of 12 in. OC between sides of units. Side laps of adjacent units welded, button-punched or secured together with No. 12 by 3/4 in. long self-drilling, self-tapping steel screws spaced a max of 36 in. OC or
Classified Steel Floor Form Units* — Noncomposite, 1-1/2 or 3 in. deep galv units, min gauge is 22 MSG. Ends overlapped at supports min 1-1/2 in. and welded to supports at deck laps at a max of 12 in. OC between sides of units. Side laps of adjacent units welded, button-punched or secured together with No. 12 by 3/4 in. long self-drilling, self-tapping steel screws spaced a max of 36 in. OC.

ASC STEEL DECK, DIV OF ASC PROFILES

INC —24, 30, or 36 in. wide, Types DGB Hi-Form, B Hi-Form, DGB, B, DGN Hi-Form, N Hi-Form, DGN, and N All units may be galvanized or Prime Shield™.

CANAM STEEL CORP — Type P-3606, P-3615, P-2436, and P-2404, P-2403, and P-2438 noncomposite.

CONSOLIDATED SYSTEMS INC —Types B, BI, F, N, NI. Units may be phos/ptd.

LOADMASTER SYSTEMS INC —Types PS, SS-300. Type PS may be ptd/ptd.

MARLYN STEEL DECKS INC — Types B, F, N, NV

NEW MILLENNIUM BUILDING SYSTEMS L L C — Types B, FD, and N. Units may be phos/painted or galvanized.

VERCO DECKING INC - A NUCOR CO — Types PLB, B, PLN or N Formlok. Units may be phos/ptd. Types PLB, HSB, PLN or N. Units may be ptd/ptd.

VULCRAFT, DIV OF NUCOR CORP —Types 1.5B, 1.5BI, 1.5F, 3N, 3NI. Units may be ptd/ptd.

WHEELING-PITTSBURGH STEEL CORE, DIV

OF WHEELING CORRUGATING CO —Types BW, F, High Strength B, High Strength BW or N. Types BW, F, High Strength B, High Strength BW, N units may be ptd/ptd.

CMC JOIST & DECK - MANUFACTURERS

OF UNITED STEEL DECK PRODUCTS — Types B, N Units may be phos./ptd or ptd/ptd.

- 8A. Metal Lath — Not shown — Required on unclassified painted steel roof deck. Rib lath, galv or painted, min 2.5 lb/sq yd, with ribs facing down, fastened to deck using No. 8 by 1/2 in. wafer head self-drilling, self-tapping coated steel screws spaced max 15 in. OC in both directions with lath edges overlapped approx 3 in.
- 9 Spray-Applied Fire Resistive Materials* — Applied to steel surfaces by spraying with water, in one or more coats, to final thicknesses shown in the table below. Steel surfaces should be free of dirt, oil and scale. Use of adhesive is required on the steel roof deck. Tamping is optional. Min avg density of 13 pcf, and min ind density of 11 pcf for Types DC/F and II. Min avg and min ind densities of 22 and 19 pcf, respectively, for Type HP. For method of density determination, refer to Design Information Section, Sprayed Material. The protection material on steel deck shall cover screw tips by min 1/2 in.

Restrained Assembly Rating Hr	Un restrained Assembly Rating Hr	Un restrained Beam Rating Hr	Min Insulation Thkns In.	Wallboard (Item No. 13) Required	Deck#	W6x16 Beam	Protection Thkns In.	10K1 Joist	12K3 Joist	10K1 Joist (I)
1	1	1	1	Yes	1/2	5/8	1-1/8	1-1/16	1-1/8	1-1/8
1	1	1	2	Yes	1/2	5/8	1-1/8	1-1/16	1-1/8	1-1/8
1	1	1	0	Yes	5/8	5/8	1-1/8	1-1/16	1-1/8	1-1/8
1	1	1	3	No	13/16	5/8	1-1/8	1-1/16	1-1/8	1-1/8
1	1	1	2	No	15/16	5/8	1-1/8	1-1/16	1-1/8	1-1/8
1	1	1	1	No	1-1/4	5/8	1-1/8	1-1/16	1-1/8	1-1/8
1	1	1	0	No	2-1/16	5/8	1-1/8	1-1/16	1-1/8	1-1/8
1-1/2	1	1	2	Yes	13/16	13/16	1-9/16	1-9/16	1-9/16	1-1/8
1-1/2	1	1	1	Yes	7/8	13/16	1-9/16	1-9/16	1-9/16	1-1/8
1-1/2	1	1	3	No	1-3/8	13/16	1-9/16	1-9/16	1-9/16	1-1/8
1-1/2	1	1	2	No	1-3/4	13/16	1-9/16	1-9/16	1-9/16	1-1/8
1 1/2	1-1/2	1-1/2	2	Yes	13/16	13/16	1-9/16	1-9/16	1-9/16	1-1/8
1 1/2	1-1/2	1-1/2	1	Yes	7/8	13/16	1-9/16	1-9/16	1-9/16	1-1/8
1-1/2	1-1/2	1-1/2	0	Yes	1	13/16	1-9/16	1-9/16	1-9/16	1-1/8
1-1/2	1-1/2	1-1/2	3	No	1-3/8	13/16	1-9/16	1-9/16	1-9/16	1-1/8
1-1/2	1-1/2	1-1/2	2	No	1-3/4	13/16	1-9/16	1-9/16	1-9/16	1-1/8
1-1/2	1-1/2	1-1/2	0	No	2-5/8	13/16	1-9/16	1-9/16	1-9/16	1-1/8
2	1	1	2	Yes	1-3/16	1	1-5/8	1-5/8	1-5/8	1-3/8
2	1	1	1	Yes	1 5/8	1	1-5/8	1-5/8	1-5/8	1-3/8
2	1	1	3	No	2-1/8	1	1-5/8	1-5/8	1-5/8	1-3/8
2	1	1	2	No	2-5/16	1	1-5/8	1-5/8	1-5/8	1-3/8
2	2	2	2	Yes	1-3/16	1	1-11/16	1-11/16	1-11/16	1-9/16
2	2	2	1	Yes	1-3/8	1	1-11/16	1-11/16	1-11/16	1-9/16
2	2	2	0	Yes	1-9/16	1	1-11/16	1-11/16	1-11/16	1-9/16

FIRE RESISTANCE DIRECTORY ISOLATEK

FIRE RESISTANCE RATINGS - ANSI/UL 263 (BXUV)

Restrained Assembly Rating Hr	Un restrained Assembly Rating Hr	Un restrained Beam Rating Hr	Min Insulation Thkns In.	Wallboard (Item No. 13) Required	Deck#	W6x16 Beam	Protection Thkns In.		
							10K1 Joist	12K3 Joist	10K1 Joist (1)
2	2	2	3	No	2-1/8	1	1-11/16	1-11/16	1-9/16
2	2	2	2	No	2-5/16	1	1-11/16	1-11/16	1-9/16
2	2	2	0	No	3-1/4	1	1-11/16	1-11/16	1-9/16

#The required minimum thickness of Spray-Applied Fire Resistive Materials on the steel deck is increased by 1/16 in. for 1-1/2 hr Unrestrained Assembly Rating and 1/4 in. for 2 hr Unrestrained Assembly Rating when Item 5A is used.

1 = Thickness of 10K1 joists when spacing is 4 ft. or less OC.

NR = No Rating

ISOLATEK INTERNATIONAL — Type D-C/F, HP or II, Type EBS or Type X adhesive/sealer

9A. Spray-Applied Fire Resistive Material* — (Not shown — As an alternate to Item 9) Applied by mixing with water and spraying or troweling in one or more coats to a final thickness as shown in the table below, to steel surfaces which must be clean and free of dirt, loose scale and oil. Thickness beneath floor units measured to face of lath (Item 15). Min avg density of 38 pcf with min ind value of 35 pcf for Type 800. Min avg density of 44 pcf with min ind value of 40 pcf for Type M-II. Min avg density of 44 pcf with min ind value of 42 pcf for Type TG. For method of density determination, refer to Design Information Section.

Restrained Assembly Rating Hr	Unrestrained Assembly Rating Hr	Unrestrained Beam Rating Hr	Min Insulation Thkns In.	Wallboard (Item No. 13) Required	Deck#	W6x16 Beam	Protection Thkns In.		
							10K1 Joist	12K3 Joist	10K1 Joist (1)
1	1	1	1	Yes	9/16	11/16	NR	NR	1-1/16
1	1	1	2	Yes	9/16	11/16	NR	NR	1-1/16
1	1	1	0	Yes	11/16	11/16	NR	NR	1-1/16
1	1	1	3	No	13/16	11/16	NR	NR	1-1/16
1	1	1	2	No	15/16	11/16	NR	NR	1-1/16
1	1	1	1	No	1-1/4	11/16	NR	NR	1-1/16
1	1	1	0	No	2-1/16	11/16	NR	NR	1-1/16
1-1/2	1	1	2	No	13/16	13/16	1-9/16	1-9/16	1-9/16
1-1/2	1	1	1	Yes	7/8	13/16	1-9/16	1-9/16	1-9/16
1-1/2	1	1	3	No	1-3/8	13/16	1-9/16	1-9/16	1-9/16
1-1/2	1	1	2	No	1-3/4	13/16	1-9/16	1-9/16	1-9/16
1-1/2	1-1/2	1-1/2	2	Yes	13/16	13/16	1-9/16	1-9/16	1-9/16
1-1/2	1-1/2	1-1/2	1	Yes	7/8	13/16	1-9/16	1-9/16	1-9/16
1-1/2	1-1/2	1-1/2	0	Yes	1	13/16	1-9/16	1-9/16	1-9/16
1-1/2	1-1/2	1-1/2	3	No	1-3/8	13/16	1-9/16	1-9/16	1-9/16
1-1/2	1-1/2	1-1/2	2	No	1-3/4	13/16	1-9/16	1-9/16	1-9/16
1-1/2	1-1/2	1-1/2	0	No	2-5/8	13/16	1-9/16	1-9/16	1-9/16
2	1	1	2	Yes	1-3/16	1	1-5/8	1-5/8	1-5/8
2	1	1	1	Yes	1-3/8	1	1-5/8	1-5/8	1-5/8
2	1	1	3	No	2-1/8	1	1-5/8	1-5/8	1-5/8
2	1	1	2	No	2-5/16	1	1-5/8	1-5/8	1-5/8
2	2	2	2	Yes	1-3/16	1	1-11/16	1-11/16	1-11/16
2	2	2	1	Yes	1-3/8	1	1-11/16	1-11/16	1-11/16
2	2	2	0	Yes	1-9/16	1	1-11/16	1-11/16	1-11/16
2	2	2	3	No	2-1/8	1	1-11/16	1-11/16	1-11/16
2	2	2	2	No	2-5/16	1	1-11/16	1-11/16	1-11/16
2	2	2	0	No	3-1/4	1	1-11/16	1-11/16	1-11/16

#The required minimum thickness of Spray-Applied Fire Resistive Materials on the steel deck is increased by 1/16 in. for 1-1/2 hr Unrestrained Assembly Rating and 1/4 in. for 2 hr Unrestrained Assembly Rating when Item 5A is used.

NR = No Rating

ISOLATEK INTERNATIONAL — Types 800, M-II or TG investigated for exterior use.

- Glass Fiber Mesh — (Optional) — Not Shown — Min 3/32 in. square mesh, coated fiberglass scrim fabric, weighing a min of 1.9 oz/sq yd shall be attached to one side of each joist web member. The method of attachment must be sufficient to hold the mesh and fire protection material during application and curing of the material. An acceptable method of attaching the mesh is by embedding the mesh in min 1/4 in. long beads of hot melted glue. The beads of glue shall be spaced min 12 in. OC along the top chord of the bar joists. Another method of attachment is the use of 1-1/4 in. long, 1/2 in. wide hairpin clips formed from 0.064 in. diameter steel wire, alternating from top to bottom of the joist web member.
 - Metal Lath — (Optional) — As an alternate to Item 10 — Metal lath used to facilitate the spray application of the Spray-Applied Fire Resistive Material to the steel joists. Diamond mesh, 3/8 in. expanded steel, min 1.7 lb/sq yd fastened to one side of joists using No 18 SWG steel wire, located at midheight of every other member or 18 in. OC whichever is less. Both sides of lath must be completely coated with Spray-Applied Fire Resistive Material, but with no min thickness requirements.
 - Bridging — (Not shown) — Min 1-1/4 by 1-1/4 by 1/8 in. thick steel angles welded to top and bottom chords of each joist. Number and spacing of bridging angles per Steel Joist Institute specification. Bridging coated with the same thickness of Spray-Applied Fire Resistive Materials (Item 9) as the joist.
 - Gypsum Board — (Not shown — Classified or Unclassified) — May be used to obtain various Restrained and Unrestrained Assembly Ratings as described in (Item 9). Supplied in sheets nom 2 by 4 ft to 4 by 12 ft, by nom 5/8 in. thick. Min weight 2.2 psf Applied perpendicular to steel roof deck direction with adhesive (Item 5), hot asphalt (Item 6) or laid loosely. End joints to occur over crests of steel roof and to be staggered 2 ft in adjacent rows. See Gypsum Board (CKNX) category for names of manufacturers.
 - Building Units* — (Optional — Not shown) — Nominal 12 by 18 in. or 18 by 24 in. flat or tapered cellular glass blocks or 24 by 48 in. flat or tapered cellular glass boards, applied over the roof insulation (Item 3 or 3A) with asphalt (or coal tar pitch) joints to be offset from joints of roof insulation.
- PITTSBURGH CORNING CORP
- Metal Lath — (For use on steel roof deck with Item 9A) 3/8 in. diamond mesh, min 2.5 lbs per sq yd painted or galv expanded steel. Fastened to steel roof deck with ribs facing down using, No. 8 by 1/2 in. wafer head self-drilling, self-tapping, coated steel screws spaced max 15 in OC in both directions for 1 and 1-1/2 hr ratings. Spaced a max 12 in. OC in both directions for 2 hr ratings. Lath edges overlapped approx 3 in.

*Bearing the UL Classification Mark