

# Inspection Checklist for Permit #000055556

Notes:

| <b>Order</b> | <b>Category</b> | <b>Inspection</b>   | <b>Requirements</b> |
|--------------|-----------------|---|---------------------|
| 1            | Swimming Pool   | <b>Pool Steel and Ground</b><br><i>Reviews steel reinforcing and equipotential bonding grid. Ref: NEC 680.26, FBC 454.1.10.4.2</i>        |                     |
| 2            | Engineering     | <b>Setbacks</b><br><i>Confirms buildings, structures, and improvements are within required property setbacks. Columbia County LDR 4.1</i> |                     |
| 3            | Swimming Pool   | <b>Pool Footer</b><br><i>Inspects reinforcing and bonding in pool footers. Ref: FBC 454.1.6</i>   |                     |
| 4            | Swimming Pool   | <b>Pool Deck/Piping Pressure</b><br><i>Verifies deck drains and pool piping under pressure. Ref: FBC 454.1.6.5.1</i>                      |                     |
| 5            | Electrical      | <b>Pool/Deck Bonding</b><br><i>Ensures all metallic pool parts and decking are bonded together. Ref: NEC Art. 680.26</i>                  |                     |
| 6            | Swimming Pool   | <b>Pool Safety and Final</b><br><i>Ensures barriers, alarms, and final system safety. Ref: FBC 454.1.3.1.9</i>                            |                     |