



Application For Construction Permit
Onsite Sewage Treatment and Disposal System (OSTDS)

E-MAILED
Jimmy 8/17/26

Application for:

- ☐ New System
☐ Repair

- modification*
☒ Existing System
☐ Abandonment

- ☐ Temporary
☐ Other

Permit No. 26-5682
Date Paid: 7/22/26
Fee Paid: 285.88
Receipt #: 2316284

Subtype:

- ☐ Aerobic Treatment Unit ☐ Holding Tank ☐ Other (describe):
☐ Non-innovative Performance-based treatment system (PBTS) ☐ Innovative PBTS ☐ Innovative, Non PBTS

Does the system include nitrogen treatment?

- ☐ Enhanced Nutrient-Reducing OSTDS ☐ In-ground Nitrogen Reducing Biofilter

Applicant: Stars & Stripes Mobile Home Sales, Inc Email: keenpermitting@gmail.com
Agent: Keen Permitting LLC Telephone: 352-356-1333

Mailing Address: 474 NE 628th St Old Town 32680

To be completed by applicant or applicant's authorized agent. Systems must be constructed by a person licensed pursuant to 489.105(3)(m) or 489.552, Florida Statutes. It's the applicant's responsibility to provide documentation of the date the lot was first recorded in its present form or platted (MM/DD/YY) if requesting consideration of statutory grandfather provisions.

Property Information

Lot: 13 Block: A Subdivision: West Lake City Hills Date Lot Recorded:
Property Id #: 34-3s-16-02507-000 Zoning: I/M Or Equivalent ☐ Yes ☒ No Property Size: 0.93 Acres

Water Supply: Private ☒ Public Not Limited Use ☐ ≤ 2000 gpd ☐ > 2000 gpd Limited Use Public ☐ ≤ 2000 gpd ☐ > 2000 gpd

Is Sewer Available As Per 381.0065, F.S.? ☐ Yes ☒ No

Property Address: 282 NW Divider Ter Lake City 32060 32055

Directions To Property: GPS is accurate

Building Information

☒ Residential ☐ Commercial

Unit No.	Type of Establishment	No. of Occupants	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table I, Chapter 62-6, FAC
1 New	SFR-MH		4	1352	
2 old	SFR-MH		2	1456	
3					
4					

☐ Floor/Equipment Drains ☐ Other (Specify):

SIGNATURE: James Keen 25-2064 DATE: 7/22/2026



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM (OSTDS)
CONSTRUCTION PERMIT

Permit No. 12-SC-4121291
Application No. AP2316684
Date Paid: 07/27/2026
Fee Paid: 55
Receipt No. 12-PID-8077643
Document No. PR2395203
Facility ID. _____

Type ☐ New System ☒ Existing System Modification ☐ Repair ☐ Abandonment ☐ Temporary
Subtype ☐ Aerobic Treatment Unit ☐ Non-Innovative PBTS ☐ Innovative PBTS ☐ Innovative Non PBTS
☐ Holding Tank ☐ Other (describe) _____

Applicant: STARS**26-0602 STRIPES MH SALES LLC

Property Address: 282 NW DIVIDER City Lake City State FL Zip 32055

Lot: 13 Block: A Subdivision: West Lake City Hills

Property ID No. 02507-000 [Section, Township, Range, Parcel Number, or Tax ID No.]

The system must be constructed in accordance with specifications and standards of Section 381.0065, F.S., and Chapter 62-6, F.A.C. Department approval of system does not guarantee satisfactory performance for any specific period of time. Any change in material facts, which served as a basis for issuance of this permit, require the applicant to amend the permit application. Such amendments may result in voiding this permit. Issuance of this permit does not exempt the applicant from compliance with other federal, state, or local permitting required for development of this property.

SYSTEM DESIGN AND SPECIFICATIONS

Tank

1050 Gallons / GPD capacity ☒ Septic Tank ☐ Aerobic Treatment Unit ☒ Multi-chambered ☐ In series
Gallons / GPD capacity N/A ☐ Multi-chambered ☐ In series
Gallons Grease Interceptor capacity _____
Gallons Dosing Tank capacity _____ gallons at _____ doses per 24 hours doses per 24 hours _____

Drainfield

500 Square feet Drainfield _____ system
Square feet N/A _____ system
System type ☒ Standard ☐ Filled ☐ Mound ☐ _____
Configuration ☒ Trench ☐ Bed ☐ _____
Location of benchmark/reference point Nail with red ribbon in hickory tree near site
Elevation of proposed system site 29.5 ☒ inches ☐ feet ☐ above ☒ below benchmark/reference point
Bottom of drainfield to be 57.5 ☒ inches ☐ feet ☐ above ☒ below benchmark/reference point
Fill required 0 inches Excavation required _____ inches

Other

The system is sized for 4 bedrooms with a maximum occupancy of 8 persons (2 per bedroom), for a total estimated flow of 400 gpd. System to go in same footprint as original. If system is moved from original location, it will require a new system permit and will need to be a nitrogen reducing system.

Specifications by (Joshua) Kameron Keen CEHP
Printed Name Title Signature


Approved by Sean P Havens Environmental Specialist II Florida Department of Health in Columbia County
Printed Name Title Office Signature

Date issued 08/04/2026 Expiration date 02/04/2028

26-D602

Stars & Stripes
282 NW Divider Ter
Lake City

g. d. deer
85-2064
7-22-20



approved

Columbia

2/4/26