



# CAL-TECH TESTING, INC.

ENGINEERING & TESTING LABORATORY  
 P.O. Box 1625, Lake City, FL 32056-1625  
 2907 Spring Glen Road • Jacksonville, FL 32207

Lake City • (386) 755-3633  
 Fax • (386) 752-5456

Jacksonville • (904) 381-8901  
 Fax • (904) 381-8902

JOB NO.: 24-471  
 DATE TESTED: 9-17-24

## REPORT OF IN-PLACE DENSITY TEST

ASTM METHOD:  (D-2922) Nuclear  (D-2937) Drive Cylinder  Other

PROJECT: 555 SW Rolling Meadows

CLIENT: Crown Concepts

GENERAL CONTRACTOR: SAC EARTHWORK CONTRACTOR: SAC

SOIL USE (SEE NOTE): 1 SPECIFICATION REQUIREMENTS: 95

TECHNICIAN: JG/ken

MODIFIED (ASTM D-1557):  STANDARD (ASTM D-698):

TEST NO.	TEST LOCATION	TEST:		PROCTOR NO.	WET DENS. LBS. CU. FT.	DRY DENS. LBS. CU. FT.	MOIST PERCENT	% MAX. DENS.
		DEPTH	ELEV. LIFT					
	Middle of pad			1	112.8	108.7	3.9	103
	15 ft South of middle			1	111.1	105.9	4.4	101
	15 ft North of middle			1	108.9	103.5	5.2	98

REMARKS:

PROCTOR NO.	SOIL DESCRIPTION	PROCTOR VALUE	OPT. MOIST.
1		105.2	

NOTE: 1. Building Fill 2. Trench Backfill 3. Base Course 4. Subbase/Stabilized Subgrade 5. Embankment 6. Subgrade/Natural Soil 7. Other  
 The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with generally accepted methods and standards. Since material conditions can vary between test location and change with time, sound judgement should be exercised with regard to the use and interpretation of the data.

WA  
 DE  
 ONSTR  
 TRES  
 L BE P  
 TO TH  
 EXTENT O