

Project Information

For: Hunter and Ashley Faulkner
 Fort White, FL 32038

Notes:

Design Information

Weather: Gainesville, FL, US

Winter Design Conditions

Outside db 33 °F
 Inside db 70 °F
 Design TD 37 °F

Ventilation Method ASHRAE 62.2-2019

Heating Summary

Structure 21515 Btuh
 Ducts (R-6.0) 4119 Btuh
 Central vent (102 cfm) 4099 Btuh
 Outside air Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 29733 Btuh

Infiltration

Method Simplified
 Construction quality Average
 Fireplaces 0

	Heating	Cooling
Area (ft ²)	2400	2400
Volume (ft ³)	21600	21600
Air changes/hour	0.32	0.16
Equiv. AVF (cfm)	115	58

Heating Equipment Summary

Make ECOTEMP
 Trade
 Model W5H5S36*K*AAA*
 AHRI ref 214101862

Efficiency 7.5 HSPF2
 Heating input
 Heating output 35600 Btuh @ 47°F
 Temperature rise 28 °F
 Actual air flow 1167 cfm
 Air flow factor 0.046 cfm/Btuh
 Static pressure 0.53 in H2O
 Space thermostat
 Capacity balance point = 0 °F

Backup:
 Input = 9 kW, Output = 30361 Btuh, 100 AFUE

Summer Design Conditions

Outside db 92 °F
 Inside db 75 °F
 Design TD 17 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 43 gr/lb

Sensible Cooling Equipment Load Sizing

Structure 19136 Btuh
 Ducts (R-6.0) 2630 Btuh
 Central vent (102 cfm) 1944 Btuh
 Outside air Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 0.97
 Equipment sensible load 23093 Btuh

Latent Cooling Equipment Load Sizing

Structure 2495 Btuh
 Ducts 1318 Btuh
 Central vent (102 cfm) 3002 Btuh
 Outside air
 Equipment latent load 6815 Btuh

Equipment Total Load (Sen+Lat) 29908 Btuh
 Req. total capacity at 0.80 SHR 2.4 ton

Cooling Equipment Summary

Make ECOTEMP
 Trade
 Cond W5H5S36*K*AAA*
 Coil WCHL365*B*
 AHRI ref 214101862

Efficiency 12.0 EER2, 14.5 SEER2
 Sensible cooling 28000 Btuh
 Latent cooling 7000 Btuh
 Total cooling 35000 Btuh
 Actual air flow 1167 cfm
 Air flow factor 0.054 cfm/Btuh
 Static pressure 0.53 in H2O
 Load sensible heat ratio 0.78

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Project Information

For: Hunter and Ashley Faulkner
Fort White, FL 32038

Cooling Equipment

Design Conditions

Outdoor design DB:	92.4°F	Sensible gain:	23710 Btuh	Entering coil DB:	77.2°F
Outdoor design WB:	75.8°F	Latent gain:	6815 Btuh	Entering coil WB:	64.4°F
Indoor design DB:	75.0°F	Total gain:	30525 Btuh		
Indoor RH:	50%	Estimated airflow:	1167 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	ECOTEMP	Model:	W5H5S36*K*AAA*+WCHL365*B*		
Actual airflow:	1167 cfm				
Sensible capacity:	28000 Btuh		118% of load		
Latent capacity:	7000 Btuh		103% of load		
Total capacity:	35000 Btuh		115% of load	SHR:	80%

Heating Equipment

Design Conditions

Outdoor design DB:	33.3°F	Heat loss:	29733 Btuh	Entering coil DB:	65.8°F
Indoor design DB:	70.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	ECOTEMP	Model:	W5H5S36*K*AAA*+WCHL365*B*		
Actual airflow:	1167 cfm				
Output capacity:	35600 Btuh		120% of load	Capacity balance:	0 °F
Supplemental heat required:	0 Btuh			Economic balance:	0 °F

Backup equipment type:	Elec strip				
Manufacturer:		Model:			
Actual airflow:	1167 cfm				
Output capacity:	8.9 kW	102% of load	Temp. rise:	0 °F	

Meets all requirements of ACCA Manual S.

Project Information

For: Hunter and Ashley Faulkner
 Fort White, FL 32038

	Heating	Cooling
External static pressure	0.53 in H2O	0.53 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.53 in H2O	0.53 in H2O
Supply / return available pressure	0.391 / 0.139 in H2O	0.391 / 0.139 in H2O
Lowest friction rate	0.232 in/100ft	0.232 in/100ft
Actual air flow	1167 cfm	1167 cfm
Total effective length (TEL)	229 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
1/2 Bath	c 128	2	7	0.232	4.0	0x0	VIFx	28.6	140.0	st4
Bath 2	h 1006	46	24	0.232	5.0	0x0	VIFx	28.6	140.0	st1
Bed 2	h 3349	152	114	0.232	7.0	0x0	VIFx	28.6	140.0	st1
Bed 3	c 1634	75	88	0.232	6.0	0x0	VIFx	28.6	140.0	st2
Dining	c 1551	70	83	0.232	6.0	0x0	VIFx	28.6	140.0	st2
Great Room	c 2047	83	110	0.232	6.0	0x0	VIFx	28.6	140.0	st1
Great Room-A	c 2047	83	110	0.232	6.0	0x0	VIFx	28.6	140.0	st1
Kitchen	c 1923	35	103	0.232	6.0	0x0	VIFx	28.6	140.0	st2
Kitchen-A	c 1923	35	103	0.232	6.0	0x0	VIFx	28.6	140.0	st2
Laundry	h 2509	114	79	0.232	6.0	0x0	VIFx	28.6	140.0	st4
Mud Room	h 1281	58	16	0.232	5.0	0x0	VIFx	28.6	140.0	st4
Office	c 1467	54	79	0.232	5.0	0x0	VIFx	28.6	140.0	st3
P Bedroom	h 1938	88	86	0.232	6.0	0x0	VIFx	28.6	140.0	st3
P Bedroom-A	h 1938	88	86	0.232	6.0	0x0	VIFx	28.6	140.0	st3
P WC	h 28	1	1	0.232	4.0	0x0	VIFx	28.6	140.0	st3
P WIC	c 276	9	15	0.232	4.0	0x0	VIFx	28.6	140.0	st4
Pantry	h 732	33	9	0.232	4.0	0x0	VIFx	28.6	140.0	st2
Primary Bath	h 1934	88	43	0.232	6.0	0x0	VIFx	28.6	140.0	st4
WIC	h 1112	51	13	0.232	5.0	0x0	VIFx	28.6	140.0	st2

Supply Trunk Detail Table


Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1	Peak AVF	365	357	0.232	464	12.0	0 x 0	VinIFlx	
st3	Peak AVF	232	252	0.232	569	9.0	0 x 0	VinIFlx	
st4	Peak AVF	272	160	0.232	498	10.0	0 x 0	VinIFlx	
st2	Peak AVF	298	399	0.232	507	12.0	0 x 0	VinIFlx	

Return Branch Detail Table


Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb4	0x0	275	231	74.2	0.232	504	10.0	0x 0		VIFx	
rb1	0x0	892	936	60.0	0.232	530	18.0	0x 0		VIFx	rst2

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rst2	Peak AVF	892	936	0.232	530	18.0	0 x 0	VinIFlx	



Sheet 1



Job #: J-12117 - C-2936
Performed by Ade Bonner for:
Hunter and Ashley Faulkner

Fort White, FL 32038

Scale: 1 : 161

Page 1
Right-Suite® Universal 2024
24.0.03 RSU11033
2025-Jul-18 11:30:21
... C-2936\j - 12117 - c - 2936.rup