

Inspection Checklist for Permit #000055198

Notes:

Order	Category	Inspection	Requirements
1	Swimming Pool	Pool Steel and Ground <i>Reviews steel reinforcing and equipotential bonding grid. Ref: NEC 680.26, FBC 454.1.10.4.2</i>	
2	Engineering	Setbacks <i>Confirms buildings, structures, and improvements are within required property setbacks. Columbia County LDR 4.1</i>	
3	Swimming Pool	Pool Footer <i>Inspects reinforcing and bonding in pool footers. Ref: FBC 454.1.6</i>	
4	Swimming Pool	Pool Deck/Piping Pressure <i>Verifies deck drains and pool piping under pressure. Ref: FBC 454.1.6.5.1</i>	
5	Electrical	Pool/Deck Bonding <i>Ensures all metallic pool parts and decking are bonded together. Ref: NEC Art. 680.26</i>	
6	City of Lake City Utilities	Lake City Utilities Tap Inspection <i>Conducted when required by the City to verify proper connection and availability of utility services. Ref: City of Lake City</i>	
7	Swimming Pool	Pool Safety and Final <i>Ensures barriers, alarms, and final system safety. Ref: FBC 454.1.3.1.9</i>	