

**Columbia County, FL.**  
**New Residential Construction Permit #000052281**  
**Issued February 10, 2025**




**Cal-Tech Testing, Inc.**  
 • Engineering  
 • Geotechnical  
 • Laboratories

P.O. Box 1820, Lake City, FL 32065-1825 • Phone: (904) 328-4444  
 2807 Spring Oak Road Jacksonville, FL 32217 • Phone: (904) 449-1191 • Fax: (904) 241-0520

**REPORT OF LABORATORY COMPACTION TEST**

**Client:** Daniel Curry 217 NW Simmons Way, Grand Lake, FL 32066  
**Project Name:** 4280 Carpenter Road  
**Project Location:** Daniel Curry  
**Contractor:** Daniel Curry

**File No.:** 24-00332-01  
**Lab No.:** 4280/0208  
**Lab No.:** 89122



**PROCTOR DATA**

Proctor No.: 1  
 Modified Proctor (ASTM D-1557)   
 Standard Proctor (ASTM D-698)   
 Maximum Dry Density Pct: 105.3  
 Optimum Moisture Percent: 12.5  
 Total 200 %: 2.8  
 LL: NA  
 PL: NA  
 PI: NP

The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with the methods specified in the referenced standards. No field or laboratory conditions can ever remove the influence and change with time. Each judgment should be exercised with regard to the use and interpretation of the data. The user should be responsible when not approved by the client.

**Sample Description:** Tan Sand (SP)  
**Sample Location:** Stockpile  
**Proposed Use:** Building Fill  
**Sampled By:** J. Abbott  
**Tested By:** J. Richter  
**Remarks:** TCC Client  
 TCC File

**Reviewed By:** [Signature]  
**Date:** 4/28/2025  
**Licensed:** Florida No. 65960

