

FIELD DENSITY WORKSHEET

CLIENT Cason Builders DATE 8-7-24
 PROJECT NO. _____
 PROJECT NAME Payne Res PERMIT NO. _____
 EARTH CONTRACTOR 143 SW Aquag Way Fort White TESTED BY CE
 COMPACTION REQUIREMENT (%) 95 Standard Proctor Modified Proctor FIELD CONTACT _____
 TOTAL ON-SITE TIME _____ MILES FROM OFFICE _____
 Limerock Subgrade Pipe Backfill Building Pad Building Footing Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
Approx 10' NW of SE corner	1088	9.9	FL	12"	36	1097	1059	973
10' SE of NW corner	1	1	1	1	44	1123	1076	989
CTR of Pad	1	1	1	1	41	111.1	1067	981

REMARKS _____

* Density failed to meet minimum project requirement
 ** Retest indicates minimum density requirement was obtained.
 () Client is aware of unsatisfactory test results.