

Project No. : 2605893
Project Name : COLE
Project Address : 312 SW THISTLEWOOD LN, FORT WHITE, FLORIDA, 32038

POOL HYDRAULICS WORKSHEET

DESIGN CIRCULATION FLOW PARAMETERS:

1. Pool circulation volume : $V := 408 \text{ ft}^2 \cdot 4 \text{ ft} + 12 \text{ ft} \cdot 6 \text{ ft} \cdot 6 \text{ in} = 12477.506 \text{ gal}$
 2. Preferred turnover rate: $t := 6 \text{ hr} = 360 \text{ min}$
 3. Pool circulation flow rate : $Q_p := \frac{V}{t} = 34.66 \text{ gpm}$
- Add water feat. flow rate $Q_{wf} := 0 \text{ gpm}$
- Total circulation flow rate $Q_c := Q_p + Q_{wf} = 34.66 \text{ gpm}$
- Minimum design flow rate $Q_{min} := 36 \text{ gpm}$
- Pool pump flow rate $Q := \text{Trunc}(\max(Q_c, Q_{min}), 1 \text{ gpm}) + 1 \text{ gpm} = 36 \text{ gpm}$

Richard E. Walker, P.E. # 61240

PIPE SIZES & SIMPLIFIED TDH:

Pool pump max. flow rate: $Q = 36 \text{ gpm}$

FLOW AND FRICTION LOSSES PER FOOT - SCH. 40 PVC PIPE						
Pipe size (in)	Velocity					
	6 ft/s		8 ft/s		10 ft/s	
	gpm	ft	gpm	ft	gpm	ft
1	16	0.14	21	0.23	26	0.35
1 1/2	37	0.08	50	0.14	62	0.21
2	62	0.06	82	0.1	103	0.16
2 1/2	88	0.05	117	0.09	146	0.13
3	138	0.04	181	0.07	227	0.1
4	234	0.03	313	0.05	392	0.07
5	534	0.02	712	0.03	890	0.05

Pipe Sizes Per 2023 FBC, 8th Edition:

Main Drain Piping: **2.0"** to keep velocity @ **8fps** max at flow rate = **82 gpm** max.

Skimmer/ Vac line Piping: **2.0"** to keep velocity @ **8fps** max at flow rate = **82 gpm** max.

Filter Return Piping: **2.0"** to keep velocity @ **10fps** max at flow rate = **103 gpm** max.

The distance of the pool equipment pad from the nearest edge of the pool = **20 ft.** (max.)

1. Friction loss (in suction/trunk pipe) in **2.0"** pipe per ft at $f_{suction} := 0.1$

2. Friction loss (in return pipe) in **2.0"** pipe per ft at $f_{return} := 0.16$

3. Length of suction pipe $L_{suction} := 70 \text{ ft}$

TDH in suction pipe $TDH_{suction} := L_{suction} \cdot f_{suction} = 7 \text{ ft}$

4. Length of return pipe $L_{return} := 100 \text{ ft}$

TDH in return pipe $TDH_{return} := L_{return} \cdot f_{return} = 16 \text{ ft}$

5. TDH in Piping $TDH_{piping} := TDH_{suction} + TDH_{return} = 23 \text{ ft}$

6. Filter loss in TDH $TDH_{filter} := 7 \text{ ft}$

7. Heater loss in TDH $TDH_{heater} := 0 \text{ ft}$

8. All other losses $TDH_{other} := 14 \text{ ft}$...head losses in fittings, etc

9. Total simplified TDH $TDH := TDH_{piping} + TDH_{filter} + TDH_{heater} + TDH_{other} = 44 \text{ ft}$

Filter (As Listed or Equal): Pentair CCRP 150 Cartridge

Pool Recir. Pump (As Listed or Equal):

Manufacturer : Pentair


Model : Superflo VS

Size / HP = 1.5

Maximum flow rate, $Q = 36 \text{ gpm}$

Total simplified TDH, $TDH = 44 \text{ ft}$

PERFORMANCE CURVES



Main Drain Cover (As Listed or Equal):

Manufacturer : CMP

Model : 25506-32X-VGBA

Max. cover flow rate (floor) = 184 gpm

Cover Replacement Date = 7 years

Notes :

1. In flow suction outlets cover/grate must conform to most recent edition of ASME/ANSI A112.19.8 and be embossed with that edition approval. Single drains shall be unblockable.
2. Center to center spacing of multiple drains shall be at least 3'-0".
3. Pump and Filter make, model and location cannot change without submitting a revised plan TDH worksheet.