

INPUT SUMMARY CHECKLIST REPORT**PROJECT**

Title:	Steckbeck Residence	Address type:	Street Address		
Building Type:	User	Bedrooms:	4	Lot #:	---
Owner:		Conditioned Area:	2209	Block/SubDivision:	---
Builder Home ID:		Total Stories:	2	PlatBook:	---
Builder Name:		Worst Case:	No	Street:	
Permit Office:		Rotate Angle:	0	County:	Columbia
Jurisdiction:		Cross Ventilation:		City, State, Zip:	, FL,
Family Type:	Detached	Whole House Fan:			
New/Existing:	New (From Plans)	Terrain:	Rural		
Year Construct:	2026	Shielding:	Moderate/Rural		
Comment:					

CLIMATE

<input checked="" type="checkbox"/> Design Location	Tmy Site	Design Temp	97.5%	2.5%	Int Design Temp	Winter	Summer	Heating Degree Days	Design Moisture	Daily temp Range
___ FL, Gainesville	FL_GAINESVILLE_REGIONA	32	92	70	75	1305.5	51	Medium		

BLOCKS

<input checked="" type="checkbox"/> Number	Name	Area	Volume
___ 1	Block1	2209	21312 cu ft

SPACES

<input checked="" type="checkbox"/> Number	Name	Area	Volume	Kitchen	Occupants	Bedrooms	Finished	Cooled	Heated
___ 1	Main	1799	17990	Yes	6	3	Yes	Yes	Yes
___ 2	Garage Bath	42	378	No	0	0	Yes	Yes	Yes
___ 3	Bonus Room	368	2944	No	2	1	Yes	Yes	Yes

FLOORS

(Total Exposed Area = 1841 sq.ft.)

<input checked="" type="checkbox"/> #	Floor Type	Space	Exposed Perim(ft)	Area	R-Value Perim.	U-Factor Joist	Slab Insul. Vert/Horiz	Tile	Wood	Carpet	
___ 1	Slab-On-Grade Edge Ins	Main	200	1799 sqft	0.0	---	0.563	0 (ft)/0 (ft)	0.20	0.60	0.20
___ 2	Slab-On-Grade Edge Ins	Garage Bath	26	42 sqft	0.0	---	0.710	0 (ft)/0 (ft)	1.00	0.00	0.00
___ 3	Floor Over Other Space	Bonus Room	---	368 sqft	---	0.0	0.173	-----	0.00	0.00	1.00

ROOF

<input checked="" type="checkbox"/> #	Type	Materials	Roof Area	Gable Area	Framing. Fract.	Roof Color	Rad Barr	Solar Absor.	SA Tested	Emitt	Emitt Tested	Deck Insul.	Pitch (deg)
___ 1	Gable or shed	Metal	2213 ft²	614 ft²	0.11	Unf, Gal.	N	0.7	No	0.7	No	21	33.69

ATTIC

<input checked="" type="checkbox"/> #	Type	Ventilation	Vent Ratio (1 in)	Area	RBS	IRCC
___ 1	No attic	Unvented	0	1841 ft²	N	N

INPUT SUMMARY CHECKLIST REPORT

CEILING													(Total Exposed Area = 2209 sq.ft.)			
✓ #	Ceiling Type		Space	R-Value	Ins. Type	Area	U-Factor	Framing Frac.	Truss Type							
___ 1	Single assembly, no airspace(Unvented)		Main	21.0	Blown	1799.0ft²	0.025	0.11	Wood							
___ 2	Single assembly, no airspace(Unvented)		Garage Bath	21.0	Blown	42.0ft²	0.025	0.11	Wood							
___ 3	Single assembly, no airspace(Unvented)		Bonus Room	21.0	Blown	368.0ft²	0.025	0.11	Wood							

WALLS													(Total Exposed Area = 2229 sq.ft.)			
✓ #	Ornt	Adjacent To	Wall Type	Space	Cavity R-Value	Width Ft In	Height Ft In	Area sq.ft.	U-Factor	Sheath R-Value	Frm. Frac.	Solar Absor.	Below Grade			
___ 1	N	Exterior	Frame - Wood	Main	19.0	35.0 0	10.0 0	350.0	0.061		0.23	0.75	0.0 %			
___ 2	E	Exterior	Frame - Wood	Main	19.0	48.0 2	10.0 0	481.7	0.061		0.23	0.75	0.0 %			
___ 3	S	Exterior	Frame - Wood	Main	19.0	4.0 2	10.0 0	41.7	0.061		0.23	0.75	0.0 %			
___ 4	E	Exterior	Frame - Wood	Main	19.0	10.0 2	10.0 0	101.7	0.061		0.23	0.75	0.0 %			
___ 5	S	Exterior	Frame - Wood	Main	19.0	12.0 8	10.0 0	126.7	0.061		0.23	0.75	0.0 %			
___ 6	W	Exterior	Frame - Wood	Main	19.0	15.0 2	10.0 0	151.7	0.061		0.23	0.75	0.0 %			
___ 7	S	Exterior	Frame - Wood	Main	19.0	18.0 2	10.0 0	181.7	0.061		0.23	0.75	0.0 %			
___ 8	W	Exterior	Frame - Wood	Main	19.0	16.0 4	10.0 0	163.3	0.061		0.23	0.75	0.0 %			
___ 9	S	Exterior	Frame - Wood	Main	19.0	5.0 0	10.0 0	50.0	0.061		0.23	0.75	0.0 %			
___ 10	W	Exterior	Frame - Wood	Main	19.0	13.0 0	10.0 0	130.0	0.061		0.23	0.75	0.0 %			
___ 11	N	Exterior	Frame - Wood	Main	19.0	5.0 0	10.0 0	50.0	0.061		0.23	0.75	0.0 %			
___ 12	W	Exterior	Frame - Wood	Main	19.0	13.0 10	10.0 0	138.3	0.061		0.23	0.75	0.0 %			
___ 13	N	Exterior	Frame - Wood	Garage Bath	19.0	6.0 0	9.0 0	54.0	0.061		0.23	0.75	0.0 %			
___ 14	E	Exterior	Frame - Wood	Garage Bath	19.0	7.0 4	9.0 0	66.0	0.061		0.23	0.75	0.0 %			
___ 15	N	Exterior	Frame - Wood	Bonus Room	19.0	17.0 10	8.0 0	142.7	0.061		0.23	0.75	0.0 %			

DOORS													(Total Exposed Area = 92 sq.ft.)			
✓ #	Ornt	Adjacent To	Door Type	Space	Storms	U-Value	Width Ft In	Height Ft In	Area							
___ 1	S	Exterior	Insulated	Main	None	0.46	3.00 0	8.00 0	24.0ft²							
___ 2	S	Exterior	Insulated	Main	None	0.46	3.00 0	8.00 0	24.0ft²							
___ 3	W	Exterior	Insulated	Main	None	0.46	3.00 0	8.00 0	24.0ft²							
___ 4	E	Exterior	Insulated	Garage Bath	None	0.46	3.00 0	6.00 8	20.0ft²							

WINDOWS													(Total Exposed Area = 323 sq.ft.)			
✓ #	Ornt	Wall ID	Frame	Panes	NFRC U-Factor	SHGC	Imp	Storm	Total Area (ft²)	Same Units	Width (ft)	Height (ft)	--Overhang-- Depth (ft)	Sep. (ft)	Interior Shade	Screen
___ 1	N	1	Vinyl	Low-E Double	Y 0.26	0.20	N	N	24.0	3	2.00	4.00	1.5	1.3	None	None
___ 2	N	1	Vinyl	Low-E Double	Y 0.26	0.20	N	N	24.0	2	2.00	6.00	1.5	1.3	None	None
___ 3	N	1	Vinyl	Low-E Double	Y 0.26	0.20	N	N	48.0	1	6.00	8.00	1.5	1.3	None	None
___ 4	N	1	Vinyl	Low-E Double	Y 0.26	0.20	N	N	6.0	1	2.00	3.00	1.5	1.3	None	None
___ 5	E	2	Vinyl	Low-E Double	Y 0.26	0.20	N	N	4.0	1	4.00	1.00	1.5	1.3	None	None
___ 6	E	2	Vinyl	Low-E Double	Y 0.26	0.20	N	N	18.0	1	3.00	6.00	1.5	1.3	None	None
___ 7	E	2	Vinyl	Low-E Double	Y 0.26	0.20	N	N	8.0	1	2.00	4.00	1.5	1.3	None	None
___ 8	S	5	Vinyl	Low-E Double	Y 0.26	0.20	N	N	36.0	2	3.00	6.00	1.5	1.3	None	None
___ 9	S	5	Vinyl	Low-E Double	Y 0.26	0.20	N	N	8.0	1	6.00	1.33	1.5	1.3	None	None
___ 10	W	6	Vinyl	Low-E Double	Y 0.26	0.20	N	N	15.0	1	2.50	6.00	1.5	1.3	None	None
___ 11	S	7	Vinyl	Low-E Double	Y 0.26	0.20	N	N	36.0	2	3.00	6.00	1.5	1.3	None	None
___ 12	W	8	Vinyl	Low-E Double	Y 0.26	0.20	N	N	30.0	2	2.50	6.00	1.5	1.3	None	None
___ 13	W	10	Vinyl	Low-E Double	Y 0.26	0.20	N	N	30.0	2	2.50	6.00	1.5	1.3	None	None
___ 14	N	11	Vinyl	Low-E Double	Y 0.26	0.20	N	N	15.0	1	2.50	6.00	1.5	1.3	None	None
___ 15	N	13	Vinyl	Low-E Double	Y 0.26	0.20	N	N	6.0	1	2.00	3.00	1.5	1.3	None	None
___ 16	N	15	Vinyl	Low-E Double	Y 0.26	0.20	N	N	15.0	1	3.00	5.00	1.5	1.3	None	None

INPUT SUMMARY CHECKLIST REPORT

INFILTRATION											
<input checked="" type="checkbox"/> #	Scope	Method	SLA	CFM50	ELA	EqLA	ACH	ACH50	Space(s)	Infiltration Test Volume	
___ 1	Wholehouse	Proposed ACH(50)	0.00037	2131	116.92	219.51	0.1672	6.0	All	21312 cu ft	

MASS						
<input checked="" type="checkbox"/> #	Mass Type	Area	Thickness	Furniture Fraction	Space	
___ 1	Default(8 lbs/sq.ft.)	0 ft²	0 ft	0.30	Main	
___ 2	Default(8 lbs/sq.ft.)	0 ft²	0 ft	0.30	Garage Bath	
___ 3	Default(8 lbs/sq.ft.)	0 ft²	0 ft	0.30	Bonus Room	

HEATING SYSTEM											
<input checked="" type="checkbox"/> #	System Type	Subtype/Speed	AHRI #	Efficiency	Capacity kBtu/hr	---Geothermal HeatPump---			Ducts	Block	
						Entry	Power	Volt	Current		
___ 1	Electric Heat Pump	None/Single		HSPF2: 8.00	48.0		0.00	0.00	0.00	sys#1	1

COOLING SYSTEM									
<input checked="" type="checkbox"/> #	System Type	Subtype/Speed	AHRI #	Efficiency	Capacity kBtu/hr	Air Flow cfm	SHR	Duct	Block
___ 1	Central Unit	None/Single		SEER2:15.0	48.0	1440	0.75	sys#1	1

HOT WATER SYSTEM											
<input checked="" type="checkbox"/> #	System Type	Subtype	Location	EF(UEF)	Cap	Use	SetPnt	Fixt. Flow	Trap	Pipe Ins.	Pipe length
___ 1	Electric	None	Garage Bath	0.92 (0.92)	50.0 gal	70 gal	120 deg	Standard	Yes	None	99

	Recirculation System	Recirc Control Type	Loop length	Branch length	Pump power	DWHR	Facilities Connected	Equal Flow	DWHR Eff	Other Credits
___ 1	No		NA	NA	NA	No	NA	NA	NA	None

DUCTS												
<input checked="" type="checkbox"/> #	Duct Location	Supply R-Value	Supply Area	Return Location	Return R-Value	Return Area	Leakage Type	AHU Location	CFM 25 TOT OUT	QN OUT	AHU SEALED	HVAC # Heat Cool
___ 1	Main	6.0	442 ft²	Main	6.0	110 ft²	Default Leakage	Bonus Room (Default)	(Default)			1 1

TEMPERATURES													
Programable Thermostat: Y						Ceiling Fans: N							
Cooling	<input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input checked="" type="checkbox"/> Jun	<input checked="" type="checkbox"/> Jul	<input checked="" type="checkbox"/> Aug	<input checked="" type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec	
Heating	<input checked="" type="checkbox"/> Jan	<input checked="" type="checkbox"/> Feb	<input checked="" type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input checked="" type="checkbox"/> Nov	<input checked="" type="checkbox"/> Dec	
Venting	<input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input checked="" type="checkbox"/> Mar	<input checked="" type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input checked="" type="checkbox"/> Oct	<input checked="" type="checkbox"/> Nov	<input type="checkbox"/> Dec	
<input checked="" type="checkbox"/>	Thermostat Schedule: HERS 2006 Reference												
	Schedule Type	1	2	3	4	5	6	7	8	9	10	11	12
___	Cooling (WD)	AM PM	78 80	78 80	78 80	78 80	78 80	78 80	78 80	78 80	80 78	80 78	80 78

INPUT SUMMARY CHECKLIST REPORT

TEMPERATURES(Continued)

___ Cooling (WEH)	AM	78	78	78	78	78	78	78	78	80	80	80	80
	PM	80	80	80	80	78	78	78	78	78	78	78	78
___ Heating (WD)	AM	65	65	65	65	65	65	65	65	68	68	68	68
	PM	68	68	68	68	68	68	68	68	68	68	68	68
___ Heating (WEH)	AM	65	65	65	65	65	65	65	65	68	68	68	68
	PM	68	68	68	68	68	68	68	68	68	68	68	68