


MEMORANDUM

To:	All Concerned Parties	Date:	April 2, 2026
From:	Austin Blazs	Project:	24-0379.22
Subject:	Finished Floor Elevation letter for Lot 22, Preserve at Laural Lake, Unit 1		

Please accept this memorandum as my certification that the elevation of the lowest finished floor of the concrete foundation constructed on Lot 22, Preserve at Laural Lake, Unit 1, as per plat recorded in Plat Book 9, Pages 19-25, was field measured on April 1, 2026, to be **113.24** feet. Said foundation is in compliance with the Zoning setback requirements. The benchmark used as a basis for this measurement is based on NGS Data Point BD1031, with a designation of I75 71 A14.

The minimum finished floor elevation required for Lot 22, per an Elevation Letter provided by Christopher A. Potts, P.E. with LJA Engineering, is **112.20** feet.



Austin Blazs, PSM
Registered Florida Surveyor and Mapper Certificate Number 7401