

Finish Floor Elevation Requirement\Exemption

Client: Chris Chapman & Elizabeth Moses

Contractor: Unknown

Description: Chapman Mobile Home Residence


Parcel ID#: 24-7S-16-04311-106

Foundation Requirements:

For protection against water damage during the 100 year storm event, the minimum finish floor elevation of the proposed structure shall be 18 inches above the existing ground at any point along the perimeter of the proposed structure.

The ground around the proposed structure shall be graded such as to convey all stormwater runoff away from the proposed structure.

Please note that this certification letter also serves as a request for exemption from the elevation requirements for areas where no base flood data has been provided. This is because the above elevations are based on an engineering analysis of flood hazards at the structure's current location, centered at approximately +/-330 feet north of the southern property boundary, and approximately +/-330 feet west of the adjacent ungraded dirt road.



David M. Winsberg
PE# 68463, CA# 29596
April 23, 2026

