

Inspection Checklist for Permit #000055692

Notes:

Order	Category	Inspection	Requirements
1	Mechanical	A/C Replacement Final <i>Checks installation, electrical, and condensate disposal for new HVAC unit. Ref: FBC-M 307</i>	
2	Engineering	Initial Driveway <i>Verifies location, layout, culvert size, and grade before driveway construction begins.</i>	Requires ROW Access/Driveway connects to county maintained road.
3	Engineering	Final Driveway <i>Approves finished driveway, verifying pavement, culvert, drainage, mitered ends, and safety compliance. Ref: Columbia County LDR 4.2.3</i>	Requires Initial Driveway.