

## Laurie Hodson

---

**From:** Shasta Pelham [pelhams@lcfla.com]  
**Sent:** Wednesday, July 02, 2014 12:38 PM  
**To:** Laurie Hodson  
**Subject:** RE: Information

Laurie,

Sorry for the delay in my response I took a few vacation days. I see we have an account for First Full Gospel Church at 2344 NE Washington St for water and gas. We currently do not provide any services at 288 NE Jones Way. A tap inquiry will need to be done to determine if service is available at 288 NE Jones Way.

Thank You,  
Shasta M. Pelham  
The City of Lake City  
Customer Service Representative III  
[pelhams@lcfla.com](mailto:pelhams@lcfla.com)  
Office: (386)719-5786 / Fax : (386)719-5837

**From:** Laurie Hodson [[mailto:laurie\\_hodson@columbiacountyfla.com](mailto:laurie_hodson@columbiacountyfla.com)]  
**Sent:** Friday, June 27, 2014 10:19 AM  
**To:** Shasta Pelham  
**Subject:** Information

Good Morning Shasta,

Can you tell me if the First Full Gospel Church at 288 NE Jones Way, Lake City, FL 32055, which is on the corner of East Washington and Jones Way, is serviced by city water and/or sewer?

Thanks in advance for your help,

*Laurie Hodson*

Laurie Hodson, Office Manager  
Columbia County Building & Zoning Department  
135 NE Hernando Ave, Suite B-21,  
Lake City, FL 32055  
Office (386) 758 1007  
Fax (386) 758 2160  
[laurie\\_hodson@columbiacountyfla.com](mailto:laurie_hodson@columbiacountyfla.com)







# COLUMBIA COUNTY FIRE RESCUE

## Life Safety Services

P.O. BOX 1529 Lake City, Florida 32056  
Office (386) 754-2120 Fax (386) 754-7064

Fire Inspector/PIO  
Lt. Joshua Wehinger

09 December 2014

TO: Troy Crews  
Columbia County Building and Zoning

FROM: Joshua Wehinger  
Florida State Fire Inspector #180649

RE: First Full Gospel Church of Columbia County, Application #32253, 32254

A Plan review was performed of the proposed construction of the New Youth Class Rooms and Youth Hall to be located at 288 Ne Jones Way Lake City, FL. The Youth Class Rooms were classified under Chapter 38 New Business and the Youth Hall under Chapter 12 New Assembly, of the Florida Fire Prevention Code, 2009 Edition. I recommend Approval of the Buildings with the following conditions;

- Light Weight Truss Marking
  - Florida Statute, Section 633.027, (2008) requires the owner of any commercial, industrial or multiunit residential structure of three units or more constructed of light-frame trusses, to install a symbol adopted by rule of the State Fire Marshal's Office. This rule establishes the dimensions, color, and location of the symbol to be applied to every commercial, industrial and multiunit residential structure of three units or more constructed of light-frame trusses.
- Building Address
  - New and existing buildings shall have approved **address numbers** placed in a position to be plainly legible and visible from the street or road, in contrast with their background. At the minimum, numbers shall be not less than 3 inches in height for residential buildings and at least 6 inches in height for all other buildings. *NFPA 1:10.13.1.1 & NFPA 1:10.13.1.2*

- Electrical Disconnect
  - NFPA 1:11.1.7 states, “Means shall be provided for the fire department to disconnect the electrical service to a building, structure or facility when the electrical is covered under the scope of NFPA 70

Should you require any additional information, please feel free to contact my office.

Sincerely,

A handwritten signature in black ink, appearing to read "Lt. Joshua Wehinger". The signature is written in a cursive, flowing style.

Lt. Joshua Wehinger