

## FIELD DENSITY WORKSHEET

CLIENT Tanner Const DATE 6-28-23  
 PROJECT NO. \_\_\_\_\_  
 PROJECT NAME 250 SE Shadowwood DR Lake City PERMIT NO. \_\_\_\_\_  
 EARTH CONTRACTOR \_\_\_\_\_ TESTED BY CE  
 COMPACTION REQUIREMENT (%) 95  Standard Proctor  Modified Proctor FIELD CONTACT \_\_\_\_\_  
 TOTAL ON-SITE TIME \_\_\_\_\_ MILES FROM OFFICE \_\_\_\_\_  
 Limerock  Subgrade  Pipe Backfill  Building Pad  Building Footing  Other \_\_\_\_\_

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
Approx 10' NW of SE corner	1088	9.9	FG	12"	49	111.2	1066	974
Appx. 10' SE of NW corner				1	57	1136	1075	988
Appx. 0.12 of north face					52	1123	1067	981

REMARKS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

\* Density failed to meet minimum project requirement  
 \*\* Retest indicates minimum density requirement was obtained.  
 ( ) Client is aware of unsatisfactory test results.