

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

September 8, 2018

Enka Ashley

13th Street Home Sales

Enka.liveoakhomes@gmail.com

re: ELEVATION LETTER – PARCELS 06-55-14-09130-008 # -009

FINLEY LITTLE ROAD, LAKE CITY, FL


David & Sharon Timmerman

As requested, I inspected the mobile home installed at the above referenced site. The finished floor of the structure is approximately 30 inches above the original soil elevation. The topography of the site slopes away from the structure on the sides and rear.

I certify that the finished floor elevation of the home as it is currently set will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,



Carol Chadwick, P.E.

