

Inspection Checklist for Permit #000056222

Notes:

Order	Category	Inspection	Requirements
1	Solar	Solar Final <i>Ensures PV system, inverter, and disconnects are safe/approved. Ref: NEC 690</i>	
2	Electrical	Permanent Power <i>Releases power once service equipment is complete and safe. Ref: NEC Art. 230</i>	
3	Engineering	Setbacks <i>Confirms buildings, structures, and improvements are within required property setbacks. Columbia County LDR 4.1</i>	