

**September 28, 2021**

Brian Papka  
363 SW Blaylock Court  
Lake City, FL 32024

**Subject: Lot 4, Oaks of Lake City, Phase 1 - FFE Letter**

Dear Mr. Papka:

Daniel & Gore, LLC has performed a vertical survey on Lot 4, Oaks of Lake City Phase 1, Columbia County, Florida from a benchmark being a concrete monument (P.R.M.) at the P.C. of Lot 75, Oaks of Lake City Phase 2 (elevation – 91.745', NAVD 1988) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 92.0'.
- The elevation of the finish floor is at 102.10', being 10.1' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,

Scott Daniel, PSM

