

MechaniCalcs LLC

122 Del Palma, Palm Coast, FL 32137 Phone: 386-503-0449 Email: MechaniCalcs@gmail.com Web: ineedHVACcalcs.com or MechaniCalcsLLC.com

Project Information

For: Vincent Greenlee, Buildings & More
132 SW Eglin Pl, Lake City, FL 32024

Notes:

Design Information

Weather: Gainesville, FL, US

Winter Design Conditions

Outside db 33 °F
Inside db 70 °F
Design TD 37 °F

Ventilation Method ASHRAE 62.2-2010

Heating Summary

Structure 25355 Btuh
Ducts 0 Btuh
Central vent (0 cfm) 0 Btuh

Humidification 0 Btuh
Piping 0 Btuh
Equipment load 25355 Btuh

Infiltration

Method Blower door
Shielding / stories 3 (partial) / 1
Pressure /ACH /AVF 50 Pa / 7.0 / 2536 cfm

	Heating	Cooling
Area (ft ²)	1500	1500
Volume (ft ³)	21740	21740
Air changes/hour	0.55	0.31
Equiv. AVF (cfm)	198	112

Heating Equipment Summary

Make Mitsubishi Electric
Trade Ductless 4 Zone
Model MXZ-5D36NL***
AHRI ref 216498927

Efficiency 9.3 HSPF2
Heating input
Heating output 36000 Btuh @ 47°F
Temperature rise 28 °F
Actual air flow 1180 cfm
Air flow factor 0.047 cfm/Btuh
Static pressure 0 in H2O
Space thermostat
Capacity balance point = 24 °F

Summer Design Conditions

Outside db 94 °F
Inside db 75 °F
Design TD 19 °F
Daily range M
Relative humidity 50 %
Moisture difference 42 gr/lb

Sensible Cooling Equipment Load Sizing

Structure 14603 Btuh
Ducts 0 Btuh
Central vent (0 cfm) 0 Btuh

Blower 0 Btuh

Use manufacturer's data y
Rate/swing multiplier 1.00
Equipment sensible load 14603 Btuh

Latent Cooling Equipment Load Sizing

Structure 3799 Btuh
Ducts 0 Btuh
Central vent (0 cfm) 0 Btuh

Equipment latent load 3799 Btuh

Equipment Total Load (Sen+Lat) 18402 Btuh
Req. total capacity at 0.80 SHR 1.5 ton

Cooling Equipment Summary

Make Mitsubishi Electric
Trade Ductless 4 Zone
Cond MXZ-5D36NL***
Coil
AHRI ref 216498927
Efficiency 12.0 EER2, 19.2 SEER2
Sensible cooling 28320 Btuh
Latent cooling 7080 Btuh
Total cooling 35400 Btuh
Actual air flow 1180 cfm
Air flow factor 0.080 cfm/Btuh
Static pressure 0 in H2O
Load sensible heat ratio 0.79

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

MechaniCalcs LLC

122 Del Palma, Palm Coast, FL 32137 Phone: 386-503-0449 Email: MechaniCalcs@gmail.com Web: ineedHVACcalcs.com or MechaniCalcsLLC.com

Project Information

For: Vincent Greenlee, Buildings & More
132 SW Eglin Pl, Lake City, FL 32024

Cooling Equipment

Design Conditions

Outdoor design DB:	94.0°F	Sensible gain:	14603 Btuh	Entering coil DB:	75.0°F
Outdoor design WB:	76.0°F	Latent gain:	3799 Btuh	Entering coil WB:	62.5°F
Indoor design DB:	75.0°F	Total gain:	18402 Btuh		
Indoor RH:	50%	Estimated airflow:	0 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP			
Manufacturer:	Mitsubishi Electric	Model:	MXZ-5D36NL***	
Actual airflow:	1180 cfm			
Sensible capacity:	28320 Btuh	194% of load		
Latent capacity:	7080 Btuh	186% of load		
Total capacity:	35400 Btuh	192% of load	SHR:	80%

Heating Equipment


Design Conditions

Outdoor design DB:	33.3°F	Heat loss:	25355 Btuh	Entering coil DB:	70.0°F
Indoor design DB:	70.0°F				

Manufacturer's Performance Data at Actual Design Conditions


Equipment type:	Split ASHP			
Manufacturer:	Mitsubishi Electric	Model:	MXZ-5D36NL***	
Actual airflow:	1180 cfm			
Output capacity:	36000 Btuh	142% of load		Capacity balance: 24 °F
Supplemental heat required:	0 Btuh			Economic balance: -99 °F

Meets all requirements of ACCA Manual S.



First Floor


Split ASHP Mitsubishi Electric Ductless 4
Zone MXZ-5D36NL***



Job #:
Performed by Jonathan Jacobs for:
Vincent Greenlee
132 SW Eglin Pl
Lake City, FL 32024

MechaniCalcs LLC
122 Del Palma
Palm Coast, FL 32137
Phone: 386-503-0449
ineedHVACcalcs.com or MechaniCalcsLLC.com Me...

Scale: 1 : 99
Page 1
Right-Suite@ Universal 2025
25.0.04 RSU00000
2026-Feb-26 14:55:04
...rs\Greenlee -132 SW Eglin Pl.rup



Notes

MechaniCalcs DESIGN DETAIL SUMMARY

MechaniCalcs responsibility is solely for design of the HVAC system based upon the design information and conditions specified in the drawing and accompanying ACCA Manual J, S, D and T reports. The HVAC design is based only upon the design information and conditions shown, which have not been verified. Before use, the building designer must verify the applicability of the design information and conditions, and properly incorporate this HVAC design into the overall building design. The HVAC design shown is only valid for the building layout, elevations, orientation, interior floor plan, construction materials, equipment, and weather bin data specified in the drawing.

Any change to the design information and conditions, or deviation from this design will require an updated HVAC design. MechaniCalcs no responsibility for deviations from it's HVAC design, use of its designs for purpose other than as intended by MechaniCalcs, or for the improper construction or installation of HVAC systems based on its designs.

Job #:
Performed by Jonathan Jacobs for:
Vincent Greenlee
132 SW Eglin Pl
Lake City, FL 32024

MechaniCalcs LLC
122 Del Palma
Palm Coast, FL 32137
Phone: 386-503-0449
ineedHVACcalcs.com or MechaniCalcsLLC.com Me...

Scale: 1 : 99
Page 2
Right-Suite@ Universal 2025
25.0.04 RSU00000
2026-Feb-26 14:55:04
...rs\Greenlee -132 SW Eglin Pl.rup