

## Project Information

For: NORTON RESIDENCE  
Lake City, FL

Notes:

## Design Information

Weather: Gainesville, FL, US

### Winter Design Conditions

Outside db 33 °F  
Inside db 70 °F  
Design TD 37 °F

Ventilation Method MJ8

### Heating Summary

Structure 31454 Btuh  
Ducts (R-6.0) 9345 Btuh  
Central vent (0 cfm) 0 Btuh  
  
Humidification 0 Btuh  
Piping 0 Btuh  
Equipment load 40799 Btuh

### Infiltration

Method Simplified  
Construction quality Average  
Fireplaces 0

	Heating	Cooling
Area (ft <sup>2</sup> )	2794	2794
Volume (ft <sup>3</sup> )	27731	27731
Air changes/hour	0.32	0.16
Equiv. AVF (cfm)	148	74

### Heating Equipment Summary

Make Trane  
Trade TRANE  
Model 4TWR4060N1000A  
AHRI ref 209842243  
  
Efficiency 7.5 HSPF2  
Heating input  
Heating output 55000 Btuh @ 47°F  
Temperature rise 27 °F  
Actual air flow 1833 cfm  
Air flow factor 0.045 cfm/Btuh  
Static pressure 0.53 in H2O  
Space thermostat  
Capacity balance point = 25 °F

Backup:  
Input = 10 kW, Output = 35767 Btuh, 100 AFUE

### Summer Design Conditions

Outside db 92 °F  
Inside db 75 °F  
Design TD 17 °F  
Daily range M  
Relative humidity 50 %  
Moisture difference 43 gr/lb

### Sensible Cooling Equipment Load Sizing

Structure 26958 Btuh  
Ducts (R-6.0) 13112 Btuh  
Central vent (0 cfm) 0 Btuh  
  
Blower 0 Btuh  
Use manufacturer's data n  
Rate/swing multiplier 0.97  
Equipment sensible load 39028 Btuh

### Latent Cooling Equipment Load Sizing

Structure 2976 Btuh  
Ducts 2694 Btuh  
Central vent (0 cfm) 0 Btuh  
  
Equipment latent load 5671 Btuh  
  
**Equipment Total Load (Sen+Lat)** 44699 Btuh  
Req. total capacity at 0.80 SHR 4.1 ton

### Cooling Equipment Summary

Make Trane  
Trade TRANE  
Cond 4TWR4060N1000A  
Coil TEM4B0C60S51SA  
AHRI ref 209842243  
Efficiency 11.7 EER2, 14.3 SEER2  
Sensible cooling 44000 Btuh  
Latent cooling 11000 Btuh  
Total cooling 55000 Btuh  
Actual air flow 1833 cfm  
Air flow factor 0.046 cfm/Btuh  
Static pressure 0.53 in H2O  
Load sensible heat ratio 0.88

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

## Project Information

For: NORTON RESIDENCE  
 Lake City, FL

## Cooling Equipment

### Design Conditions

Outdoor design DB:	92.4°F	Sensible gain:	40070	Btuh	Entering coil DB:	78.3°F
Outdoor design WB:	75.8°F	Latent gain:	5671	Btuh	Entering coil WB:	64.0°F
Indoor design DB:	75.0°F	Total gain:	45741	Btuh		
Indoor RH:	50%	Estimated airflow:	1833	cfm		

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Trane	Model:	4TWR4060N1000A+TEM4B0C60S51SA		
Actual airflow:	1833	cfm			
Sensible capacity:	44121	Btuh	110%	of load	
Latent capacity:	8341	Btuh	147%	of load	
Total capacity:	52461	Btuh	115%	of load	SHR: 84%

## Heating Equipment

### Design Conditions

Outdoor design DB:	33.3°F	Heat loss:	40799	Btuh	Entering coil DB:	68.4°F
Indoor design DB:	70.0°F					

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Trane	Model:	4TWR4060N1000A+TEM4B0C60S51SA		
Actual airflow:	1833	cfm			
Output capacity:	55000	Btuh	135%	of load	Capacity balance: 25 °F
Supplemental heat required:	0	Btuh			Economic balance: -99 °F

Backup equipment type:	Elec strip				
Manufacturer:		Model:			
Actual airflow:	1833	cfm			
Output capacity:	10.5	kW	88%	of load	Temp. rise: 50 °F

Meets all requirements of ACCA Manual S.