

Christopher Q. Dicks, P.E.
P.E. License No. 64766
4037 SE County Road 252
Lake City, FL 32025
(386) 365-1223
chrisdicks1974@outlook.com

7/24/2026

Wentworth Construction Services, LLC
Caleb Wentworth
(850) 295-3016

**Re: ELEVATION LETTER - Parcel Id 27-6S-17-09784-105,
258 SE Ripley Pl., Lake City, Columbia County, Florida.**

SUBJECT: Finish Floor Height Verification

To whom it may concern,

During a field survey conducted on 7/24/2026 at the subject property, the finish floor elevation of ~111.34' meets the requirements of my previous letter, signed on 7/21/2025. The finished floor is sufficiently higher than the surrounding ground, measured at 10" higher than the existing ground on the northwest corner and 3'-8" higher than the surrounding ground on the southeast corner.

I certify that the minimum finish floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the land Development Regulations.

Christopher Q Dicks



Digitally signed by Christopher Q Dicks
DN: cn=Christopher Q Dicks,
o=Qualifier:A0141D000001B0BDEA75C20000F146,
c=Florida, CHUS
Reason: I am the author of this document
Date: 2026.07.30 16:34:17 -0400

Christopher Q. Dicks, P.E.
Florida P.E. 64766

