

Work Order

Number	2026-00009291	Request Date	7/29/2026 12:00:00 AM
Type	Water Inspection	Schedule Date	7/29/2026 12:00:00 AM
Priority		Assign Date	
Requester	Shasta Pelham	Assigned To	Scott, William Brian
Account	143417-001	Service Address	1051 NW COUNTY ROAD 25A
	Columbia County Animal Control Facility 3867583352	Phone:	LAKE CITY, FL 32055

Comments	10:32 am Give to Kevin. Please verify if the plumber has correctly connected to the water meter. David Rhodes, Sr., will be on site at 1 pm. He can be reached at 386-288-8805. - SMP
-----------------	---

New Meter Device	Meter #99173029			
	1,1/2" Cordonel meter			
	MXU #142885786			

Read 00000000 Read

Mark from Paradise plumbing on site turned on left on
Meter rear of building on 25 a near sidewalk and gate
2:00-2:30pm

Read Date 07-29-2026 Read Date / /

Meter and Back Flow installed properly, Back Flow
 Comments
 behind building by the gas meter and the sidewalk

Completed By: Kap

Work Order

Number	2026-00009293	Request Date	7/29/2026 12:00:00 AM
Type	Sewer Inspection	Schedule Date	7/29/2026 12:00:00 AM
Priority		Assign Date	
Requester	Shasta Pelham	Assigned To	Scott, William Brian
Account	143417-001	Service Address	1051 NW COUNTY ROAD 25A
	Columbia County Animal Control Facility Phone: 3867583352		LAKE CITY, FL 32055

Comments	10:42 am Give to Kevin. Please verify if the plumber has correctly connected to the sewer tap. David Rhodes, Sr., will be on site at 1 pm. He can be reached at 386-288-8805. - SMP
----------	---

New Meter Device				

Read _____ _____ _____ _____	Read _____ _____ _____ <u>1:00-1:45pm</u>
--	---

Read Date <u>07-29-2026</u>	Read Date ____ / ____ / ____
------------------------------------	-------------------------------------

County has private Lift station force main connected
 properly to city force main, on 25 a across the street from
 boat doctors

Completed By: Kap