



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

07/15/2026

Permit # 000055823

L-32452

Re: Lot 27 Stone Henge Phase 2

John Norris Construction

To Whom It May Concern:

The finished floor elevation on Lot 27 is determined to be 100.37 feet NAVD 88 datum. The permit states that the MFE per the plat of record is 101.2 feet, however the plat was calculated on NGVD 29 datum. The conversion is -0.83 feet to NAVD 88 therefore the correct MFE in 88 datum is 100.37 feet.

Sincerely,


L. Scott Britt
LS 5757

