

JBROTHER'S HOME INSPECTION & ENGINEERING SERVICES
4210 NW 29TH TERRACE, GAINESVILLE, FL, 32605
PHONE: (352) 575-6456
EMAIL: JBROTHERSHOMEINSPECTION@GMAIL.COM




COLUMBIA COUNTY BUILDING & ZONING
135 NE HERNANDO AVE #21
LAKE CITY, FL, 32055
(386) 758-1008
bldginfo@columbiacountyfla.com

DATE: 05/21/2026
PERMIT: 000055382
SUBJECT: GARAGE SLAB DESIGN CHANGE REQUEST
SITE ADDRESS: 2678 SW CR 778, FORT WHITE, FL, 32038

THIS LETTER SERVES TO DOCUMENT A REVISION TO THE GARAGE SLAB DESIGN. THE ORIGINAL SLAB DESIGN WAS INTENDED TO ACCOMMODATE HEAVIER VEHICLE LOADING CONDITIONS ASSOCIATED WITH LARGER TONNAGE VEHICLES. SUBSEQUENT REVISIONS TO THE BUILDING LAYOUT NOW INCLUDE A FRAMED FLOOR SYSTEM ABOVE THE GARAGE AREA, AND THE SPACE IS INTENDED TO BE UTILIZED FOR STANDARD PASSENGER VEHICLES AND LIGHTER LOADING CONDITIONS ONLY. BASED ON THE REVISED INTENDED USE AND REDUCED VEHICLE LOADS, THE GARAGE SLAB DESIGN HAS BEEN MODIFIED TO CONSIST OF A 4-INCH CONCRETE SLAB REINFORCED WITH 6"X6" W1.4XW1.4 WELDED WIRE FABRIC (WWF). THE PROPOSED SLAB CONFIGURATION IS STRUCTURALLY ADEQUATE AND SUITABLE FOR THE ANTICIPATED LIGHT-DUTY VEHICLE LOADS ASSOCIATED WITH THE GARAGE SPACE.

IT IS MY PROFESSIONAL OPINION THAT THE REVISED SLAB THICKNESS AND REINFORCEMENT ARE ADEQUATE FOR THE INTENDED LIGHTER-DUTY RESIDENTIAL VEHICLE LOADING CONDITIONS.

THANK YOU,
JOSH KING
JBROTHER'S HOME INSPECTION & ENGINEERING SERVICES



THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY JOSHUA D. KING ON THE DATE ADJACENT TO SEAL.

SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.