

FIELD DENSITY WORKSHEET

CLIENT Amira Builders DATE 5-18-22
 PROJECT NO. _____
 PROJECT NAME Short Res PERMIT NO. _____
 EARTH CONTRACTOR 269 SE CR 349 Lake City TESTED BY CE
 COMPACTION REQUIREMENT (%) 95 Standard Proctor
 Modified Proctor FIELD CONTACT _____
 TOTAL ON-SITE TIME _____ MILES FROM OFFICE _____
 Limerock Subgrade Pipe Backfill Building Pad Building Footing Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
Approx 15' NW of SE corner	1045	9.5	12"	12"	32	1054	1021	97.7
Approx CR206 PAD	7	9	7	7	38	1075	1036	991
Approx 15' SE of NW corner	7	9	7	7	36	1065	1028	984

REMARKS _____

* Density failed to meet minimum project requirement
 ** Retest indicates minimum density requirement was obtained.
 () Client is aware of unsatisfactory test results.