



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
ON-SITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM (OSTDS)

PERMIT NO. 26-857
DATE PAID: 6/24/20
FEE PAID: 310.00
RECEIPT #: 2311887

APPLICATION FOR CONSTRUCTION PERMIT

APPLICATION FOR:

☒ New System ☐ Existing System ☐ Holding Tank ☐ Innovative
☐ Repair ☐ Abandonment ☐ Temporary ☐

APPLICANT: Thomas Stinson (Morgan) EMAIL: NFLSEPTICTANK@COMCAST.NET

AGENT: ROBERT FORD III- NORTH FLORIDA SEPTIC TANK INC TELEPHONE: 386-755-6372

MAILING ADDRESS: 741 SE STATE ROAD 100, LAKE CITY FL 32025

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.105(3)(m) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

PROPERTY INFORMATION

LOT: — BLOCK: — SUBDIVISION: — OSTDS REMEDIATION PLAN? ☐ Y / ☐ N]
PLATTED: —

PROPERTY ID #: 02-48-15-00330-009 ZONING: — I/M OR EQUIVALENT: ☐ Y / ☐ N]

PROPERTY SIZE: 46.52 ACRES WATER SUPPLY: ☒ PRIVATE PUBLIC ☐ ≤ 2000 GPD ☐ > 2000 GPD

IS SEWER AVAILABLE AS PER 381.0065, FS? ☒ Y / ☐ N] DISTANCE TO SEWER: — FT

PROPERTY ADDRESS: 130 SW Koonville Ave, Lake City FL

DIRECTIONS TO PROPERTY: CR 252 to Koonville Ave + R follow to site on left
Before
Driveway just before 2692 SW Koonville Ave follow to back of property

BUILDING INFORMATION

☒ RESIDENTIAL ☐ COMMERCIAL

Unit No.	Type of Establishment	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table I, Chapter 62-6, FAC
1	MH	4	2410	
2				
3				
4				

☐ FLOOR/EQUIPMENT DRAINS ☐ OTHER (SPECIFY) —

SIGNATURE: Robert Ford 999 DATE: 6-22-2020



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM (OSTDS)

CONSTRUCTION PERMIT

Permit No. 12-SC-4113468
Application No. AP2311887
Date Paid: 06/24/2026
Fee Paid: 55
Receipt No. 12-PID-8038831
Document No. PR2396840
Facility ID.

Type ☒ New System ☐ Existing System Modification ☐ Repair ☐ Abandonment ☐ Temporary
Subtype ☒ Aerobic Treatment Unit ☐ Non-Innovative PBTS ☐ Innovative PBTS ☐ Innovative Non PBTS
☐ Holding Tank ☐ Other (describe)

Applicant: THOMAS**26-0517 STINSON

Property Address: SW KOONVILLE Ave City Lake City State FL Zip 32024

Lot: Block: Subdivision:

Property ID No. 00330-009 [Section, Township, Range, Parcel Number, or Tax ID No.]

The system must be constructed in accordance with specifications and standards of Section 381.0065, F.S., and Chapter 62-6, F.A.C. Department approval of system does not guarantee satisfactory performance for any specific period of time. Any change in material facts, which served as a basis for issuance of this permit, require the applicant to amend the permit application. Such amendments may result in voiding this permit. Issuance of this permit does not exempt the applicant from compliance with other federal, state, or local permitting required for development of this property.

SYSTEM DESIGN AND SPECIFICATIONS

Tank

500 Gallons / GPD capacity ☐ Septic Tank ☒ Aerobic Treatment Unit ☐ Multi-chambered ☐ In series
Gallons / GPD capacity N/A ☐ Multi-chambered ☐ In series
Gallons Grease Interceptor capacity
Gallons Dosing Tank capacity gallons at doses per 24 hours doses per 24 hours

Drainfield

375 Square feet Drainfield system
Square feet N/A system
System type ☒ Standard ☐ Filled ☐ Mound ☐
Configuration ☒ Trench ☐ Bed ☐
Location of benchmark/reference point Large oak tree west of site
Elevation of proposed system site 24 ☒ inches ☐ feet ☐ above ☒ below benchmark/reference point
Bottom of drainfield to be 42 ☒ inches ☐ feet ☐ above ☒ below benchmark/reference point
Fill required 0 inches Excavation required inches

Other

The system is sized for 4 bedrooms with a maximum occupancy of 8 persons (2 per bedroom), for a total estimated flow of 400 gpd. *Customer wants 600gl - 562.5"

Specifications by Robert W Ford Master Contractor
Printed Name Title Signature

Approved by Sean P Havens Environmental Specialist II
Printed Name Title Signature
Florida Department of Health in Columbia County
Office

Date issued 08/17/2026 Expiration date 02/17/2028

APPLICATION FOR CONSTRUCTION PERMIT
1 "5401

- PART II - SITEPLAN



Page 2 of 4