

Notice of Prevention for Subterranean Termites

(As required by Florida Building Code (FBC) 104.2.6)



A locally owned
company serving
you since 1972

17856 U.S. 129 • McALPIN, FLORIDA 32062
(386) 362-3887 • 1-800-771-3887 • Fax: (386) 364-3529

176 SW KIMBERLY LANE LAKE CITY 32024

Address of Treatment or Lot/Block of Treatment

2-18-25

Date

1:42 pm

Time

OTT # 84

Applicator

Prowise

Product Used

Imidacloprid

Chemical used (active ingredient)

84 gal

Number of gallons applied

.1%

Percent Concentration

NA

Area treated (square feet)

210 LFAT

Linear feet treated

FINAL GRADE

Stage of treatment (Horizontal, Vertical, Adjoining Slab, retreat of disturbed area)

As per 104.2.6 - If soil chemical barrier method for Subterrean termite prevention is used, final exterior treatment shall be completed prior to final building approval.

The building has received a complete treatment for the prevention of subterranean termites. Treatment is in accordance with rules & laws established by the Florida Department of Agriculture & Consumer Services. Initial and date this line.

2-18-25 OTT

If this notice is for the final exterior treatment initial and date this line.

2-18-25 OTT