

Inspection Checklist for Permit #000056323

Notes:

Order	Category	Inspection	Requirements
1	Electrical	1st Underground Rough-In <i>Verifies conduit, wiring, and grounding prior to backfill. Ref: NEC Art. 300.5</i>	
2	Electrical	Permanent Power <i>Releases power once service equipment is complete and safe. Ref: NEC Art. 230</i>	
3	Building	Final <i>Ensures structure is complete, safe, and code-compliant before Certificate of Occupancy. Ref: FBC 110.5</i>	
4	Engineering	Zoning Final <i>Ensures all zoning-related site requirements (buffers, landscaping, setbacks, parking) are satisfied before CO. Columbia County LDR</i>	