



CAL-TECH TESTING, INC.

ENGINEERING & TESTING LABORATORY
 P.O. Box 1625, Lake City, FL 32056-1625
 2907 Spring Glen Road • Jacksonville, FL 32207

Lake City • (386) 755-3633
 Fax • (386) 752-5456

Jacksonville • (904) 381-8901
 Fax • (904) 381-8902

JOB NO.: 26-418
 DATE TESTED: 5-27-26

REPORT OF IN-PLACE DENSITY TEST

55643

ASTM METHOD: (D-2922) Nuclear (D-2937) Drive Cylinder Other

PROJECT: 348 SW Tall Pine Court Lake City

CLIENT: ADF concrete

GENERAL CONTRACTOR: SAC **EARTHWORK CONTRACTOR:** SAC

SOIL USE (SEE NOTE): I **SPECIFICATION REQUIREMENTS:** 95%

TECHNICIAN: S.D. Kyr

MODIFIED (ASTM D-1557): **STANDARD (ASTM D-698):** _____

TEST NO.	TEST LOCATION	TEST:		PROCTOR NO.	WET DENS. LBS./CU.FT.	DRY DENS. LBS./CU.FT.	MOIST PERCENT	% MAX. DENS.
		DEPTH	ELEV. LIFT					
	18ft S 13ft W from NE corner	12in		105.3	110.7	106.8	3.6	101
	20ft N 4ft W from SE corner	12in		105.3	108.8	104.1	4.5	99
	26ft S 12ft E from NW corner	12in		105.3	113.7	107.4	5.6	102

REMARKS: _____

PROCTOR NO.	SOIL DESCRIPTION	PROCTOR VALUE	OPT. MOIST.
		105.3	

NOTE: 1. Building Fill 2. Trench Backfill 3. Base Course 4. Subbase/Stabilized Subgrade 5. Embankment 6. Subgrade/Natural Soil 7. Other
 The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with generally accepted methods and standards. Since material conditions can vary between test location and change with time, sound judgement should be exercised with regard to the use and interpretation of the data.