



17 MARCH 2020

RE: SLAB REINFORCING

CONTRACTOR: RHETT SMITHEY

PROJECT: LOT 14, CROSSWINDS

BUILDING OFFICIAL: COLUMBIA COUNTY BUILDING DEPARTMENT

TO WHOM IT MAY CONCERN,

ADDING FIBERMESH TO THE CONCRETE MIXTURE WILL SUFFICE TO INSURE PROPER REINFORCING ALONG WITH INSTALLING WIRE MESH WITHOUT CHAIRS.

IF YOU HAVE ANY FURTHER QUESTIONS, OR IF WE MAY BE OF FURTHER SERVICE, PLEASE CONTACT MY PERSONAL REPRESENTATIVE FOR THIS PROJECT:

WILL MYERS
WM DESIGN & ASSOCIATES, INC.
426 SW COMMERCE DR. STE 130
LAKE CITY, FLORIDA 32025
PHONE: 386.867.1394
EMAIL: will@willmyers.net

THANK YOU,

SINCERELY,

NICHOLAS PAUL GEISLER, ARCHITECT AR0007005

39448