



CAL-TECH TESTING, INC.

ENGINEERING & TESTING LABORATORY

P.O. Box 1625, Lake City, FL 32056-1625
2907 Spring Glen Road • Jacksonville, FL 32207

Lake City • (386) 755-3633
Fax • (386) 752-5456

Jacksonville • (904) 381-8901
Fax • (904) 381-8902

JOB NO.: 26-410
DATE TESTED: 6-16-20

REPORT OF IN-PLACE DENSITY TEST

ASTM METHOD: (D-2922) Nuclear (D-2937) Drive Cylinder Other

PROJECT: 118 SW Timberland CT

CLIENT: DWC Contracting

GENERAL CONTRACTOR: SAC EARTHWORK CONTRACTOR:

SOIL USE (SEE NOTE): 1 SPECIFICATION REQUIREMENTS: 95%

TECHNICIAN: C. W.

MODIFIED (ASTM D-1557): STANDARD (ASTM D-698):

TEST NO.	TEST LOCATION	TEST:		PROCTOR NO.	WET DENS. LBS./CU.FT.	DRY DENS. LBS./CU.FT.	MOIST PERCENT	% MAX. DENS.
		DEPTH ELEV. LIFT						
1	N Corner 10' SE x 5' SW	12		1	121.4	114.5	6.0	98
2	Center of Pad	12		1	120.7	113.4	6.5	97
3	S corner 5' NE x 10' NW	12		1	121.1	113.0	7.1	97

REMARKS:

PROCTOR NO.	SOIL DESCRIPTION	PROCTOR VALUE	
		116.9	

