



# NFPS



PO BOX 3823  
LAKE CITY, FL 32056



PHONE (386) 752-4675  
FAX (386) 752-4674



www.nfps.net

DATE: Wednesday, January 26, 2022

TO: Columbia County Building Department

FROM: James B. Smith, PSM – North Florida Professional Services


CC: Keith Eaker

RE: Finished Floor Elevation – 265 SW Jewell Lake Drive, Lake City FL 32024

This is to certify that the following elevations of were obtained on the finished floor of a building constructed on Parcel # 33-3S-16-02439-243 at the address of 265 SW Jewell Lake Drive, Lake City, FL 32024

**Permit # 42787 FFE: 127.94'**

The required elevation is 125.50'

  
\_\_\_\_\_  
James B. Smith, PSM  
Florida Certification No. 7355

