

Inspection Checklist for Permit #000055199

Notes:

| Order | Category | Inspection | Requirements |
|--------------|-----------------|--|---------------------|
| 1 | Building | Framing <i>Reviews structural framing, load paths, fire blocking, and MEP rough-ins prior to insulation. Ref: FBC 110.3(3)</i> | |
| 2 | Electrical | 2nd Rough-In <i>Checks wiring, panel placement, and boxes before cover-up. Ref: NEC Art. 110.3</i> | |
| 3 | Mechanical | Rough In <i>Checks ductwork, equipment location, and condensate before covering. Ref: FBC-M 603</i> | |
| 4 | Plumbing/Gas | 2nd Rough-In <i>Reviews piping, venting, and fixtures before wall close. Ref: FBC-P 312</i> | |
| 5 | Building | Insulation <i>Verifies insulation type, R-value, and installation before drywall. Ref: FBC Energy C101.5</i> | |
| 6 | Building | Final <i>Ensures structure is complete, safe, and code-compliant before Certificate of Occupancy. Ref: FBC 110.5</i> | |